



Arnold Schwarzenegger
Governor

REAL TIME SYSTEM OPERATIONS 2006 — 2007

Prepared For:
California Energy Commission
Public Interest Energy Research Program

Prepared By:
Lawrence Berkeley National Laboratory

CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

PIER FINAL PROJECT REPORT

Month Year
CEC-500-2008-XXX

Prepared By:

Lawrence Berkeley National Laboratory
Joseph H. Eto
Joseph H. Eto, Manu Parashar and Nancy Jo Lewis
Berkeley, CA 94720
Commission Contract No. 500-02-004
Commission Work Authorization No: MR-041

Prepared For:

Public Interest Energy Research (PIER)
California Energy Commission

Jamie Patterson
Contract Manager

Mike Gravely
Program Area Lead
ENERGY SYSTEMS INTEGRATION

Mike Gravely
Office Manager
ENERGY SYSTEMS RESEARCH

Martha Krebs, Ph.D.
PIER Director

Thom Kelly, Ph.D.
Deputy Director
ENERGY RESEARCH & DEVELOPMENT DIVISION

Melissa Jones
Executive Director



DISCLAIMER

This report was prepared as the result of work sponsored by the California Energy Commission. It does not necessarily represent the views of the Energy Commission, its employees or the State of California. The Energy Commission, the State of California, its employees, contractors and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the uses of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the California Energy Commission nor has the California Energy Commission passed upon the accuracy or adequacy of the information in this report.

Disclaimer

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor The Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or The Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, or The Regents of the University of California.

Ernest Orlando Lawrence Berkeley National Laboratory is an equal opportunity employer.

Acknowledgement

CERTS performers are grateful for the technical direction provided by The Public Interest Energy Research (PIER) Transmission Research Program (TRP) and Energy Commission PIER staff Jamie Patterson, and California Institute for Energy and Environment (CIEE) staff Merwin Brown, Jim Cole, Virgil Rose and Larry Miller.

Task 2.0 was led by Manu Parashar, Electric Power Group (EPG), with assistance from research performers Jim Dyer, Simon Mo, Peng Xiao, Jose Coroas, EPG; Ken Martin, Bonneville Power Administration (BPA), Dan Trudnowski, Montana Tech, and Ian Dobson, University of Wisconsin. California Independent System Operator (California ISO) advisors for Task 2.0 were Dave Hawkins, Jim Hiebert, Brian O'Hearn, Greg Tillitson, Paul Bleuss, and Nan Liu.

Task 3.0 was led by Manu Parashar, EPG, with assistance from research performers Abhijeet Agarwal, and Jim Dyer, EPG; Ian Dobson, University of Wisconsin, Yuri Makarov and Ning Zhou, Pacific Northwest National Laboratory (PNNL). California ISO advisors for Task 3.0 were Soumen Ghosh, Matthew Varghese, Patrick Truong, Dinesh Salem-Natarajan, Yi Zhang and Robert Sparks.

Citation

Eto, Joseph H., Manu Parashar, Nancy Jo Lewis. Consortium for Electric Reliability Technology Solutions (CERTS). 2008. Real Time System Operations (RTSO) 2006 - 2007. California Energy Commission, PIER Transmission Research Program. CEC-500-2008-XXX.

Preface

The Public Interest Energy Research (PIER) Program supports public interest energy research and development that will help improve the quality of life in California by bringing environmentally safe, affordable, and reliable energy services and products to the marketplace. The PIER Program, managed by the California Energy Commission (Energy Commission), conducts public interest research, development, and demonstration (RD&D) projects to benefit California.

The PIER Program strives to conduct the most promising public interest energy research by partnering with RD&D entities, including individuals, businesses, utilities, and public or private research institutions.

PIER funding efforts are focused on the following RD&D program areas:

- Buildings End-Use Energy Efficiency
- Energy Innovations Small Grants
- Energy-Related Environmental Research
- Energy Systems Integration
- Environmentally Preferred Advanced Generation
- Industrial/Agricultural/Water End-Use Energy Efficiency
- Renewable Energy Technologies
- Transportation

Real Time System Operations (RTSO) 2006 - 2007 is the final report for the Real Time System Operations project (contract number 500-03-024 MR041 conducted by the Consortium for Electric Reliability Technology Solutions (CERTS). The information from this project contributes to PIER's Transmission Research Program.

For more information about the PIER Program, please visit the Energy Commission's website at www.energy.ca.gov/pier or contact the Energy Commission at 916 654 5164.

Contact and subcontract relationships and flow downs

500-02-004 MR-041 University of California/California Institute for Energy and the Environment \$2,500,000

Contractor Name	Contract Amount	Subcontract Amount
Lawrence Berkeley National Laboratory	\$2,500,000	
Bonneville Power Administration		\$22,000
Electric Power Group		\$2,065,000
Pacific Northwest National Laboratory		\$155,000
Trudnowski Consulting		\$31,000
University of Wisconsin		\$21,000
Washington State University		\$20,000

Table of Contents

Preface	iii
1.0 Task 2.0: Real-Time Applications of Phasors for Monitoring, Alarming and Control	1
1.1. Executive Summary	1
1.2. Introduction	3
1.3. Task Objectives	7
1.4. Task Approach/Methods.....	8
1.5. Task Outcomes	10
1.6. Conclusions and Recommendations	22
2.0 Task 3.0 Real-Time Voltage Security Assessment (RTVSA) Prototype Tool	25
2.1. Executive Summary	25
2.2. Introduction	27
2.3. Task Objectives	31
2.4. Task Approach/Methods.....	32
2.5. Task Outcomes	33
2.6. Conclusions and Recommendations	40
3.0 References.....	43
4.0 Glossary	45

Appendices

Appendix A, Phasor Feasibility Assessment and Research Results Report

Appendix B, Real-Time Voltage Security Assessment Algorithms and Framework Report

Appendix C, Real-Time Voltage Security Assessment Algorithm's Simulation and Validation Results

Appendix D, Real-Time Voltage Security Assessment Summary Report

Appendix E, Real-Time Voltage Security Assessment Functional Specifications for Commercial Grade Application

List of Figures

Figure 1. Task 2.0 Multi-Year Research Roadmap for California ISO Phasor Project.....	6
Figure 2. RTDMS Situational Awareness Dashboard.....	12
Figure 3. RTDMS Platform System Architecture.....	13
Figure 4. Small-Signal Stability Monitoring Display	16
Figure 5. Use of Additional PMUs to Monitor Existing Nomograms in Real-Time.....	18
Figure 6. Predicting P-V Curves and Voltage Stability Using Phasors	20
Figure 7. Task 3.0 Multi-Year Research Roadmap for Real-Time Voltage Security Assessment (VSA).....	28
Figure 8. RTVSA Algorithms Flowchart.....	36
Figure 9. RTVSA System Architecture	39

List of Tables

Table 1. Summary of RTVSA capabilities.....	38
---	----

Report Organization

The Real Time System Operations 2006 – 2007 project consisted of two parallel technical tasks:

- Task 2.0 Real-Time Applications of Phasors for Monitoring, Alarming and Control
- Task 3.0 Real-Time Voltage Security Assessment Prototype Tool

The tasks that are funded under this work authorization represent the third phase of a multi-project ongoing RD&D activity that is coordinated by the Consortium for Electric Reliability Technology Solutions (CERTS) for the Energy Commission's Public Interest Energy Research (PIER) Transmission Research Program (TRP). Earlier phases of this research were conducted through an RD&D contract directly with Lawrence Berkeley National Laboratory (LBNL), Contract # 150-99-003, and through several task orders from the California Institute for Energy and Environment (BOA#20, Task Order 21, Task Order 24, and Work Authorization # MR-036, PIER Contract #500-02-004). Additional research on Task 2.0, through a separate subsequent contract, has been proposed which will build upon the work that was initiated in this work authorization.

An overview of Real Time System Operations 2006 – 2007 is provided in the Project Introduction. Additional reporting is organized separately for each technical task.

Project Introduction

The increased need to manage the U.S. electricity grid more actively in real time is in large part a result of the ongoing transition from a system operated by vertically-integrated utilities to one that's operation is coordinated through the actions of a competitive energy market. Markets have replaced utilities in performing the match between generation and demand, adding to the operator's burden of controlling the grid with revised operational responsibilities and more unpredictable system behavior. This transition has confronted system operators with dramatic changes from past practice, including unregulated generation owners and market participants engaging in increased volumes of energy trades over large distances. To meet these new needs operators have had, until now, only the previous generation of grid management tools, which were designed for a centrally planned and controlled system whose relatively predictable conditions did not require the kind of minute-by-minute decision making demanded by today's electricity markets. In fact, the traditional approach was to analyze, months in advance, a few contingencies for a handful of selected peak load conditions, ignore other periods and contingencies, and then set conservative operating limits for the system. The increasing incidence of not only managed and unmanaged power outages but also transmission congestion, energy price spikes, frequency abnormalities, and voltage degradation on today's grid makes it clear that the traditional management tools and approaches must now be enhanced.

The best strategy for new analytical tools development is to equip system operators with better real-time information about actual safe operating margins so that they can better manage the system within its true limits. Such tools need to analyze geographically dispersed events in real-time. This requires using time-stamped data to combine information collected over wide areas for dynamic system analysis to inform dynamic response through automatic system controls and operator alarms. Analytical tool development is challenged by the system complexity caused by the thousands of components, and the multitude of operating conditions created by minute-to-minute changes in demand, generation, planned and unplanned equipment outages, and market participant actions.

The strategic direction the Energy Commission has sponsored for this research includes: (1) enhancement of tools that obtain and translate real-time data for analysis and operator actions; (2) better system dynamic models; and (3) improved understanding of system parameters (e.g. loads and generators) during system emergencies. The new tools collect and analyze a myriad of data from multiple sources, rapidly calculate the risk of system failure, and translate the information into multi-view graphic displays that allow operators to quickly grasp grid conditions and take action to address emerging problems. These tools and technologies will set the stage for a future smart, switchable electricity grid that will be able to automatically sense and respond to system emergencies.

The objectives of this project were to research, develop, test and evaluate prototypes for new, first-of-a-kind real-time software tools that support reliability management by California Independent System Operator (California ISO).

The overall goals of this project were to:

Improve the reliability and quality and cost/value of California's electricity through the use of new and better real-time operational tools.

Improve the energy cost/value of California's electricity.

- Research, develop, test and evaluate the operational performance of two new prototype real-time operational tools to meet California ISO specifications.
- Initiate the transfer of these prototypes to a vendor selected (and paid for) by California ISO for implementation as production-grade operating tools
- Communicate research results to California utilities, Bonneville Power Administration and other entities involved in the Transmission Research Program (TRP).

The tasks that were funded under this work authorization represent one phase of a multi-project ongoing RD&D activity that is being coordinated by the Consortium for Electric Reliability Technology Solutions (CERTS) for the Energy Commission's TRP. Earlier phases of the PIER sponsored research were through an RD&D contract directly with Lawrence Berkeley National Laboratory (LBNL) under PIER Contract # 150-99-003, and through several task orders from the California Institute for Energy and Environment (BOA#20, Task Order 21, Task Order 24, and Work Authorization # MR-036, PIER Contract #500-02-004). Additional research through a separate subsequent contract has been proposed to build upon the work initiated on Task 2.0 in this work authorization.

Tasks and deliverables described below refer solely to accomplishments that have been completed under the funding for this work authorization.

Abstract

The Real Time System Operations (RTSO) 2006-2007 project focused on two parallel technical tasks: (1) Real-Time Applications of Phasors for Monitoring, Alarming and Control; and (2) Real-Time Voltage Security Assessment (RTVSA) Prototype Tool. The overall goal of the phasor applications project was to accelerate adoption and foster greater use of new, more accurate, time-synchronized phasor measurements by conducting research and prototyping applications on California ISO's phasor platform - Real-Time Dynamics Monitoring System (RTDMS) – that provide previously unavailable information on the dynamic stability of the grid. Feasibility assessment studies were conducted on potential application of this technology for small-signal stability monitoring, validating/improving existing stability nomograms, conducting frequency response analysis, and obtaining real-time sensitivity information on key metrics to assess grid stress. Based on study findings, prototype applications for real-time visualization and alarming, small-signal stability monitoring, measurement based sensitivity analysis and frequency response assessment were developed, factory- and field-tested at the California ISO and at BPA. The goal of the RTVSA project was to provide California ISO with a prototype voltage security assessment tool that runs in real time within California ISO's new reliability and congestion management system. CERTS conducted a technical assessment of appropriate algorithms, developed a prototype incorporating state-of-art algorithms (such as the continuation power flow, direct method, boundary orbiting method, and hyperplanes) into a framework most suitable for an operations environment. Based on study findings, a functional specification was prepared, which the California ISO has since used to procure a production-quality tool that is now a part of a suite of advanced computational tools that is used by California ISO for reliability and congestion management.

Key Words: Electricity grid, reliability, real-time operator tools, time synchronized phasor measurements, voltage security.

1.0 Task 2.0: Real-Time Applications of Phasors for Monitoring, Alarming and Control

1.1. Executive Summary

Introduction

Electric industry restructuring in California has led to the formation of larger control areas with correspondingly larger areas of reliability oversight, as well as increased energy transactions over long, region-wide transmission paths. These developments have introduced greater uncertainty into real-time grid operations, which, in turn, have led to the need for better real-time information on actual conditions that can supplement traditional operating guidelines based on off-line studies. Currently, control areas depend on static nomograms produced from off-line simulations conducted several months before the operating season to manage power flows on critical transmission paths. Because actual operating conditions may differ significantly from those assumed in preparing the off-line simulations, the California Independent System Operator (California ISO) system is operated without complete information on adequate reliability margins. To help the California ISO make more accurate and timely assessments of grid instabilities, the Consortium for Electric Reliability Technology Solutions (CERTS) project team enhanced a monitoring, alarming, and control tool—the Real-Time Dynamics Monitoring System (RTDMS)—with phasor technology, creating the first prototype tool to provide the California ISO with real-time information about the dynamic stability of the grid.

Purpose

This is the third phase of a multi-year research activity through which CERTS developed real-time phasor technology-based tools that will provide operating staff with previously unavailable information on the dynamic stability of the grid. The goal is to foster and expedite the adoption of new, more accurate time-synchronized phasor measurements by California ISO and Bonneville Power Administration (BPA) reliability coordinators and control area operators, as well as by California and Western Electricity Coordinating Council (WECC) utility transmission dispatchers. The project significantly leverages companion efforts, also managed by CERTS for the DOE, to promote the use of phasor measurements nationally. For this project, prototype versions 4, 5, and 5.5 of the CERTS Real-Time Dynamics Monitoring System (RTDMS) were developed and delivered for testing and feedback from the California ISO and Bonneville Power Administration (BPA).

Project Objectives

The main objective of Task 2.0 was to research, develop, and factory- and field-test prototypes for several California ISO phasor applications, with project oversight provided by the California ISO. Additional objectives included performing RD&D for an enhanced real-time monitoring tool (i.e., an expansion of a current phasor monitoring application); conducting a feasibility assessment studies, obtaining results from testing new algorithms driven by phasor measurements, developing new prototype applications implementing these algorithms and preparing a project research report on these results; and providing PIER and California utilities

with technical research and development support, including technical and system integration support for utility projects, research roadmaps, Western Electric Coordinating Council (WECC) coordination, and North American Synchrophasor Initiative (NASPI) liaison.

Project Outcomes

To complete Task 2.0 objectives to research, develop, and factory- and field-test prototypes for several California ISO phasor applications, the CERTS team conducted feasibility assessment studies on utilizing phasor measurements to validate and improve existing stability nomograms, evaluated small-signal stability monitoring algorithms, conducted frequency-response analyses, and obtained real-time sensitivity information on grid-stress directly from phasor measurements.

These rigorous RD&D studies enabled the CERTS project team to successfully develop prototype applications offering a rich set of features for wide-area monitoring and analytics, which were factory- and field-tested at the California ISO and at BPA. For example, significant improvements were made to the RTDMS Visualization, version 4, including the incorporation of innovative visualization techniques to deal with screen clutter and information overload, and a dashboard display that uses easy-to-grasp signals akin to traffic-lights (i.e., green, yellow, and red), to provide information on the status of the overall system. For the RTDMS Visualization, version 5, visualization and navigational features were improved through data from algorithm research and end-user feedback. For offline analysis of frequency response, the Event Analyzer prototype was developed. In addition, the CERTS team also developed two new dedicated displays for measurement-based angle sensitivity and voltage sensitivity (incorporated into RTDMS version 5.5) as key indicators of grid-stress and proximity to instability. These advanced real-time applications, while they still remain research prototypes, have been migrated onto the California ISO's production-grade hardware and into its control room, are now an integral and growing part of the California ISO's real-time operations and decision-making processes.

Conclusions

The CERTS project team's efforts to develop phasor applications for real-time monitoring, alarming, and control and test prototype applications on the RTDMS platform has led to the California ISO's adoption of time-synchronized phasor measurements for real-time applications in the Western Interconnection. Not only has the California ISO adopted CERTS' prototype real-time phasor applications, it has now made significant investments in the underlying hardware and supporting maintenance practices to host the prototypes and enable needed future research to develop functional specifications to enable acquisition of commercially-supported, production-quality tools. The infrastructure that now supports the RTDMS prototype applications now meets California ISO production-quality standards and resides on the California ISO's secure network, where it operates very reliably, with over 90 percent of the devices reporting 99 percent data availability, and no system downtime.

The CERTS project team designed RTDMS to meet the California ISO's need for real-time monitoring, alarming, and control, through features such as wide-area monitoring and analytics. Wide-area monitoring will allow operators to evaluate stability margins across critical

transmission paths, detect potential grid instabilities in real time, and mitigate these problems through the system's manual or automatic controls. The system may also be used to improve state estimations and to determine the optimal location for additional phasor measurements. The first of its kind, the system will facilitate technical exchange, collaboration, and resource leveraging with companion phasor measurement-based activities supported by the operating entities and DOE throughout North America, and may lead to further developments in advanced real-time control applications.

Recommendations

The CERTS project team recommends continuing RD&D for prototype applications towards development of functional specifications that California ISO can use to acquire production-quality tools from commercial vendors. The CERTS project team also recommends continuing efforts through the WECC to expand and link phasor measurement units across the entire Western Interconnection.

Benefits to California

The enhanced reliability of the California ISO and the Western Interconnection benefits California by providing reliability coordinators and control area operators with the latest advances in phasor measurement applications. Specifically, these applications will both improve transmission loadability from the point of view of transient stability and also help operate the system within safe regions.

1.2. Introduction

Task 2.0 had three overall goals: 1) accelerating adoption and fostering greater use of new, more accurate, time-synchronized phasor measurements by California ISO reliability coordinators and control area operators, as well as by California and BPA utility transmission dispatchers, 2) providing these real-time operators, starting with California ISO, with previously unavailable information on the dynamic stability of the grid, which in the long run may also provide the basis for the introduction of a new generation of automatic grid controls, and 3) providing technical support and assistance in coordinating phasor applications being researched and developed by California investor-owned utilities.

1.2.1. Background and Overview

California ISO's traditional security-assessment approach, which is based on Supervisory Control and Data Acquisition (SCADA) data and off-line model-based studies conducted long in advance of real time operations, is becoming increasingly unrealistic for real-time operations because it cannot fully anticipate all the conditions that operators may encounter. New technologies, which rely on accurate, high-resolution, real-time monitoring of actual (not modeled) system conditions, are needed to support the California ISO's real-time operations. These new tools and systems will enhance the California ISO's ability to monitor, assess, enable, and, ultimately, automatically take necessary control actions to prevent or mitigate problems in real time.

Applications of phasor measurements will provide the real-time operating staff with previously unavailable, yet greatly needed, tools to avoid voltage and dynamic instability, and monitor

generator response to abnormal significant system frequency excursions. Perhaps of equal or greater importance, the measurement infrastructure will provide the California ISO, in the near term, with an alternate, independent real-time monitoring system that could act as an end-of-line backup for failures affecting California ISO's current SCADA/Energy Management System (EMS); in the long term, it will also become a key element for enabling advanced real-time control with the California ISO's next-generation monitoring system.

Phasor measurement technologies are a leading example of a new generation of advanced grid monitoring technologies that rely on high-speed, time-synchronized, digital measurements. These characteristics are essential for monitoring real-time grid performance, validating (or replacing) off-line nomogram studies, providing advance warning of potential grid instabilities, and, ultimately, enabling the development and introduction of advanced automatic grid control approaches such as adaptive islanding. (Adaptive islanding is the automated reconfiguration and separation of the power system into self-contained electrical "islands" as a preventative measure to avoid cascading outages and major blackouts.)

The first research-grade demonstration of phasor technologies was undertaken by the Department of Energy (DOE), the Electric Power Research Institute (EPRI), BPA, and the Western Area Power Administration (WAPA) in the early 1990s (J. F. Hauer, et al. 1999). The investment was paid in full when data recorded by the system was effectively used to investigate causes of the major 1996 West Coast blackouts. DOE has continued to support outreach for these technologies, and has provided technical support to the Western Electricity Coordinating Council (WECC) committees that rely on these data for off-line and model validation reliability studies. PIER has supported installation of an initial data connection and workstation to support off-line analysis by California ISO staff in 2002. In 2003 and 2004, PIER supported the deployment of a real-time application using phasor technology—a phasor-data link to BPA and WAPA for real-time data—to monitor actual grid conditions (J. Eto, et. al. 2007).

In July 2004, the CERTS Program Review Committee recommended that the Energy Commission and the California ISO continue research, development, and application of this technology. Research focused on determining (1) the appropriate phase angles, rates of phase angle changes, associated ranges around these quantities, including appropriate boundaries or thresholds, and recognizing inescapable uncertainties for various locations in the system; (2) the actions that operators or automatic control equipment should take if there are major deviations; and (3) the desired location for additional phasor monitoring equipment around the WECC. This approach, developed in conjunction with California ISO staff, introduced phasor information to operators, and allowed the CERTS project team to work closely with them to modify and enhance the applications (including training) to increase their confidence in the new real-time application to support their day-to-day activities (CERTS 2007).

During 2004 and 2005, the phasor visualization prototype Real-Time Dynamics Monitoring System (RTDMS), which was initially developed as a stand-alone application, was transformed into a phasor technology research and development platform. The prototype's underlying

functionalities complied with the long-term goal to use phasor technology for wide-area monitoring, alarming, and control (CERTS 2007).

Additionally, in July 2005, CERTS worked with the California ISO to formalize and relate prior and planned phases of the research into a single RD&D roadmap (Figure 1). The roadmap identified three research tracks: (1) input data requirements, (2) applications research and development, and (3) system integration and support. Each track has been implemented in three phases, which are described below:

The first phase established the initial starter phasor network, and built the prototype visualization and monitoring capabilities providing real-time, wide-area visibility to the California ISO operators and Reliability Coordinators. This application included long-term archiving of frequency data collected from the phasor network at high-, sub-second resolution to meet the North American Electric Reliability Corporation / Western Electricity Coordinating Council (NERC/WECC) disturbance monitoring requirements. Support was provided to each of the three California utilities on an as-needed basis. Each utility identified a pilot project to demonstrate phasor technology to address their utility-specific problems. During this phase, Southern California Edison (SCE) expressed its interest in local remedial action controls with phasors; San Diego Gas & Electric (SDG&E), its desire to use phasor measurement unit (PMU) measurements to improve the state estimation results; and PG&E, its interest in monitoring critical paths via PMUs.

The second phase expanded the phasor network coverage by incorporating PG&E's PMU measurements into the network as well as new PMU installations with the BPA and SCE footprints; improved the visualization and monitoring capabilities on the RTDMS platform (e.g., real-time alarming, event detection and capture); evaluated possible advanced applications that could be developed on the platform for wide-area security assessment (WASA); and continued supporting the California utilities' on their pilot projects. In 2005, the CERTS project team formulated a survey to gather industry experts' comments, suggestions, and recommendations for the WASA, and found that the majority of respondents agreed that the use of phasor measurements for modal estimations to assess small-signal stability was an ideal first step towards achieving the WASA project objectives.

During the third phase, which is the subject of this report, research was conducted to assess the feasibility of using phasor measurements for a variety of advanced applications including small-signal stability monitoring, frequency-response assessment, new measurement-based sensitivity metrics, stability nomograms using phasors, and event identification and classification. Many of the applications have also been prototyped on the RTDMS platform (e.g., small-signal stability monitoring, voltage sensitivity monitoring) and factory-tested by the RD&D team, and have undergone field trials at the California ISO and BPA.

During the next phase of this task, currently under discussion with the Energy Commission, research is expected to lead to development of functional specifications that will describe the design, functional, and visualization requirements for commercial-grade tools.

MULTI-YEAR RESEARCH ROADMAP FOR CA ISO PHASOR PROJECTS




Figure 1. Task 2.0 Multi-Year Research Roadmap for California ISO Phasor Project

1.3. Task Objectives

The objective of this task was to research, develop, factory- and field-test prototypes for several California ISO phasor applications in close coordination with, and with oversight provided by California ISO.

The original Task 2.0 objectives, taken from the contract, were to:

- Perform RD&D for an enhanced real time monitoring tool (the functional expansion of current phasor monitoring application) to include:
 1. Real Time Dynamics Monitoring System (RTDMS) Visualization version 4 with dashboard display, clutter management, trending and reporting;
 2. RTDMS Small Signal Stability Monitoring application prototype development, factory-, and field-testing, and production quality commercial functional specification;
 3. RTDMS Wide-Area Real Time Control applications prototype development, factory-, and field-testing and production quality commercial functional specification;
 4. RTDMS Frequency Data Collection and Analysis System prototype development, factory-, and field-testing, and technical support for integration with California ISO system; and
 5. RTDMS Frequency Response and Sensitivity Analysis application, prototype development, factory, and field-testing.
- Prepare a Feasibility Assessment Studies Report to include, but not be limited to, a feasibility assessment and initial scoping for development of a prototype tool for pattern/signature recognition.
- Prepare an Algorithm Results Report for the applications of items 1, 2, 3, & 4 above
- Prepare Production-Quality Functional Specifications for the applications of items 2 & 3 above
- Provide technical research and development support to PIER and California utilities for phasor applications including technical and system integration support for utility projects, research roadmaps, WECC coordination, and EIPP Liaison.
- Prepare the Phasor Applications Project Research Report. This report shall be a summary that includes, but is not limited to, research performed on real-time applications of phasors, research support and coordination.

Principal evidence that objectives of this project have been met:

The CERTS team performed the following RD&D to enhance the real time monitoring tool:

- RTDMS Visualization version 4 incorporated innovative visualization techniques to deal with screen clutter and information overload. A dashboard display was developed that uses easy-to-grasp visuals based on traffic lights (i.e., green, yellow, red) to provide information on the status of the overall system.

- RTDMS Visualization version 5 incorporated visualization and navigational improvements based on algorithm research and end-user feedback.
- PDC to PI interface for Phasor and Frequency Data Collection and Analysis within California ISO's pre-existing, commercial-grade PI Historian tool, which is linked to the California ISO's EMS
- In RTDMS version 5.5, the CERTS team developed two new dedicated displays for measurement based angle sensitivity and voltage sensitivity (i.e. measurement-based Sensitivity Analysis). An RTDMS Event Analyzer prototype tool was also developed to assist with post-disturbance assessment functions such as frequency Response Analysis.

RTDMS Visualization (versions 4, 5, and 5.5), RTDMS Small-Signal Stability Monitoring, and RTDMS Event Analyzer (Frequency Response) prototype applications for an enhanced real-time monitoring tool have been installed and tested at the California ISO. These real-time applications have been migrated by California ISO onto production-grade hardware, and, while they remain research prototypes, they are now being used in the California ISO control room where they are rapidly becoming an integral part of real-time operations, and the decision-making processes.

The Phasor Feasibility Assessment and Research Results Report, which is attached as Appendix A to this report, includes the Feasibility Assessment Studies Report, the Algorithm Results Report, and the Phasor Application Project Research Report.

The CERTS project team held discussions with Southern California Edison (SCE), San Diego Gas & Electric (SDG&E), Pacific Gas & Electric (PG&E), and the California ISO to determine how best to support their research and development needs. CERTS then provided assistance and support to California utilities in their efforts to (1) use phasor measurements to control local remedial actions, (2) improve state estimation, and 3) monitor critical paths. CERTS also provided technical assistance to the California ISO in preparing their multi-year research roadmap, which included the North American Synchrophasor Initiative (NASPI) collaboration and knowledge exchange, the formation of the WECC Wide Area Measurement Task Force (WAMTF), and increased collaboration with industry and academic experts.

1.4. Task Approach/Methods

The task approach involved research on the third phase of each of the three project tracks identified in Figure 1: (a) input data requirements, (b) applications research and development, and (c) system integration and support. Key highlights of the phasor applications project research report entitled Feasibility Assessment and Research Results Report (see Appendix A, Phasor Feasibility Assessment and Research Results Report) are summarized below.

Real-Time Dynamics Monitoring System (RTDMS) Visualization version 4 with dashboard display, clutter management, trending and reporting

The CERTS project team met with California ISO staff to identify requirements for RTDMS version 4. The CERTS team then developed a prototype that featured dashboard displays, clutter management, trending and reporting functions, and factory-tested the application before

installation at California ISO for field-testing and feedback. During the feedback phase, additional functionalities were discussed with the California ISO.

RTDMS Small Signal Stability Monitoring application prototype development, factory-, and field-testing, and production quality commercial functional specification

The CERTS project team met and collaborated with BPA and California ISO to discuss algorithms and framework for the small-signal stability monitoring application. The project team then worked on the algorithms and developed the application based on these algorithms. The application was then factory-tested before it was installed at both the California ISO and BPA for field-testing and feedback. During the feedback phase, additional functionalities were discussed and incorporated into the application.

RTDMS Wide-Area Real-Time Control applications prototype development, factory-, and field-testing, and production quality commercial functional specification

Based on the feasibility assessment study completed in an earlier contract, 500-02-004, the CERTS project team met with the California ISO to develop the use of phasor technology to enhance stability nomograms. The project team then investigated methodologies for improving and enhancing the existing operation nomograms with phasor measurements. During follow-up meetings with Dave Hawkins and Nan Liu from the California ISO, the project team was directed to focus its efforts on the small-signal stability monitoring application. Resources were therefore redirected to conducting research and developing this higher-priority application.

RTDMS Frequency Data Collection and Analysis System prototype development, factory-, and field-testing, and technical support for integration with California ISO system

The CERTS project team met with California ISO to discuss the architecture and definitions of the RTDMS Frequency Data Collection and Analysis System application. The project team then developed, factory-, and field-tested the application to allow users to save frequency data in the California ISO's PI Historian, a commercial- grade production database that resides on the California ISO EMS.

RTDMS Frequency Response and Sensitivity Analysis application prototype factory and field testing

The CERTS project team met with the California ISO to discuss requirements for the RTDMS Frequency Response and Sensitivity Analysis application. The project team then developed, factory-, and fielded tested the new RTDMS Event Analysis application incorporating frequency response analysis capabilities, and additional sensitivity analysis displays within RTDMS version 5.5.

Prepare a Feasibility Assessment Studies Report

The CERTS project team conducted research and evaluated the feasibility of using phasors by performing an extensive on-line literature review of all known existing publications on phasor technologies and applications. In addition, the project team consulted with university professors at Washington State University, the University of Wisconsin, Rensselaer Polytechnic

Institute, and Montana Tech, and with staff at the California ISO. The feasibility assessment studies report was written and incorporated into the Phasor Applications Project Research Report.

Prepare an Algorithm Results Report

Based on the findings from the feasibility assessment studies it had conducted earlier, the project team evaluated possible solutions to address the feasibility of using phasors to (1) improve stability nomograms; (2) monitor small-signal stability; (3) measure key sensitivities related to voltage stability or dynamic stability; (4) assess interconnection frequency response; and (5) apply graph theory concepts for pattern recognition. The project team wrote algorithms conduct tests of these solutions using data provided by the California ISO. The algorithm results were incorporated into the Phasor Applications Project Research Report.

Prepare the Phasor Applications Project Research Report

The CERTS team summarized Task 2.0 research in the Phasor Applications Project Research Report. See Appendix A, Phasor Feasibility Assessment and Research Results Report, which includes the feasibility assessment study and algorithms results.

Prepare Production-Quality Functional Specifications for the Small Signal Stability Monitoring and RTDMS Wide-Area Real-Time Control applications

If the California ISO agreed that the research had advanced sufficiently, the CERTS project team was to next develop the functional specification for a production-quality small-signal stability tool. In March 2007, the California ISO directed CERTS to perform additional research on this application, and not to prepare the production-quality functional specifications at this stage of development.

Provide technical research and development support to PIER and California utilities for phasor applications including technical and system integration support for utility projects, research roadmaps, WECC coordination, and EIPP Liaison

CERTS provided assistance and support to (1) SCE in its use of phasor measurements for local remedial action control, (2) SDG&E in its use of phasor measurements to improve its state estimator, and (3) PG&E's in its use of phasor measurements to assist in monitoring critical paths. CERTS also provided technical assistance to the California ISO in preparing a multi-year research roadmap, which included NASPI collaboration and knowledge exchange, the formation of the WECC-WAMTF, and increased collaboration with industry and academic experts.

1.5. Task Outcomes

The project team completed research on the third phase of each of the three project tracks identified in Figure 1: (a) input data requirements; (b) applications research and development; and (c) system integration and support. This summary reviews key finding and highlights derived from a separate appendix that provides greater technical detail on each of these

accomplishments. (See Appendix A, Phasor Feasibility Assessment and Research Results Report).

With respect to input data requirements, CERTS utilized and expanded the current WECC and California ISO phasor infrastructure as the input data source for the real-time applications. Then, when C37.118 became the approved Institute of Electrical and Electronics Engineers (IEEE) standard for real time streaming phasor data, the RTDMS platform was adapted to support this new format. Finally, as discussed below, RTDMS version 5 included development of an interface to the California ISO's PI Historian, which provides a bridge for phasor data to migrate into other applications that reside on California ISO's EMS

With respect to applications research and development, the key accomplishment of the project was development, factory-testing, installing, and field-testing of RTDMS versions 4, 5, and 5.5 at the California ISO. Prior to each development cycle for an enhanced version of RTDMS, a prototype functional specification document was provided to the California ISO for its review and feedback. Comments from the California ISO were then incorporated into each version.

The CERTS project team worked closely with the California ISO operations staff to solicit their input on enhancements to expand the visualization, monitoring, and alarming capabilities of the RTDMS platform. The RTDMS Visualization version 4 included dashboard display, tiered visualization architecture to manage display clutter, and long-term trending capacities (Figure 2). RTDMS Visualization version 5 included visualization and navigation improvements based on operator feedback, PDC-PI interface for archiving data into California ISO's PI historian and reporting services. RTDMS Visualization version 5.5 included measurement based sensitivity displays.

In addition, the first ever small-signal stability monitoring prototype application was developed. This application assesses the stability of low frequency inter-area oscillations in real-time, and from data captured under ambient system conditions. This tool has the ability to display dynamic activity using spectral waterfall plots, and to trace mode estimates, both their characteristic frequency and damping properties, using visuals geared towards a real-time operations environment.

Preliminary work was completed on the RTDMS Wide-Area Real-Time Control, but at the California ISO's request, resources were redirected to developing other higher-priority applications.

The successful completion of these tasks was made possible by off-line analyses and research conducted by the CERTS project team in consultation with California ISO staff, feedback from operators on the usability and usefulness of the information provided by the network, and the means developed to present the information. These interactive processes continued in direct parallel with the delivery of specific functionalities and prototype displays.




Figure 2. RTDMS Situational Awareness Dashboard

With respect to systems integration and support, the CERTS project team supported the California ISO in its migration of the RTDMS platform and phasor applications from the RD&D test bed to the California ISO's production-quality hardware, which resides in the California ISO operations environment. This major accomplishment significantly advances the development of this promising technology into an actual commercial application (Figure 3).




Figure 3. RTDMS Platform System Architecture

The specific project objectives have been taken directly from the contract. The outcomes of each research task are as follows:

Real-Time Dynamics Monitoring System (RTDMS) Visualization version 4 with dashboard display, clutter management, trending and reporting

The RTDMS Visualization version 4 incorporated innovative visualization techniques to deal with screen clutter and information overload. With the rapidly growing number of PMUs within the WECC phasor network, a key focus was on improved visualization to integrate information within standardized displays. Careful attention was placed on avoiding clutter. The solution included tiered visualization architecture with drill-down capabilities from

centrally configured and standardized “global” displays for wide-area viewing at the Interconnection and Reliability Coordinator levels. This tiered visualization facilitates communication across utilities for consistency, but also provides a means for development of “local” end-user customized displays at the utility level that complement the wide-area displays. The highest tier consists of a “dashboard” summary display that uses easy-to-grasp traffic-light visuals (Figure 2) and gauges to provide information on a set of predefined metrics that characterize the overall system status. Green signifies that the metric is well within its threshold limit and that things are normal; yellow indicates that the metric is approaching its threshold limit and further investigation is needed; and red or blue means that the metric is low or high, respectively, and that immediate action is required. Other enhancements included reporting capabilities on PMU performance, alarm history, and long-term trends and statistics on various metrics to assist with the system baselining functions.

In January 2006, under the prior contract, the CERTS team provided training at the California ISO on an earlier version of the RTDMS, version 3, platform. During these training sessions, California ISO reliability coordinators Dave Hawkins, Nan Liu, Greg Tilitson, and Paul Blues were consulted on their requirements for RTDMS, version 4. During the next development stage, the project team incorporated the California ISO’s requirements for dashboard displays, clutter management, and trends and reporting functions. Training commenced on the application that was installed in May 2006 on two machines in the testing room, and one machine installed on the Reliability Coordinators desk on the dispatch floor (Control Room) at the California ISO.

In addition, the real-time phasor monitoring applications on the RTDMS platform underwent a series of functional enhancements incorporating new capabilities that were extensively field-tested at the California ISO and at BPA; RTDMS Visualization version 5, which included visualization and navigation improvements based on operator feedback, and a PDC-PI interface for archiving data in the California ISO’s PI historian and reporting services, was released. RTDMS Visualization, version 5.5, included measurement-based sensitivity displays. Prior to each development cycle, a prototype functional specification document was provided to the California ISO for their review and feedback. Comments from the California ISO were then incorporated into each version. The RTDMS platform currently supports 12 clients at the California ISO’s main Folsom Facility and two at the Alhambra backup center.

RTDMS Small Signal Stability Monitoring application prototype development, factory-, and field-testing, and production quality commercial functional specification

The first ever small-signal stability monitoring prototype application was developed and delivered to the California ISO. This application assesses the stability of low-frequency inter-area oscillations in real-time using data captured under ambient system conditions. The key capacities of this tool are its ability to display dynamic activity using spectral waterfall plots, and to trace mode estimates, both their characteristic frequency and damping properties, using visuals geared towards a real-time operations environment.

In February 2006, the CERTS project team met with Bill Middelstadt, Carson Taylor, Ken Martin, Dmitry Kosterev, and Jim Gronquist from BPA, which has been a technical leader among utilities in the industry on the topic of small-signal stability. The discussion focused on algorithms and framework for the small-signal stability monitoring application. During the next several months the project team worked on the algorithms and developed the application based on the algorithms.

During 2006, a *Small-Signal Stability Monitoring* application was developed to utilize these algorithms to monitor and track the low-frequency inter-area modes prevalent within the power system in real time and under ambient system conditions. The application underwent field trials at both the California ISO and BPA prior to being placed in control rooms. In October 2006, the project team reviewed the application with California ISO staff Dave Hawkins, Nan Liu, Greg Tillitson, Paul Bluess, Jim Herbert, and Alan Amark. The application was further refined in response to their feedback, and later installed in the California ISO testing room and on the engineers' desks. In December 2006, after factory-testing the application, it was installed in the testing room at the California ISO.

In February 2007, Jim Detmers and Jim McIntosh from the California ISO organized a Grid Oscillation Workshop, which gathered industry experts including the CERTS project team, General Electric, Virginia Tech and Montana Tech researchers, and others to discuss the next steps required to eliminate grid oscillations. For the short term, the workshop participants recommended the development of an oscillation-detector alarm system, and for the long-term, a robust control strategy based on real-time observations.

In March 2007, the California ISO requested that the CERTS project team to focus additional efforts on the small-signal stability monitor application to RD&D instead of developing a functional specification for a production-quality tool. However, in preparation for the eventual preparation and acquisition of such a tool, in June 2007, the prototype application was migrated to the California ISO's new production-quality hardware for further research and development.

The CERTS project team participated in a follow-up grid oscillations meeting held at BPA in June 2007. The overall strategic vision for a collaborative grid oscillation, diagnosis, and control effort was discussed.

In late 2007/early 2008, the Small-Signal Stability tool's algorithms, visuals (Figure 4), and features were further enhanced through additional research and end-user feedback. Some of the

key enhancements included improved mode estimation algorithms and graphics to quantify the uncertainty associated with the mode estimates. Specifically, a newly developed "bootstrapping" method was embedded into the tool to compute the uncertainty region or error bounds (i.e., confidence intervals) associated with each estimate. At the California ISO's request, other improvements included the capability to load single or multiple phasor disturbance files and perform small-signal stability forensics (i.e., the Event Analyzer tool) to assess the stability of the power system prior to and after the event through various analysis techniques.

While this new application sparked greater interest in phasor technology and its capabilities, the California ISO considers it pre-mature to pursue a commercial-grade small-signal stability tool, and has requested that the CERTS team conduct additional RD&D in this area. A second version of this tool incorporating more advanced algorithms and improved visuals, and extending its analysis capability to off-line disturbance files, was therefore developed in lieu of the functional specification for the commercial-grade tool. The updated tool was delivered to the California ISO in March 2008 and is currently undergoing field testing at the California ISO and the BPA.




Figure 4. Small-Signal Stability Monitoring Display

RTDMS Wide-Area Real-Time Control applications prototype development, factory-, and field-testing and production quality commercial functional specification

A feasibility assessment study exploring various methodologies for using phasor measurements to improve or augment existing operational nomograms was conducted. The California ISO and the CERTS project team agreed that this was a good first step towards using phasor measurements for wide-area real-time control, as nomograms are an integral part of the real-time dispatch process. The California ISO supported the proposed concept of developing a completely new type of wide-area nomograms for monitoring, which consists of inequalities being applied to the voltage angle differences measured at different locations within the Interconnection, and are unlike traditional power flows (e.g., interface flows, total generation, total load, etc). (See Appendix A, Phasor Feasibility Assessment and Research Results Report.)

The traditional operating nomogram, which defines secure operating conditions, are constructed using off-line power flow, voltage, transient, and post-transient stability simulations for a worst- case scenario. They, therefore, have an inherent conservatism embedded in them. The use of real-time measurements provided by phasor measurement units (PMUs), and the results of real-time stability assessment applications, can complement these nomograms by providing a direct measure of system stress and actual (rather than predicted) operating margins. Using phasor measurements in this manner would enable safe, yet less conservative operation.. Phasor measurements can also provide data that could replace select critical nomogram parameters for visualization based on real-time information and determine new areas and situations where additional nomograms may be required.

The use of PMUs to monitor existing nomograms would help to provide a tighter real-time monitoring of the operational limits. The sub second information from the problem area would increase the situational awareness of the real-time dispatch personnel and allow for more time for timely manual and automatic remedial actions in the future (Figure 5).

Some of the proposed concepts included (1) the use of PMUs for estimating reduced dynamic equivalents and its most current parameters in real time to augment existing nomograms, and (2) a completely new type of wide-area nomograms for monitoring, which consists of inequalities being applied to the voltage angle differences measured at different locations within the Interconnection. Voltage angle differences are a more direct measure of transient stability than the traditional power flows (e.g., interface flows, total generation, total load, etc.), and are therefore better for coordinating the system for observing transient stability. Any topology changes, such as line outages, are directly observable in the angle measurement, which may otherwise be absent in the MW flows. A prototype tool that utilizes the above-mentioned concept is being discussed with the Energy Commission.

After meeting with the California ISO, significant research was conducted to carry out the RTDMS Wide-Area Real-Time Control applications prototype and associated efforts described above, and in greater detail in Appendix A, Phasor Feasibility Assessment and Research Results Report. During reviews and discussions with Dave Hawkins and Nan Liu at the California ISO, this activity emerged as a lower priority for California ISO compared to other research included

in this contract. California ISO therefore requested the CERTS project team to direct its focus toward developing the aforementioned small-signal stability monitoring application.




Figure 5. Use of Additional PMUs to Monitor Existing Nomograms in Real-Time

RTDMS Frequency Data Collection and Analysis System prototype development, factory-, and field-testing, and technical support for integration with California ISO system

A PDC-PI interface that continually parses real-time streaming data and populates the PI Historian was developed, factory-tested, and installed on the production quality system at the California ISO in July 2007. It is currently in use to save frequency data from PMUs and Arbiter Frequency Meters into the PI Historian. This interface is also equipped to perform data quality checks prior to storing the data in PI Historian to ensure good data quality within their production system.

The CERTS project team met with the California ISO to discuss the architecture and definitions of the RTDMS Frequency Data Collection and Analysis System application. CERTS began development of the application to allow frequency data to be saved in the California ISO's PI Historian (a commercial-grade production database) that resides on the California ISO's energy management system). The project team designed the prototype, which is the first application

designed to transfer phasor data to the PI Historian. CERTS reviewed the prototype with California ISO staff, and then built the interface between phasor data and the PI Historian.

The California ISO concluded that the analysis capabilities within their PI Historian were adequate to meet their needs for a production-quality commercial-grade system for long-term data collection and analysis.

RTDMS Frequency Response and Sensitivity Analysis application, prototype development, factory, and field-testing

The feasibility of using phasor measurements to assess the Interconnection's frequency responses during significant events and to compute key grid sensitivities directly from phasor measurements, was evaluated. It is well understood that additional loading on the power system is associated with voltage degradation across the system. This relationship is typically represented by P-V or Q-V curves, which illustrate real and reactive power and voltage relationships. The gradient at any point along such a curve provides the voltage sensitivity with respect to the loading conditions at that bus. The traditional method for obtaining this information is dependent on the system model, especially the load model, which is built by historical data. It was determined that phasor measurements offer the ability to obtain the same information directly from the real-time measurement without requiring any modeling information. There is enough loading variation within the system to estimate the local gradient of curves that map changes in one variable (MW or MVARs) to changes in the other (voltages), i.e., the current voltage sensitivities at that location/interface.

The CERTS project team met with the California ISO during the summer of 2007 to discuss the approach and to develop new applications. As a result of the meeting, two separate applications were researched and developed: (1) sensitivity analysis displays, and (2) frequency response. The frequency-response application became the off-line *RTDMS Event Analyzer*, and was demonstrated at California ISO in December 2007. The CERTS team also developed two new dedicated displays for measurement-based angle sensitivity and voltage sensitivity, respectively. The sensitivity analysis displays were incorporated into RTDMS, version 5.5, which was installed at the California ISO in March 2008. This has facilitated better understanding of voltage-real/reactive power and phase angle-real power relationships for key corridors, and at critical generation and load buses where PMUs have been installed. The next steps for these applications are currently being evaluated by the California ISO. They will be included in a proposal for additional RD&D on these applications.

Prepare a Feasibility Assessment Studies Report

The CERTS project team researched and evaluated the feasibility of using phasors to (1) improve stability nomograms, (2) monitor small-signal stability, (3) measure key sensitivities related to voltage stability or dynamic stability (Figure 6), (4) assess interconnection frequency response, and (5) apply graph theory concepts for pattern recognition. The project team performed an extensive on-line literature review of all known existing publications on phasor technologies and applications, and consulted with university experts at Washington State University, the University of Wisconsin, University of Wyoming, and Montana Tech. Based on

this research, the CERTS project team proposed new technologies to the California ISO. The results of the feasibility assessment studies were incorporated into the Phasor Applications Project Research Report (see Appendix A, Phasor Feasibility Assessment Research Results Report).




Figure 6. Predicting P-V Curves and Voltage Stability Using Phasors

Prepare an Algorithm Results Report

Based on the findings from the feasibility assessment studies, the CERTS project team developed alternative solutions to address the feasibility of using phasors to (1) improve stability nomograms, (2) monitor small-signal stability, (3) measure key sensitivities related to voltage stability or dynamic stability, (4) assess interconnection frequency response, and (5) apply graph theory concepts for pattern recognition. The project team wrote algorithms and tested data provided by the California ISO, and algorithms results were incorporated into RTDMS. Algorithm results were also incorporated into the Phasor Applications Project Research Report.

Prepare the Phasor Applications Project Research Report

The Phasor Applications Project Research Report is provided in Appendix A, Phasor Feasibility Assessment and Research Results Report. The Phasor Applications Project Research Report also summarizes research for the Feasibility Assessment Studies Report and the Algorithm Results Report.

Prepare Production-Quality Functional Specifications

Preliminary efforts were undertaken to develop the production-quality functional specifications for the RTDMS Small Signal Stability Monitoring and RTDMS Wide-Area Real-Time Control applications. Based on California ISO's request for additional research on higher priorities, resources were redirected and preparation of functional specifications for production quality applications based on research conducted to date was not undertaken.

Provide technical research and development support to PIER and California utilities for phasor applications including technical and system integration support for utility projects, research roadmaps, WECC coordination, and NASPI Liaison

CERTS provided assistance and support to (1) SCE's use of phasor measurements for local remedial action control, (2) SDG&E's state estimation improvements, and (3) PG&E's critical path monitoring. CERTS also provided technical assistance to California ISO in preparing their multi-year research roadmap, which included NASPI collaboration and knowledge exchange, the formation of the WECC WAMTF, and increased collaboration with industry and academic experts.

The CERTS team provided assistance to California utilities on demonstration projects that had been previously identified by each utility. In particular, the RTDMS platform was provided to PG&E for critical path monitoring. Additionally, in late 2006, CERTS/EPG met SDG&E staff to layout a project plan for installing PMUs and integrating them with SDG&E's state estimator. An outcome of this effort was that SDG&E formally requested CERTS/EPG to provide consultation services on their state estimation project, and a separate contract was formed between CIEE and EPG (Subcontract No: MTX-06-02B) to this effect. During 2006-2008, the EPG staff has supported SDG&E in successfully integrating the phasor data with their state estimator and evaluating the performance improvements in the state estimator results.

CERTS also provided technical assistance to California ISO in preparing their multi-year research roadmap, which included NASPI collaboration and knowledge exchange, the formation of the WECC WAMTF, and increased collaboration with industry and academic experts.

In 2005, under a prior contract, CERTS worked with the California ISO to develop an RD&D roadmap for the phasor applications technology RD&D effort. In 2007, this roadmap was updated to include tasks, roles, and responsibilities at both the California ISO and WECC levels to grow the phasor infrastructure for greater coverage, and to move the phasor applications from research into an operational environment as identified in discussions with California ISO staff. The updated roadmap was presented to the California ISO in early 2007 and at the WECC-WAMTF meeting in April 2007. In early 2008, the roadmap was further refined to incorporate future CERTS research priorities planned for 2008–2010. As a result of these efforts, the phasor network now integrates over 50 PMUs streaming real-time data into the California ISO from various locations across WECC. In addition, at the California ISO, and the RTDMS platform and phasor applications have now been migrated from the R&D test bed onto production-grade hardware and into the California ISO operations environment.

1.6. Conclusions and Recommendations

1.6.1. Conclusions

The development and testing of a prototype RTDMS with California ISO system operators has accelerated the adoption and use of time-synchronized phasor measurements for real-time applications in the Western Interconnection. As the network has grown and matured and RTDMS applications have expanded, California ISO has invested in upgrading the hardware infrastructure to support the system. The phasor real-time applications, which initially ran on PC/Workstation machines in an isolated research environment, have now migrated to a production grade hardware platform on the California ISO secure corporate network, which is supported 24/7 by California ISO Information Technology staff. The system is also operating reliably, with over 90% of the devices reporting 99% data availability, and no system downtime. An indication of the improved reliability is that RTDMS is now at the Reliability Coordinator (RC) Desk in the Folsom Control Room and is an integral part of the real-time operations decision-making process.

The system now offers a rich set of features for wide-area monitoring as well as analytics. This wide-area, common view will allow operators to evaluate stability margins across critical transmission paths, detect potential system instability in real time, and, in the future, take manual or initiate automatic actions to mitigate or dampen these potential problems. It will also enable California ISO, California, and WECC utilities to explore closely related issues, such as the use of phasor data to improve state estimations, to determine the optimal location of additional phasor measurements, and to gain experience with the technology required to develop these advanced real-time control applications. Finally, it will facilitate technical exchange, collaboration, and resource leveraging with companion phasor measurement-based activities supported by the operating entities and DOE throughout North America.

1.6.2. Recommendations

The CERTS project team recommends continuing research and development of prototype applications toward ultimately providing the California ISO with functional specifications for acquisition of production-quality commercial phasor-based tools. CERTS also recommends continuing efforts through WECC to expand and link PMUs across the entire Western Interconnection.

Aspects of additional RD&D required have been proposed and are being considered by the Energy Commission for a follow-on contract.

1.6.3. Benefits to California

The benefit to California is the enhanced reliability of the California ISO and the Western Interconnection by providing reliability coordinators and control area operators at the California ISO, and California's major utilities with the latest advances in phasor measurement applications. Ultimately, system operators will be able to evaluate stability margins across critical transmission paths, detect potential system instability (pattern recognition) in real time, and then provide control signal(s) to devices or controls that will mitigate or dampen the instability. The wide-area, common view will also allow operators to detect unanticipated

system limitations in real time, even when the grid is operating within perceived safe portions of the existing operating nomograms. Thus, the system will serve a dual purpose to both improve transmission loadability from the point of view of transient stability and help operate the system within safe regions.

As a result, this research ultimately will have the following benefits for the California ISO and California utilities:

1. California ISO will immediately benefit from increased reliability.
2. The successful implementation of advance phasor applications by California ISO and BPA will accelerate market acceptance of phasor measurements and applications throughout the WECC, leading to a promulgation of these reliability benefits.
3. Ultimately, incorporation of phasor measurements into California ISO's suite of advanced computational tools for reliability and congestion management should also improve the accuracy of locational marginal pricing (LMP) calculations, which would follow the initial roll-out of California ISO's Market Redesign Technology Update. This update seeks to correct problems in California's electricity markets that contributed to the market disruptions experienced in 2000 and 2001. This objective is accomplished, in part, through better congestion management, potentially at lower cost, for the California ISO system;¹

¹ The Market Redesign and Technology Update includes three foundational designs – a full network model of the electricity grid, an integrated day ahead forward market and LMP. The LMP is the result of the integrated forward market which provides nodal prices so that all market participants know the cost of generating power, serving load and resolving congestion at each location on the system. LMPs reflect physical constraints under all load and system conditions and offer better economic measures and signals with which to manage the system. These pricing patterns also indicate where additional generation and transmission upgrades are needed in the future.

2.0 Task 3.0 Real-Time Voltage Security Assessment (RTVSA) Prototype Tool

2.1. Executive Summary

Introduction

California ISO system operators need to know how to more effectively manage the grid and its reactive resources, as well as coordinate with other organizations (interconnected system operators, load-serving entities, and generators) within today's changed operational environment, especially during periods of system stress. Real-time assessment of voltage security is an important means for achieving this end. However, the California ISO does not have a tool that can perform these assessments within short time windows required for real-time operations.

In this, the third and final, phase of research to enable the California ISO to acquire such a tool, CERTS developed and successfully demonstrated a prototype real-time voltage security assessment (RTVSA) tool that met all of California ISO's performance requirements. Based on this research, the project team developed a complete functional specification and then supported the California ISO in acquiring a production-quality tool from a commercial vendor

The RTVSA project consisted of three research tracks: (1) data requirements, (2) algorithms, and (3) prototype development and testing. Each research track was implemented in three phases: (1) conceptualization of the overall framework, and creation of a simulation platform with which to conduct the research; (2) development of algorithms and proof-of-concept simulations; and (3) implementation and validation of even more advanced algorithms, including demonstrations using data from sub-regions within the California ISO and development of the final functional-specification document.

This report summarizes results from the third and final phase of the project. Earlier phases of the project were supported under two prior PIER contracts.

Purpose

The goal of the RTVSA project was to develop and successfully demonstrate a prototype voltage security assessment tool that could run in real time within California ISO's new reliability and congestion management system. The specific requirements of the RTVSA tool included: (1) a wide-area, situational-awareness, geographical displays to manage the voltage and volt-ampere-reactive (VAR) resources for California's transmission system; (2) calculation of available voltage security margins, as well as contingency ranking according to a severity index for voltage stability-related system problems; (3) detection of the most dangerous stresses in the system, which could lead to voltage collapse, the regions most affected by potential voltage problems, and abnormal voltage reductions in the grid; (4) identification of controls or actions to increase the available stability margin and avoid instability; and (5) dispatch information about voltage problems for look-ahead operating conditions and worst-case contingencies.

Project Objectives

The overall objective of the RTVSA project was to support the California ISO in acquiring a production quality RTVSA tool. Additional objectives included working closely with California utilities and California ISO operators to develop a prototype that met their specifications, demonstrating the prototype RTVSA tool by using it to examine selected areas under the control of the California ISO, developing a set of production-quality RTVSA functional specifications, and then providing technical support for the California ISO's efforts to work with a commercial vendor to integrate a production-quality RTVSA tool into the California ISO's new reliability and congestion management system.

Project Outcomes

The project team completed a number of important technical milestones in its effort to meet the ultimate objectives of the real-time VSA project. These milestones included validation of the continuation power flow algorithm, the direct method, a boundary-orbiting technique, and the hyperplane approach; the creation of an initial prototype real-time VSA tool by using these validated mathematical techniques; the successful testing of these aspects of the prototype tool on the Humboldt and San Diego areas; the subsequent incorporation of these results into the development of a complete prototype, which can monitor voltage stability margin in real time, and help operators manage this margin in real time by controlling resources on the transmission system; and, finally, the preparation of a functional-specification document that describes functional, design, and visualization requirements for a production-quality VSA tool that could be acquired from a commercial vendor.

In summer 2007, the California ISO used the functional-specification document prepared by the CERTS project team to select a commercial software vendor to develop a production quality real-time VSA tool and integrate it into the California ISO's Energy Management System (EMS). The tool is scheduled to go online the third quarter of 2008.

Conclusions

The research conducted by the team led to development of a robust design for a RTVSA tool based on the parameter continuation technique, and improvements in accuracy and performance from the direct method and boundary-orbiting technique. The resulting functional specifications directly supported California ISO's acquisition and installation of a production-quality tool incorporating these research findings.

Recommendations

The project team recommended and California ISO has since used the team's functional-specification document to engage a commercial vendor to deliver a production quality real-time VSA tool. The project team also recommends use the underlying concepts researched for this project in future research to explore the entire voltage security region in the parameter or power injection space, including application to a simple one-dimensional approach or to a more complex multidimensional stressing.

Benefits to California

The RTVSA Tool offers significant benefits to California, including the increased reliability of the California ISO, the Western Interconnection, and California's major utilities. Improved voltage monitoring should also improve the accuracy of the California ISO's locational marginal pricing calculations, and thereby lead to better management of congestion on the California ISO system, potentially at lower total cost.

2.2. Introduction

California ISO system operators need to know how to more effectively manage the grid and its reactive resources, as well as coordinate with other organizations (interconnected system operators, load-serving entities, and generators) within today's changed operational environment, especially during periods of system stress. Real-time assessment of voltage security is an important means for achieving this end. However, the California ISO does not have a tool that can perform these assessments within short time windows required for real-time operations.

In this, the third and final, phase of research to enable the California ISO to acquire such a tool, CERTS developed and successfully demonstrated a prototype real-time voltage security assessment (VSA) tool that met all of California ISO's performance requirements. Based on this research, the project team developed a complete functional specification and then supported the California ISO in acquiring a production-quality tool from a commercial vendor

The RTVSA project consisted of three research tracks: (1) data requirements, (2) algorithms, and (3) prototype development and testing. Each research track was implemented in three phases: (1) conceptualization of the overall framework, and creation of a simulation platform with which to conduct the research; (2) development of algorithms and proof-of-concept simulations; and (3) implementation and validation of even more advanced algorithms, including demonstrations using data from sub-regions within the California ISO and development of the final functional-specification document.

This report summarizes results from the third phase of the project. Earlier phases of this project were supported under earlier contracts as shown in the overall research roadmap for the project. See Figure 7. These earlier phases were completed under Contract No. 500-99-013, BOA-20, and Contract No. 500-02-004, MRA-036, Real-Time Grid Reliability Management 2005.




Figure 7. Task 3.0 Multi-Year Research Roadmap for Real-Time Voltage Security Assessment (VSA)

2.2.1. Background and Overview

Over the past 40 years, more than 30 major blackouts worldwide have been caused by voltage instability and collapse. Among them, at least 13 voltage-related blackouts have taken place in the United States, including two major blackouts in the Western Interconnection in 1996, and a wide-scale blackout in the Eastern Interconnection in 2003. In examining the causes of these blackouts, investigation teams have, on several occasions, concluded that online power flow and stability tools, and indicators for system-wide voltage performance in the real-time operating environment are needed to prevent future blackouts.

Research for the VSA Project was motivated by California ISO operators' desire to acquire a real-time dispatcher's VSA tool and corresponding wide-area visuals to manage the voltage and Volt-Ampere Reactive (VAR) resources for the transmission system. The California ISO sought a tool that could calculate the following:

- Available voltage security margin.
- The most dangerous stresses in the system leading to voltage collapse.
- Worst-case contingencies leading to voltage collapse, and/or contingencies with an insufficient voltage stability margin.
- Abnormal reductions of nodal voltages.
- Contingency ranks according to a severity index for voltage stability-related system problems.
- Weakest elements within the grid, and the regions most affected by potential voltage problems.
- Controls to increase the available stability margin, and to avoid instability.
- Information about voltage problems for look-ahead operating conditions and worst-case contingencies (i.e., contingencies with large severity ranks) that may appear in the future.
- A real-time dispatcher's situational-awareness, wide-area graphic, and geographic displays.

CERTS developed an initial VAR-Voltage Management prototype tool funded by DOE's Transmission Reliability Program in 1999 and 2000. This prototype tool was a direct response to the California ISO's desire to improve procedures for implementing WECC's revised voltage-VAR requirements (Martinez, et.al. 2003). Prototype tailoring and enhancements for demonstration at the California ISO began under PIER support in 2001, and led to the following key project milestones: (1) in 2001–2002, the installation of the initial prototype with snapshot displays of the San Diego system only; (2) in 2003, the development of a full California ISO system model, including the incorporation of California ISO user feedback, but still based on snapshots; (3) in summer 2004, the California ISO developed specifications for the prototype of a new RTVSA tool that incorporates and extends the functionality of the original CERTS VAR-Voltage Management prototype for voltage security assessment purposes (CERTS 2005). The prototype was enhanced to run contingency simulations and perform contingency rankings,

which were required for the VSA prototype phase of the project; these new features were tested on the California ISO system.

In July of 2004, the PIER TRP Review Committee recommended that RD&D continue in developing a RTVSA tool prototype. In forming its recommendations, the TRP identified current VAR margins, what VAR margins would be needed around the system, and options to address shortfalls as they arose. The TRP also recommended research to identify the information needed by operators to make better operating decisions, as well as factors that would improve their comfort with, and confidence in, new real-time operating tools.

In 2005 and early 2006, under PIER Contract No. 500-99-013, BOA-20 and Contract No. 500-02-004, MR-036, the project team conducted an extensive review of existing VSA approaches, and identified and selected a state-of-the-art combination of approaches and computational engines for implementation in this project. Key elements of the final approach selected include the use of (1) parameter continuation, (2) direct methods, (3) the boundary-orbiting method, and (4) hyperplane approximation of the voltage stability boundary. The real-time VSA project development team also successfully implemented the parameter continuation (also known as the predictor-corrector) method. This method is quite robust and useful, since it overcomes several mathematical obstacles; it is able to find a continuum of power flow solution starting at some base load, and leads to the steady state voltage stability limit (critical point) of the system.

Under this contract, research work included enhancements to the Power Systems Engineering Research Center's (PSERC's) parameter continuation program,, the implementation of direct methods to quickly and accurately determine the exact Point of Collapse (PoC), the implementation of boundary-orbiting techniques to trace the security boundary, the investigation of descriptive variables, the implementation of hyperplanes to approximate the voltage stability boundaries as well as identify the controllable elements in the space of power injection, and the validation of techniques for analyzing margin sensitivities.

These techniques were tested using a ~6000 bus state estimator model covering the entire Western Interconnection for Southern California problem areas suggested by the California ISO, and the results were reported in Appendix B, Real-Time Voltage Security Assessment Report on Algorithms and Framework.

At the completion of this project, a functional specification document was developed to describe the design, functional, and visualization requirements for a Real-Time Voltage Security Assessment (RTVSA) tool, as well as the California ISO's preferences for certain implementation and visualization techniques.

2.3. Task Objectives

The overall objective of Task 3.0 was to support the California ISO in acquiring a production quality VSA tool that runs in real time. A secondary objective was to conduct the research in consultation with California (CA) utilities, such that the results of the work could be evaluated by the CA utilities for their own possible future adaptation and application.

The specific research objective was to work closely with California ISO operators to assess the feasibility of algorithms that could be incorporated into and enhance a prototype tool to meet their specifications. Once the prototype was completed and successfully demonstrated, it was to be transferred via a functional specification to a commercial vendor (selected by California ISO) for implementation as a production-grade operating tool. As part of this phase of the research, the VSA tool was to be demonstrated in Humboldt or Southern California.

The specific objectives of Task 3.0 included the following:

- Perform RD&D of suitability of algorithms for continuation power flow and hyper plane construction.
- Prepare a Real-Time VSA Report to include, but not be limited to, the analysis of continuation power flow algorithms and analysis of hyper plane construction for defining safe operating regions.
- Demonstrate these algorithms in the Humboldt and San Diego areas, and report on the demonstration results.
- Research and develop a prototype VSA platform to include preparing a RTVSA Research Report on the expanded capability of the prototype VSA platform.
- Demonstrate the prototype VSA for Southern California region (or another region under the control of California ISO) and report on the demonstration results.
- Prepare an Enhanced RTVSA Research Report to include, but not be limited to, integration with California ISO Common Information Model (CIM) data and topology translator, remedial and corrective action, and expanded test areas to include the entire California ISO system.
- Develop a set of Production-Quality VSA Functional Specifications.
- Prepare a Real-Time Wide-Area VSA Project Report. This report shall include, but not be limited to, a summary of work done.
- Provide technical support for California ISO efforts to work with a vendor to integrate and deliver a production-quality VSA tool.

The primary technical objective of Task 3.0 has been accomplished, as demonstrated by the California ISO's acceptance of the final functional specifications used to procure a production-quality RTVSA software tool. The functional specification document lays out, in great detail, the design, functional, and visualization requirements for a real-time VSA tool that incorporated California ISO's preferences for specific implementation and visualization techniques.

2.4. Task Approach/Methods

The task approach involved research on each of the final phases of the three project tracks identified in Figure 7: (1) implementation of suitable algorithms; (2) integration with California ISO's EMS; and (3) validation of the implemented algorithms on California ISO test cases. The following summarizes key aspects of the approach/methods, which are documented fully in appendices to the report.

The project team conducted an extensive review of existing VSA approaches, and identified and selected a state-of-the-art combination of approaches and computational engines for implementation in this project. Key elements of the final approach selected include the use of (1) parameter continuation, (2) direct methods, (3) the boundary-orbiting method, and (4) hyperplane approximation of the voltage stability boundary.

These elements were first approved by a panel of leading experts during the course of a survey conducted at the onset of the project. The elements were also verified in the course of face-to-face personal meetings with well-known university professors, industry experts, and software developers, and included email discussions, telephone exchanges, and feedback from industrial advisors and brainstorm meetings with the projects' consultants.

CERTS industrial advisors reviewed these developments during Technical Advisory Committee (TAC) meetings conducted in 2006. The TAC consisted of representatives from the California ISO, California utilities, Bonneville Power Authority (BPA), DOE, and other organizations.

The project team prototyped the proposed algorithms on a platform, also developed by the project team, to validate the tool, and tested it with a California ISO-provided test case. The project team used the PSERC parameter continuation program and MATLAB programming language as a basis for building the VSA prototype.

The project team validated the VSA algorithm results through numerous meetings and correspondence with California ISO staff who helped identify test cases and appropriate stressing conditions. In particular, the California ISO provided information on (1) the local voltage problem areas, stress direction, or procedure (which specifies how the system parameters change from their base case values as a function of increased amounts of stress), (2) the descriptor variables (which reflect the most influential or understandable combinations of parameters, or derivative parameters that influence the voltage stability margin), as well as (3) a list of critical contingencies associated with these stressing conditions. These data were used to:

- Compute the Point of Collapse (PoC) and reactive margins under the particular stressing condition using the parameter continuation technique in conjunction with the direct method.
- Calculate hyperplanes to approximate the voltage stability boundary.
- Compile a list of abnormal reductions in nodal voltages that highlighted the elements and regions most affected by potential voltage problems.
- Apply the boundary orbiting technique to trace the boundary under changed stressing situations.

The results of the research were presented and discussed with the California ISO staff, who were consulted extensively throughout the project and the functional specification development process. In addition, as a final input to development of the functional specification, a second survey was conducted of vendors and utilities to evaluate existing power system voltage security tools and to identify industry best practices in using them.

2.5. Task Outcomes

The project team completed research on the third and final phase of each of the three research tracks identified in Figure 7: (1) implementation of suitable algorithms; (2) integration with California ISO energy management system (EMS); and (3) validation of the implemented algorithms on the California ISO test cases.

With respect to the project objectives, the project team:

- Conducted a technical assessment of the continuation power flow algorithm, direct method, boundary-orbiting technique, and the hyperplane approaches.
- Enhanced the VSA prototype software tool by incorporating the above mentioned features.
- Utilized a ~6,000 bus (1,188 generators) state estimator model covering the entire Western Interconnection for the algorithm validation as suggested by the California ISO. This detailed model includes all buses/lines at or above the 115 kV level and some of the lower voltage levels within the California ISO region.
- Tested the prototype software tool on areas in Southern California.
- Provided a functional specification to the California ISO that included functional, design, and visualization requirements for a production-quality VSA tool that can be produced by a commercial vendor.

The following summarizes key aspects of these task outcomes, which are documented fully in appendices to the report. (See Appendix B, Real-Time Voltage Security Assessment Report on Algorithms and Framework, Appendix C, Real-Time Voltage Security Assessment Algorithm's Simulation and Validation Results; Appendix D, Real-Time Voltage Security Assessment Summary Report; and Appendix E, Real-Time Voltage Security Assessment Functional Specifications for Commercial Grade Application.)

The project team's research suggested that while the continuation method worked well in reaching the proximity of the collapse point in a particular stressing direction, several iterations of the algorithm and associated step-halving within the vicinity of the point-of-collapse were required to obtain the functions needed to extract accurate information about hyperplane boundaries, weak elements, and control elements.

The advantage to applying the direct method at this point is that it is a one-step approach to finding the collapse point within a predefined tolerance, and therefore overcomes accuracy limitations in the continuation method. Having accurately reached a point on the stability boundary, it is also theoretically feasible to apply the underlying continuation method framework to the direct method equations (as opposed to the powerflow equations as in the

traditional continuation powerflow) and systematically trace the voltage stability boundary (i.e., boundary-orbiting method). This adaptation further reduced the computational time, because there is no longer a need to return to the operating point and move in a different stress direction to find a second point on the stability boundary.

Additionally, the efficacy of using hyperplanes to approximate the voltage stability boundaries as well as identifying the controllable elements in the space of power injections was corroborated. A hyperplane is a linear geometry in multi-dimensional space. In one-, two-, and three-dimensional space, this happens to be a point, a line, and a plane, respectively. In power systems, a two-dimensional security region constructed by hyperplane approximation describes a region of safe operation (also referred to as operating nomograms). This is the most promising method for determining the available voltage stability margin in real time using such piece-wise linear approximations of the voltage collapse boundary in coordinates of independent power system parameters.

The project team demonstrated that the attributes of hyperplanes (i.e. coefficients of the hyperplane) can be interpreted as the parametric sensitivities of the margin to power injections and therefore are particularly useful in ranking the most appropriate corrective actions to steer away from the stability boundary. Similarly, the participation factors at the various buses in the voltage collapse also fall out of the proposed methodology and aid in identifying weak areas with the worst voltage degradation during a voltage collapse.

In summary, the validation process confirmed that (1) hyperplanes, or piecewise linear approximations, can be extracted from the solution at the point of collapse in a particular stressing direction; (2) piecewise linear approximations are appropriate for the stability boundary; (3) the properties of these boundaries (e.g., the orientation of the hyperplanes) offered valuable information on "control" elements indicating dangerous conditions that need corrective action, or weak elements where the impact of the voltage collapse phenomenon is the most severe; (4) a hybrid approach wherein the continuum power flow algorithm augmented with the direct method and the boundary-orbiting method can meet these performance requirements.

The final RTVSA algorithm consists of the following steps (which are illustrated in the flowchart in Figure 8):

1. Initial system stressing procedure for a given stress direction to reach a vicinity of the PoC in this direction.
2. The direct method is used then to refine the PoC location along the initial stress direction (the continuation method would require multiple iterations to find the PoC with the required accuracy).
3. The inverse iteration method or Arnoldi algorithm is applied to find the left eigenvector, which is used to build the set of approximating hyperplanes.

4. The boundary-orbiting procedure is then applied to trace the voltage stability boundary along a selected slice. This procedure is a combination of a predictor-corrector method and the transposed direct method.
5. In case of divergence, the algorithm is repeated starting from Step 1 for a new stress direction predicted at the last iteration of the orbiting procedure. Divergence may be caused, for example, by singularities of the stability boundary shape along the slice.
6. For a given voltage stability problem area and the corresponding descriptor parameters, the voltage stability boundary is built using the set of approximating hyperplanes.




Figure 8. RTVSA Algorithms Flowchart

The proposed algorithm was successfully implemented on the RTVSA platform and tested on areas in Southern California (see Appendix C, Real-Time Voltage Security Assessment Algorithm's Simulation and Validation Results). The efficacy of using hyperplanes to approximate the voltage stability boundaries as well as to identify the associated weak elements and the “controllable” elements for these boundaries were corroborated.

The approximated voltage stability boundary was compared to results obtained from the GE Positive Sequence Load Flow Software (GE PSLF) program, which is commonly used in the Western Interconnection; the results of this comparison were within a few percentages of each other. The main contributing factor to these discrepancies was the California ISO state estimator model, which had deficiencies that required manual modifications to get it to solve. The GE PSLF handles such scenarios differently, and these differences show up in the stability boundary calculations.

As a final input to development of the functional specification, a second survey was conducted of vendors and utilities to evaluate existing power system voltage security tools and to identify industry best practices in using them. The survey collected information on the following topics:

- Interfaces and protocols that are currently used to import/export/exchange data, such as OPC or CIM/XML, in a power system simulation software, and thus, choose the one most appropriate for RTVSA tool.
- Available visualization capabilities within existing applications (to identify the best available solutions and gaps between what is available and RTVSA vision).
- Processing capabilities of available applications, in order to recommend improvements for the RTVSA tool.

Several vendors and utilities responded to the survey request, providing valuable information about their tool’s interoperability, processing and visualization capabilities. The detailed findings from the survey are reported in Appendix D, Real-Time Voltage Security Assessment Summary Report.

Following presentation and discussion of these research results with California ISO staff, the CERTS project team developed a functional-specification document for the production-quality RTVSA tool.

The overall functionality of the RTVSA application was subdivided into three interdependent modules addressing (1) the input subsystem (including the various interfaces, protocols, and formats that the tool must support to integrate with the California ISO EMS; (2) the central server (addressing the various centralized functions such as topology processor, simulation engine, flat file storage, etc.), and (3) the user interface (operator display consoles and stand-alone consoles) requirements. The system architecture illustrates the affiliations among the various modules, as well as the constitutive functionalities of each of the consoles (Figure 9).

The functional specifications fully describe a production quality RTVSA tool that can monitor voltage stability margin in real time, and help operators manage this margin in real time by enabling them to more confidently control reactive resources, generation dispatch, and other resources on the transmission system. The monitoring function is accomplished by integration of the tool within the California ISO’s real-time network analysis sequence, which will run the

tool automatically, at five-minute intervals or on demand, after each successful state-estimation process. The operator support function includes automatic identification of:

1. Available voltage security margins.
2. The most dangerous stresses in the system leading to voltage collapse.
3. Worst-case contingencies resulting in voltage collapse and/or contingencies with insufficient voltage stability margins.
4. Contingency ranking according to a severity index for voltage stability–related system problems.
5. Weakest elements within the grid, and the regions most affected by potential voltage problems.
6. Controls to increase the available stability margin, and to avoid instability.
7. Information about voltage problems for look-ahead operating conditions and worst-case contingencies (i.e., contingencies with large severity ranks) that may appear in the future.

The RTVSA tool also features situational-awareness, wide-area graphic and geographic displays for two modes of operation: (1) real-time and (2) look-ahead. The functionalities offered by these two modes of operation are summarized in **Error! Reference source not found.** below.

	RTVSA Modes		Study Modes
	Real-Time	Look-Ahead	
Unidirectional Stressing			
<i>Contingency screening & ranking</i>	x	x	x
<i>Real-time alarming</i>	x		
<i>Voltage profiles</i>	x	x	x
<i>MW/MVAR reserves</i>	x	x	x
<i>Single-line diagrams</i>	x	x	x
<i>Loading margins</i>	x	x	x
<i>Margin sensitivities to reactive support</i>	x	x	x
<i>Ranking of corrective controls</i>	x	x	x
<i>Identification of weak elements</i>	x	x	x
Multidirectional Stressing			
<i>2-D, 3-D or N-D Security Regions (Nomograms) developed offline</i>			x
<i>Real-time assessment of operating points including contingency ranking, margins</i>	x	x	x
<i>Real-time ranking of controls to steer away from the boundary</i>	x	x	x

Table 1. Summary of RTVSA capabilities




Figure 9. RTVSA System Architecture

The final functional specification for the production-grade VSA system was delivered to the California ISO in March, 2007 (see Appendix E, Real-Time Voltage Security Assessment

Functional Specifications for Commercial Grade Application). In summer 2007, the California ISO used the functional-specification document prepared by the CERTS project team to select a commercial software vendor to develop a production quality real-time VSA tool and integrate it into the California ISO's Energy Management System (EMS). The tool is scheduled to go online the third quarter of 2008.

2.6. Conclusions and Recommendations

2.6.1. Conclusions

The prototype RTVSA tool developed under this project was based on an extensive analysis of existing VSA approaches, surveys responses of the leading power-system experts from around the world, and interviewing vendors on their existing commercial offerings and utilities on current implementation practices within the industry. The research conducted by the team led to development of a robust design for a RTVSA tool based on the parameter continuation technique, and improvements in accuracy and performance from the direct method and boundary-orbiting technique.

The resulting functional specification has directly supported California ISO's acquisition and installation of a production-quality tool incorporating these research findings. The production quality RTVSA tool will form an integral element of the advanced suite of computational tools for congestion management that California ISO will utilize for reliability and congestion management.

2.6.2. Recommendations

The project team recommended and California ISO has since used the team's functional-specification document to engage a commercial vendor to deliver a production quality RTVSA tool. The project team also recommends use the underlying concepts researched for this project in future research to explore the entire voltage security region in the parameter or power injection space, including application to a simple one-dimensional approach or to a more complex multidimensional stressing.

2.6.3. Benefits to California

The RTVSA tool will provide significant benefits to California. Most of the VSA tools that are currently available commercially are well-suited for the planning environment, where they are used in an offline mode to conduct studies and define safe operating regions and margins (or nomograms). However, these nomograms, which are utilized to operate the grid in real time, tend to be conservative when dealing with uncertainties, worst-case conditions, and any discrepancies between real-time operating conditions and those used in the offline planning studies. Therefore, the ability to dynamically adjust voltage security regions to changing system conditions, and to compute margins in real time that accurately reflect true system conditions, which are embodied in the RTVSA tool, offer the following benefits to the California ISO and California utilities:

1. California ISO will immediately benefit from increased reliability.
2. Improved voltage monitoring should also improve the accuracy of locational marginal pricing (LMP) calculations. which will accompany the roll-out of California ISO's

Market Redesign Technology Update. This update seeks to correct problems in California's electricity markets that contributed to the market disruptions experienced in 2000 and 2001. This objective is accomplished, in part, through better congestion management, potentially at lower cost, for the California ISO system;² and

3. The successful implementation of the RTVSA tool by California ISO will likely accelerate market acceptance of this and similar operating tools, leading to a promulgation of the first two benefits above to other regions of the country.

² The Market Redesign and Technology Update includes three foundational designs – a full network model of the electricity grid, an integrated day ahead forward market and LMP. The LMP is the result of the integrated forward market which provides nodal prices so that all market participants know the cost of generating power, serving load and resolving congestion at each location on the system. LMPs reflect physical constraints under all load and system conditions and offer better economic measures and signals with which to manage the system. These pricing patterns also indicate where additional generation and transmission upgrades are needed in the future.

3.0 References

Hauer, J.F., W. A. Mittelstadt, W. H. Litzemberger, C. Clemans, D. Hamai, and P. Overholt. 1999. Wide Area Measurements For Real-Time Control And Operation of Large Electric Power Systems – Evaluation And Demonstration Of Technology For The New Power System. Prepared for U.S. Department of Energy Under BPA Contracts X5432-1, X9876-2. January.

CERTS. 2006. Maintain, Enhance and Improve Reliability of California's Electric System Under Restructuring." Energy Commission CEC-500-2006-035.
http://www.energy.ca.gov/pier/final_project_reports/CEC-500-2006-035.html. March.

Eto, J., M. Parashar, B. Lesieutre, N.J. Lewis. 2007 Real Time Grid Reliability Management 2005, LBNL Report #62368. December.

Martinez, C., J. Dyer, and M. Skowronski, Electric Power Group. 2003. "Real-Time Voltage Monitoring and VAR Management System®". Energy Commission P500-03-087F.
http://www.energy.ca.gov/pier/final_project_reports/500-03-087f.html, October 2003.

4.0 Glossary

<i>Acronym</i>	<i>Definition</i>
BPA	Bonneville Power Administration
California ISO	California Independent System Operator
CIEE	California Institute for Energy and Environment
CIM	Common Information Model
CERTS	Consortium for Electric Reliability Technology Solutions
CPR	Critical Project Review
DOE	Department of Energy
EIPP	Eastern Interconnection Phasor Project
EMS	Energy Management System
EPRI	Electric Power Research Institute
GE PSLF	General Electric Positive Sequence Load Flow (GE PSLF is the load-flow component of the GE power systems analysis package)
IEEE	Institute of Electrical and Electronic Engineers
LBNL	Lawrence Berkeley National Laboratory
MATLAB	MATrix LABoratory (programming language for technical computing from The MathWorks, Natick, MA)
MW	Megawatt
MRTU	Market Redesign and Technology Update
MVARs	Mega Voltage-Ampere Reactive
NERC-WECC	North American Electric Reliability Corporation – Western Electricity Coordinating Council
PG&E	Pacific Gas and Electric
PI	Principal Investigator
PIER	Public Interest Energy Research
PMUs	Phasor Measurement Units
PoC	Point of Collapse
PSERC	Power Systems Engineering Research Center
RD&D	Research Development & Demonstration
RTDMS	Real Time Dynamics Monitoring System

RTSO	Real Time System Operations
RTVSA	Real Time Voltage Security Assessment
SCADA/EMS	Supervisory Control and Data Acquisition/Energy Management System
SCE	Southern California Edison
SDG&E	San Diego Gas & Electric
TRP	PIER Transmission Research Program
VAR	Volt-Ampere Reactive
VSA	Voltage Security Assessment
WAPA	Western Area Power Administration
WASA	Wide-area Security Assessment
WECC	Western Electricity Coordinating Council

Appendices

Appendices are available as separate documents.

Appendix A, Phasor Feasibility Assessment and Research Results Report

Appendix B, Real-Time Voltage Security Assessment Report on Algorithms and Framework.

Appendix C, Real-Time Voltage Security Assessment Algorithm's Simulation and Validation Results

Appendix D, Real-Time Voltage Security Assessment Summary Report

Appendix E, Real-Time Voltage Security Assessment Functional Specifications for Commercial Grade Application



Arnold Schwarzenegger
Governor

REAL TIME SYSTEM OPERATION 2006 – 2007

Phasor Technology Applications
Feasibility Assessment and
Research Results Report

Prepared For:
California Energy Commission
Public Interest Energy Research Program

Prepared By:
Lawrence Berkeley National Laboratory

CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

APPENDIX A

Month Year
CEC-500-2008-XXX-APA

Prepared By:

Lawrence Berkeley National Laboratory
Joseph H. Eto, Principal Investigator
Manu Parashar and Wei Zhou, Electric Power Group
Dan Trudnowski, Montana Tech
Yuri Makarov, Pacific Northwest National Laboratory
Ian Dobson, University of Wisconsin
Berkeley, CA 94720
Commission Contract No. 500-02-004
Commission Work Authorization No: MR-041

Prepared For:

Public Interest Energy Research (PIER)
California Energy Commission

Jamie Patterson
Contract Manager

Mike Gravely
Program Area Lead
ENERGY SYSTEMS INTEGRATION

Mike Gravely
Office Manager
ENERGY SYSTEMS RESEARCH



Martha Krebs, Ph.D.
PIER Director

Thom Kelly, Ph.D.
Deputy Director
ENERGY RESEARCH & DEVELOPMENT DIVISION

Melissa Jones
Executive Director

DISCLAIMER

This report was prepared as the result of work sponsored by the California Energy Commission. It does not necessarily represent the views of the Energy Commission, its employees or the State of California. The Energy Commission, the State of California, its employees, contractors and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the uses of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the California Energy Commission nor has the California Energy Commission passed upon the accuracy or adequacy of the information in this report.



FEASIBILITY ASSESSMENT AND RESEARCH RESULTS REPORT

Prepared For

California Independent System Operator (CA ISO)

Prepared By

Consortium for Electric Reliability Technology Solutions (CERTS)

Funded By

California Public Interest Energy Research
Transmission Research Program

Date: Revised June 20, 2008

The work described in this report was coordinated by the Consortium for Electric Reliability Technology Solutions with funding provided by the California Energy Commission, Public Interest Energy Research Program, through the University of California/California Institute of Energy Efficiency under Contract No. 500-02-004, MR-041.

PREPARED FOR:

California Independent System Operator

PREPARED BY:

Electric Power Group

Manu Parashar, Ph.D. - Principal Investigator

Wei Zhou - Investigator

Montana Tech

Dan Trudnowski, Ph.D. - Consultant

Pacific Northwest National Laboratory

Yuri Makarov, Ph.D. - Principal Consultant

University of Wisconsin, Madison

Ian Dobson, Ph.D. - Consultant

DATE: Revised June 20, 2008

Acknowledgements

Special thanks to California ISO staff Mr. Jim Hiebert, Mr. Brian O’Hearn, Mr. Brian Murry, Mr. Paul Bleuss, Mr. Greg Tillitson, Mr. Eric Whitley and Mr. Nan Liu for their consultations to the project and support for the RTDMS system.

Mr. Dave Hawkins (California ISO) for his expertise, comprehensive support, and advices.

Dr. Yuri V. Makarov (PNNL) and Prof. Ian Dobson, (University of Wisconsin-Madison) for their role in suggesting methodologies on applying phasor technology to stability nomogram, literature review, participation in the brainstorm meetings, expertise and essential advices.

Prof. Dan Trudnowski (Montana Tech), for providing the algorithms for monitoring oscillatory modes under ambient system conditions and his support in the prototype development.

Mr William Mittelstadt, Mr Ken Martin (BPA), Dr John Hauer, Dr Henry Huang, Dr Ning Zhou (PNNL), Prof. John Pierre (University of Wyoming) for sharing their expertise and advise on the mode meter algorithm evaluation.

Mr. Jim Cole (California Institute for Energy Efficiency) for initiating and support of this project, and participants of the TAC meeting for their thoughtful suggestions.

Mr. Joseph Eto (Lawrence Berkeley National Lab) for his support.

Parashar, Manu, Wei Zhou, Dan Trudnowski, Yuri Marakov, Ian Dobson. Consortium for Electric Reliability Technology Solutions (CERTS). 2008. Phasor Technology Applications Feasibility Assessment and Research Results Report. California Energy Commission, PIER Transmission Research Program. CEC-500-2008-XXX.

Preface

The Public Interest Energy Research (PIER) Program supports public interest energy research and development that will help improve the quality of life in California by bringing environmentally safe, affordable, and reliable energy services and products to the marketplace.

The PIER Program, managed by the California Energy Commission (Energy Commission), conducts public interest research, development, and demonstration (RD&D) projects to benefit California.

The PIER Program strives to conduct the most promising public interest energy research by partnering with RD&D entities, including individuals, businesses, utilities, and public or private research institutions.

PIER funding efforts are focused on the following RD&D program areas:

- Buildings End-Use Energy Efficiency
- Energy Innovations Small Grants
- Energy-Related Environmental Research
- Energy Systems Integration
- Environmentally Preferred Advanced Generation
- Industrial/Agricultural/Water End-Use Energy Efficiency
- Renewable Energy Technologies
- Transportation

Real Time System Operations (RTSO) 2006 - 2007 is the final report for the Real Time System Operations project (contract number 500-03-024 MR041 conducted by the Consortium for Electric Reliability Technology Solutions (CERTS). The information from this project contributes to PIER's Transmission Research Program.

For more information about the PIER Program, please visit the Energy Commission's website at www.energy.ca.gov/pier or contact the Energy Commission at 916-654-5164.

Table of Contents

1. OBJECTIVE	Error! Bookmark not defined.
2. INTRODUCTION	7
3. METHODOLOGIES FOR USING PHASORS FOR STABILITY NOMOGRAMS.....	13
3.1. Improving Existing Nomograms using Real-Time Phasor Measurements ..	13
3.2. Use of PMUs for Reduced Dynamic Equivalents and Transient Stability Assessment	16
3.3. New Concept of Wide Area Nomograms.....	17
3.4. Use of PMUs for Wide-Area Voltage Security Assessment	24
3.5. Augmenting Existing Nomograms using Small-Signal Stability Assessment	25
4. ALGORITHMS FOR MONITORING SMALL-SIGNAL STABILITY WITH PHASOR MEASUREMENTS	27
4.1. Algorithms to Estimate the System Modes Using Synchronized Phasor Data	28
4.2. Mode Selection.....	30
4.3. Algorithm Tuning	31
4.4. Implementation of Small-Signal Stability Monitoring Prototype Tool.....	35
5. MEASUREMENT BASED SENSITIVITIES AND VOLTAGE STABILITY MONITORING	41
5.1. Measurement based Sensitivities	41
5.2. Voltage Stability Loading Margins	43
5.3. Predicting Voltage Stability with Phasor Measurements	48
5.4. Implementation of Measurement bases Sensitivity Prototype Tool	48
6. FREQUENCY RESPONSE MONITORING.....	51
7. GRAPH THEORY BASED PATTERN RECOGNITION	55
8. RTDMS SYSTEM ARCHITECTURE	57
9. CONCLUSION	59

LIST OF FIGURES

Figure 1: Detecting potential “holes” in the nomograms	13
Figure 2: Detecting excessive “conservatism” in the nomograms	14
Figure 3: Use of additional PMUs to monitor existing nomograms in real-time.....	16
Figure 4: MW Flow and Angle Difference tracking across COI – (a) the net MW flows remained unchanged (b) the transmission outage was captured by angle difference.	18
Figure 5: Western interconnection transmission paths	20
Figure 6: Conceptual view of simple angle difference and advanced angle nomograms	21
Figure 7: A cutset of stability boundary in rectangular coordinates of nodal voltages ...	22
Figure 8: Correlation between MW flows across critical flowgates and angle difference pairs	23
Figure 9: PMU Measurement based phase angle trends in angle-angle space	24
Figure 10: Voltage stability boundary developed in angle-angle space.....	25
Figure 11: Signal flow diagram.	27
Figure 12: Mode estimates for WECC data	32
Figure 13: Long-term Inertie mode trends (frequency & damping) with varying COI flows	33
Figure 14: Long-term Inertie mode spectral trends with varying COI flows.....	34
Figure 15: Small-Signal Stability Monitoring Display	35
Figure 16: Sample Mode Tracking Plot.....	36
Figure 17: Sample Waterfall Plot	37
Figure 18: Block Diagram for the Small-Signal Stability Monitoring Tool.	38
Figure 19: Improved Mode Tracking Plot with Bootstrapping Ellipse	39
Figure 20: Sample Spectral Analysis Display.....	40
Figure 21: P-V curves and voltage sensitivities at different loading levels across COI - (a) voltage sensitivity ~ 1kV/100MW under light loading conditions (b) voltage sensitivity ~ 3kV/100MW under increased loading conditions.	42
Figure 22: Estimating sensitivities using (a) Least Squares Regression (b) Orthogonal Regression.	43

Figure 23: Flow Chart for voltage stability assessment based on phasor measurements.	44
Figure 24: Voltage stability analysis model for a multiple-infeed load center using phasor measurements.....	45
Figure 25: Estimating voltage stability margins with phasor measurements: (a) P-V curve predicted by the multiple-feed load center model; (b) phase measurement data used in the model parameter estimation.....	47
Figure 26: Voltage Sensitivity Monitoring Display	49
Figure 27: Frequency response captured by the phasor measurement network due to the Colstrip unit outage – (a) the interconnection frequency response to the outage (b) the ringdown observed in the MW flows from the Colstrip bus.....	52
Figure 28: Real Time Dynamics Monitoring System Architecture.	58

1.0 INTRODUCTION

Phasor technology is one of the key technologies on the horizon that holds great promise towards improving grid reliability, relieving transmission congestion, and addressing some of today's operational challenges within the electric industry. This technology complements existing SCADA systems by providing the high sub-second resolution and global visibility to address the new emerging need for wide area grid monitoring, while continuing to use existing SCADA infrastructure for local monitoring and control.

Recent advances in the field of phasor technologies offer new possibilities in providing the industry with tools and applications to address the blackout recommendations and to tackle reliability management and operational challenges faced by system operators and reliability coordinators. The utilization of real-time phasor measurements in the fields of visualization, monitoring, protection, and control is expected to revolutionize the way in which the power grid of the future can identify and manage reliability threats and will respond to contingencies.

Phasor measurement data provide precise real-time direct monitoring capability of the power system dynamics (beyond the static view currently available via SCADA) at a very high rate. They also have the capability of accurately estimating and dynamically tracking various system parameters that provide a quantitative assessment of the health of system under the current operating condition and the prevalent contingency. In particular, synchronized phasor measurements provide an accurate sequence of snap-shots of the power system behavior at a very high rate (30 samples per second) along with precise timing information. The timing information is essential for real-time continuous estimation of system parameters that classify the power system. A precise estimate of the load, generator and/or network parameters consequently provide the most accurate assessment of the system limits of the current operating system. This time series data along with real-time system parameter estimates based on the data can be utilized to improve stability nomogram monitoring, small signal stability monitoring, voltage stability monitoring and system frequency response assessment. A main advantage of such methodologies is that they can measure actual system states and performance and do not rely on offline studies for its assessment, nor do they rely on comprehensive system models, which can be outdated or/and inaccurate.

1.1. Objective

A California PIER funded multi-year project plan aimed at developing Real-Time Applications of Phasors for Monitoring, Alarming and Control is currently in place. One of the tasks within this plan is to research and evaluate the feasibility of using phasors for (1) improving stability nomograms as a first step towards wide area control, (2) monitoring small-signal stability, (3) measuring key sensitivities related to voltage stability or dynamic stability, (4) assessing interconnection frequency response. (4) and applying graph theory concepts for pattern recognition.

The objective of the feasibility assessment study was to propose several approaches for using these time synchronized, high resolution PMU (Phasor Measurement Unit) measurements and

possibly other EMS/SCADA data for better assessment of the system operating conditions with respect to their stability limits. Some initial results and research prototypes that were developed as under this project are also discussed. These prototypes have been developed on the Real Time Dynamics Monitoring System (RTDMS™) which is the CERTS platform conducting phasor research.

1.2. Nomogram Validation

The existing nomograms are built in the course of off-line power flow, voltage, transient and post-transient stability simulations for a “worst case” scenario. The “worst case scenario” may include

- The most limiting contingency conditions,
- Combinations of the critical (most influential) parameters,
- Most influential fault locations (for transient stability studies),
- Critical load demand conditions, and
- Generation dispatches.

The necessity of providing robustness to the nomograms is implied by the “worst case” approach. Thus the nomograms are designed to define secure operating conditions for all real-life operating situations, even if these situations deviate from the conditions simulated by the operations engineers when they develop the nomograms.

One more reason that makes the existing nomograms even more *conservative* is the necessity to select two or three most influential (critical) parameters to describe the nomograms in a way that addresses a variety of real-life situations resulting from errors accumulated by system parameters that are not included in the nomogram.

The nomograms are usually represented graphically on a plane of two critical parameters using piecewise linear approximation of the nomograms’ boundaries. The boundaries usually have a composite nature describing different types of operating limits such as thermal constraints, voltage and transient stability limits, and “cascading constraints”. If the third critical parameter is involved, the nomogram is represented as a family of limiting curves represented by the so-called “diagonal axis”. Each of the curves along the “diagonal axis” corresponds to a certain value of the third critical parameters.

The pre-calculated nomograms are used in the scheduling process, operations planning, and real-time dispatch. With the implementation of the new California ISO market design, these nomograms will be incorporated as additional constraints limiting the Security Constrained Unit Commitment (SCUC) and Security Constrained Economic Dispatch (SCED) procedures.

™ Built upon GRID-3P Platform, U.S. Patent 7,233,843. Electric Power Group. All rights reserved.

Therefore, the limits specified by the nomograms contribute to the costs associated with congestion and will influence the forward and real-time market prices in California.

The need for a more dynamically adjustable nomogram is well understood at the California ISO, and several ideas have been generated around the potential use of manually or automatically adjusted nomograms. This approach could potentially decrease the existing congestion cost in California which are estimated at up to \$500 million a year. The idea of using the PMU data to improve and adjust the existing nomograms was also proposed by the California ISO.

In general terms, the proposed concept deals with the tradeoff between the pre-calculated fixed operating limits that are based on extensive computations (which tend to be more conservative due to the uncertainty about the applications) and the limits calculated in real time and adjusted to the current system conditions (which must be computationally less expensive, but based on better knowledge of current conditions). By shifting the focus from some of the pre-calculated operating constraints to real-time calculations, it is possible to build more flexible nomograms.

Specifically, the use of real-time measurements provided by PMUs and the results of real-time stability assessment applications can complement the existing nomograms by making the pre-calculated nomograms less conservative. These measurements can also provide data to select critical nomogram parameters for visualization based on real-time information and determine new areas and situations where additional nomograms may be required.

At the same time, there are several limiting factors that need to be considered while addressing these tasks:

- The nomograms reflect various contingency and system conditions. The real-time measurements reflect just the current system state/contingency, and therefore are not indicative of potential stability problems that might happen for the same load and generation pattern under different contingency conditions or under heavier loading conditions
- Although PMUs can track the dynamics of certain grid variables in real time, there are only a limited in number of PMUs distributed over a wide area. Since PMUs do not provide full observability of the system state – additional data from the state estimation and SCADA may be required
- The number and location of the existing PMUs may not be adequate to the task of monitoring of local stability limits such as those induced by voltage stability problems

Nevertheless, phasor measurements do provide wide area observability of system swing or oscillatory dynamics where the state estimator performance is too slow, and certain approaches that exploit these attributes can be suggested for nomogram validation purposes.

1.3. Small-Signal Stability Monitoring

Low frequency electrical modes exist in the system that are of interest because they characterize the stability of the power system and limit the power flow across regions. While there is a danger that such modes can lead to instability in the power system following a sizable contingency in the system, there is also the risk of these modes becoming unstable (i.e., negatively damped) due to gradual changes in the system. The ability to continuously track the damping associated with these low frequency modes in real time and under normal conditions would therefore be a valuable tool for operators and power system engineers.

Recently there have been efforts to identify these low frequency modes under normal operating conditions. The concept is that there is broadband ambient noise present in the power system mainly due to random load variations in the system. The random variations act as a constant low-level excitation to the electromechanical dynamics in the power system and are observed in the power-flows through, or phase angle differences across, a transmission line. Assuming that the variations are truly random over the frequency range of interest (the oscillations typically lie between 0.1 to 2Hz), the spectral content of power-flows across tie-lines obtained from phasor measurements can be used to estimate the inter-area modal frequencies and damping. Operators would be alarmed if the damping of these modes falls below predetermined thresholds (e.g. 3% or 5%).

1.4. Voltage Stability and Measurement Based Sensitivity Computations

Sensitivity information, such as voltage sensitivities at critical buses to increased loading, have traditionally been computed by power system analysis tools that require complete modeling information. With the precise time synchronization and the diversity in the measurement sets from PMUs (i.e. voltage and current phasors, frequency, MW/MVAR flows), it is possible to correlate changes in one of these monitored metrics to another in real-time and, therefore, directly measure and quantify such dependencies.

While voltages at key buses and their respective voltage sensitivities to additional loading are important indicators of voltage stability, for a complete voltage security assessment it is also essential to monitor and track the loading margins to the point-of-collapse and also account for contingencies. Fortunately, phasor measurements at a load bus or from a key interface also contain enough information to estimate the voltage stability margin and define a Voltage Stability Index for it. It is a well-known fact that for a simplistic two-bus system with a constant power load (i.e., a constant source behind an impedance and a load), the maximum loadability condition occurs when the voltage drop across the source impedance is equal to the voltage across the load. Hence, the idea is to use the phasor measurements at the bus to dynamically track in real-time the two-bus equivalent of the system (a.k.a. Thevenin equivalent). As these Thevenin parameters are being tracked dynamically, they reflect any changes that may occur in the power system operating conditions and consequently provide the most accurate assessment of loadability estimates.

1.5. Frequency Response Assessment

Recent task force studies show evidence of degrading reliability performance over the years. For example, the Frequency Response Characteristic (FRC), which is a measure of the Interconnection's primary frequency control to significant change in load-generation balance and the initial defense towards arresting its decline and supporting the system frequency, is at a decline. FRC survey results gathered for the observed frequency deviations over various outages indicate that the Eastern Interconnection's Frequency Response has declined from about -3,750 MW/0.1Hz in 1994 to less than -3,200 MW/0.1Hz in 2002 (i.e., an 18% decline) while load and generation grew nearly 20% over the same period [13]. A similar decline has also been observed in the Western Interconnection's Frequency Response. Theoretically, Frequency Response should have increased proportionally with generation and load. In the past many control areas carried full reserves for their individual largest contingency and some for multiple contingencies. However, competitive pressures and greater reliance on reserve sharing groups (RSG) have reduced reserves and safety margins. If these trends continue, they may jeopardize the interconnection's ability to withstand large disturbances and move the system closer to automatic under frequency load shedding.

The sub-second resolution associated phasor measurements is sufficient to accurately track the frequency response following a major disturbance such as a generation trip. By monitoring the frequency trends during the first 2-10 seconds after such an event, (i.e. time scales typically associated with the primary control), and mapping this change in frequency to associated MW change in the system (which may also be available directly from PMU measurements), one can build a database of the interconnection Frequency Response over time.

1.6. Graph Theory based Pattern Recognition

Graph theory techniques can be used to characterize, monitor and assess the global behavior of the power grid, as well as to detect anomalies in the system. In particular, correlation between measured phase angle signals may be used to develop network graph whose nodes denote the correlation in phasor measurements. One could then apply graph-theoretic tools to segment the measurements into a small subset of signals for real time monitoring by a human operator. The network-level analysis approach may be further applied to perform anomaly detection at the topological level, where the entire network might be undergoing significant but incremental changes in response to an anomalous event as well as to identify the focal root cause of the anomalous behavior by evaluating graph-theoretic distance measures.

2.0 METHODOLOGIES FOR USING PHASORS FOR STABILITY NOMOGRAMS

2.1. Improving Existing Nomograms using Real-Time Phasor Measurements

The real-time operating conditions can deviate from the simulated conditions that have been used to build the pre-calculated existing nomograms. The existing nomograms have been developed using a very limited number of critical parameters that can hardly reflect the changes of the remaining system parameters that are not included in the nomograms. The nomograms are based on the linear approximation of the operating limits. These and other considerations introduce conservatism in the “worst case” nomograms in order to robustly cover these uncertainties and inaccuracies. These conservative limits adversely affect the definition of congestion costs on the one hand, and do not completely exclude system problems on the other hand. These circumstances create opportunities for using the real time data including the PMU and EMS/SCADA data to improve and supplement the existing nomograms. These measurements could conceptually validate the existing nomograms in the following ways:

Detection of potential “holes” in the existing nomograms (Figure 1) - The real-time monitoring of the system conditions could help to detect potential situations where the existing nomograms are not capable of detecting system problems. The feasibility of this real-time functionality strongly depends on the observability of system states and parameters needed for this task (this is why a combination of EMS/SCADA and PMU data may be required), and the time resolution of the data required to capture dynamic processes in the system.




Figure 1: Detecting potential “holes” in the nomograms

Detection of excessive “conservatism” in the existing nomograms - This feature can help to detect potential situations where the existing nomograms are excessively limiting. The elements of this approach can be described as follows (see Figure 2):




Figure 2: Detecting excessive “conservatism” in the nomograms

The essential elements of the proposed approach can be described as follows:

- At the current operating point, monitor the system security indicators² using the PMU, SCADA, and State Estimation data. These indicators can be thermal limits, voltage limits, or other stability indices.
- Monitor the relative position of the current operating point against the “walls” of the relevant nomogram.
- Generate signals to the real-time dispatchers whenever (i) the real-time security indices indicate approaching limiting conditions – i.e. potential “hole” in the nomogram (ii) the operating point reaches the nomogram walls – i.e. potential conservatism in the nomogram.
- Memorize the snapshot whenever the security indicators signal the problem before a vicinity of the nomogram boundary is reached. This information can be used offline to “repair” the pre-calculated nomogram.

² Under the current CEC-CAISO Project Plan, the various new stability metrics that are planned for research and development under the “Monitoring” and “Small-Signal Stability” tasks could be used as stability indicators here.

Note: It is important to use this information with caution, because the current operating condition can be very different in comparison to the “worst case” condition implied by the nomogram. The nomogram “repair” should be only authorized when sufficient statistical data has been gathered to indicate the need for this change. The measurement data needs to be augmented with contingency computations based on this data in order to be applicable to updating nomogram walls that account for n-1 security under contingencies.

For local limit assessment purposes, additional PMU units could be recommended to be installed in certain critical locations to provide full observability of the known problem regions so that all the critical and most influential set of parameters and states can be evaluated in real time with very high resolution. In existing systems, the information on possible violations becomes available to the grid operator with resolution from several seconds (within the SCADA/EMS cycle) to several minutes (as a result of the State Estimation cycle). Even if the nomogram monitoring feature is available to the real-time dispatchers at all, the existing systems may have delays that may be critical in some emergency conditions. Sudden unanticipated changes (for instance, the ones that may be precursors of an approaching blackout) and other rapid dynamic processes are hard to capture on time frames based on the SCADA or EMS information. Short-term parameter trends, which could lead to instabilities, and which are so important for predicting violations and real-time decision making, are almost impossible to identify in the existing systems.

The use of PMUs to monitor existing nomograms would help to provide a tighter real-time monitoring of the operational limits. The sub second information from the problem area would increase the situational awareness of the real-time dispatch personnel and allow for more time for timely manual and automatic remedial actions in the future (Figure 3).




Figure 3: Use of additional PMUs to monitor existing nomograms in real-time

2.2. Use of PMUs for Reduced Dynamic Equivalents and Transient Stability Assessment

Although phasor measurements cannot describe the complete system dynamics they seem to be well suited to identifying reduced dynamic equivalents. Here, a reduced dynamic model designed to capture some aspect of the system dynamics is assumed and the phasor measurements are used to estimate the current parameters of the reduced dynamic model in real time.

For example, the simplest dynamical equivalent is the swing equation for a single machine infinite bus system. With phasor angle measurements from a pair of critical points across the grid, the dynamics of the difference of the two angles can be used to fit the swing equation parameters such as synchronizing and damping torque. This swing equation would capture an aspect of the dynamics between the two areas in which the measurements were taken. Measurements could also be used to identify more elaborate multi-machine dynamic equivalents that would better capture aspects of the western area dynamics. One approach would be to combine together phasor angle measurements in one area to obtain a combined phasor angle measurement representing a lumped node in the reduced dynamic mode representing that area.

These reduced dynamic equivalents may be used in both in transient stability and small-signal oscillatory stability studies. For transient stability, the method relies on identifying a group of machines that separate from the other machines given a particular contingency. The machine groups are assumed to swing together. Consider phasor measurements from two groups - one inside the separating group of machines and one outside the separating group. These two groups of phasor measurements could be used to identify the parameters of the single machine equivalent in the pre-fault system. The change between the fault-on and pre-fault systems could be determined by offline simulation. The same change applied to the measurement based pre-fault system can be used to obtain an estimate of the fault-on system trajectory. Such a transient stability assessment could be usefully applied to studied patterns of transient stability that cause known separations and to the binding transient stability limits. For oscillatory stability, such reduced dynamic models may capture the low frequency oscillatory modes. An advantage of such a model-based approach is that it may be used to quickly obtain corrective measures to suppress oscillations or increase their damping.

Note: The use of the reduced dynamic equivalent is limited by the extent to which a simpler reduced dynamical model can usefully approximate the entire dynamics. However, in general, the assumption of a dynamic model allows for fewer measurements than in a static model because dynamic observer methods become feasible.

2.3. New Concept of Wide Area Nomograms

Although the existing set of PMU measurements do not provide complete system observability, they could nevertheless provide wide-area visibility and one could conceptualize a completely new type of Wide-Area Nomograms for monitoring. The proposed concept relies on the hypothesis that for these wide-area nomograms, nodal voltage angles (or magnitudes) may provide a more convenient coordinate system for measuring certain stability margins when compared with nodal power injections that are traditionally used for this purpose. In this case the phasor measurements would be ideal candidates for monitoring system conditions with respect to these wide-area nomograms. A frequently proposed simple form of the wide-area nomograms consists of inequalities applied to the voltage angle differences measured at different locations within the Interconnection – see Figure 4.

$$\delta_i - \delta_j \leq \delta_{ij}^{\max}, \quad i, j = 1, 2, 3, \dots, n \quad (1)$$

It is intuitively clear that large angle differences indicate more stress posed on the system, and that there are certain limits of this stress that make the system unstable or push it beyond the admissible operating limits such as thermal or voltage magnitude limits. At the same time, conditions applied to the angle differences are quite primitive and do not provide an acceptable accuracy of approximation of the power flow stability boundary, especially due to the nonlinear shape of this boundary.

The most convincing argument for using angles for the nomogram coordinates instead of the more traditional power flows (e.g. interface flows, total generation, total load, etc) is that angles are a more direct measure of transient stability, and therefore better coordinate system for observing transient stability. In particular, the implications of any topology changes, such as line outages, are directly observable in the angle measurement which may otherwise be absent in the MW flows – the angle difference across the interface increases when a line opens while the net MW flows through a corridor may remain unchanged (i.e. the excess power is rerouted through the other parallel lines). For this very reason, while the boundaries of conventional nomograms need to be adjusted to reflect topology changes, the boundaries of nomograms in the new angle coordinate system may be more static and consequently prove to be a more appropriate for monitoring and assessing proximity to instability.

The above mentioned scenario is illustrated by actual event that occurred on June 18th 2006, when a Malin-Round Mountain transmission line outage occurred which redirected the net power flow through the other two lines (Malin-Round Mountain 2 & Captain Jack-Olinda) that collectively define the California Oregon Interface (COI) path. The net COI flows, however, remained unchanged.




Figure 4: MW Flow and Angle Difference tracking across COI – (a) the net MW flows remained unchanged (b) the transmission outage was captured by angle difference.

Note: Net MW flow across COI before event = (1207 + 1190 + 1235) = 3632 MW

Net MW flow across COI after event = (0 + 2123 + 1583) = 3706 MW

The above figures illustrate how net COI power flow did not change after the line trip, but, the phase angle difference across COI changed by 3.88 degrees indicating greater stress.

Additionally, the fact that angle differences at other regions did not change seems to suggest that monitoring these angle difference changes can also be used to indicate the location of the event).

A better approximation of the wide-area nomograms could be achieved by applying more precise approximating conditions representing linear combinations of the voltage angles determined at different locations within the Interconnection. A hypothetical wide area nomogram for three angles (shown in Figure 4) could be described by the following set of inequalities:

$$\begin{cases} \rho_{11}\delta_1 + \rho_{12}\delta_2 + \rho_{12}\delta_2 \leq \delta_1^{\max} \\ \rho_{21}\delta_1 + \rho_{22}\delta_2 + \rho_{22}\delta_2 \leq \delta_2^{\max} \\ \dots \\ \rho_{m1}\delta_1 + \rho_{m2}\delta_2 + \rho_{m2}\delta_2 \leq \delta_m^{\max} \end{cases} \quad (2)$$

Figure 5 shows a conceptual view of the simple angle difference nomogram (a) and advanced angle nomogram (b). The angle difference nomogram is basically a set of straight lines corresponding to different levels of δ_3 . The advanced angle diagram gives a set of broken straight lines that can be adjusted to provide a better accuracy of the stability boundary approximation. It is clear that the advanced angle nomogram can follow the actual nonlinear shape of the stability boundary much more closely and consequently provides much better accuracy than the simple angle difference nomogram. The advanced angle approach, solely based on the angle differences, is more related to the static angle stability and active power “loadability” of the Interconnection.




Figure 5: Western interconnection transmission paths




Figure 6: Conceptual view of simple angle difference and advanced angle nomograms

An even more accurate approximation can be achieved by the use of Cartesian coordinates instead of the polar coordinates, and by the use of m linear combinations of active and reactive components of the nodal voltages measured at different locations $1 \dots n$ in the system describing the proposed wide-area nomograms:

$$\alpha_{i1}V_1' + \beta_{i1}V_1'' + \alpha_{i2}V_2' + \beta_{i2}V_2'' + \dots + \alpha_{in}V_n' + \beta_{in}V_n'' \leq \gamma_i, \quad i = 1, \dots, m \quad (3)$$

Numerical experiments with the use of Cartesian coordinates on the test example in Figure 6 show that the stability boundary has a “more linear” shape and consequently is more accurate in its approximation.




Figure 7: A cutset of stability boundary in rectangular coordinates of nodal voltages (New England test system)³

Hence, a new concept of measuring the stability margin by distances calculated in the space of nodal voltages can be suggested.

While angles may be more conducive to monitoring stability, MW flows are still the true controllable variables in the power system. Hence, understanding the relationship between angle differences across a critical interface and MW flows through it is still important. Figure 8 show the net MW imports into California through the California-Oregon Intertie (COI) over a 24 hour period under normal system conditions. Also shown is the angle difference between John Day (a substation up north in Oregon) and Vincent (a substation down south in southern California). The close correlation between these two trends suggest (1) using well chosen angle difference pairs to monitor stability does capture the conventional information present from monitoring the MW path flows while having the added advantage of also reflecting topology changes as mentioned earlier; (2) the relationship between flows and angle differences can easily be ascertained from similar trends - e.g. Figure 8 trends suggest a 15 degree angle change for 1,000 MW increase in COI flows.

³ Y.V. Makarov, V. A. Maslennikov, and D. J. Hill, "Calculation of Oscillatory Stability Margins in the Space of Power System Controlled Parameters", Proc. International Symposium on Electric Power Engineering Stockholm Power Tech: Power Systems, Stockholm, Sweden, 18-22 June 1995, pp. 416-422.




Figure 8: Correlation between MW flows across critical flowgates and angle difference pairs

To better understand the behavior of these nodal voltage angles, these measurements were gathered over several hours by PMUs from different geographic locations within the Western Electricity Reliability Council (WECC) phasor network was used to generate the plots in Figure 9 (a) and (b). Using one of the three nodal voltage angles as the reference, the relative angles at the other two locations was plotted in angle-angle space. In these plots, each set of hourly data is represented by a different color as indicated by the legend. The fact that these trends fall along a narrow and almost linear corridor in this angle-angle space indicates that the behavior of these relative angles is highly correlated with each other. The directionality of this corridor on the other hand is representative of the interdependence of the interaction. For example, if angle differences are indicators of static stress across the grid, then the orientation of the trends in (a) suggests an increase in the stress across one interface implies an increase in the stress across the other interface. However, the trend orientation in (b) suggests the contrary - an increase in the stress across one interface causes the relief of the stress across the second interface. This strong correlated behavior also suggests that limited observability with a few PMUs at key locations may be adequate to capture the system dynamics from a global prospective.




Figure 9: PMU Measurement based phase angle trends in angle-angle space

2.4. Use of PMUs for Wide-Area Voltage Security Assessment

A California PIER funded parallel effort by Consortium for Electricity Reliability Technology Solutions (CERTS) is currently underway in developing a Voltage Security Application (VSA) that runs in real time and provides real time dispatchers with real time reliability metrics related to voltage stability limits. The VSA application under development will be linked to the CAISO EMS system model and data. It will be used to develop and approximate voltage security regions (a type of multi-dimensional nomograms) using linear approximations or hyperplanes, calculate voltage stability indices. In addition, VSA will identify and display abnormal low voltages, weak elements and places in the system most vulnerable to voltage and voltage stability related problems. This application will also perform contingency analysis and provide the system operators with contingency rankings based on voltage problems for the purposes of system monitoring and selecting preventive and emergency corrective actions.

The VSA platform described above can easily be expanded to study wide-area voltage stability problems by selecting global stressing directions and developing the corresponding security regions. The algorithms being developed in the VSA application provide voltage magnitude and angle information, as well as their corresponding sensitivities and participation factors in voltage collapse. Hence, while the proposed VSA framework uses data from the CAISO state estimator and assumes full observability, this same VSA framework could also be used to develop wide-area nomograms whose coordinates would be nodal voltage magnitudes and angles, and the PMU measurements could directly be used to monitor the system conditions with respect to these new nomograms for a wide-area security assessment (Figure 10).




Figure 10: Voltage stability boundary developed in angle-angle space

2.5. Augmenting Existing Nomograms using Small-Signal Stability Assessment

Although small signal stability models and analysis tools are not widely used in the Western Interconnection, there is a growing interest to better understand small-signal stability limits and possibly build associated nomograms for the WECC system. This is based on the observation that some types of potential instabilities could manifest themselves ahead of time through growing oscillations observed in the system. For example, it has been noticed that insufficient frequency response in California could lead to changes of the power flow patterns in post-transient conditions and may lead to additional limits of the Operating Transfer Capability (OTC) on the Oregon-California interties. The nature of these limitations is related to growing oscillations. The low frequency oscillations observed in the system are consequently of interest because they characterize the stability of the power system and limit the power flow across regions. While there is a danger that such modes can lead to instability in the power system following a sizable event in the system, there is also the risk of these modes becoming negatively damped or unstable due to gradual changes in the system. The ability to continuously track these modes and assess their stability would therefore be a valuable tool for power system engineers. Fortunately, the high resolution and wide-area visibility that PMUs offer are well suited to observe these modes and assess the damping associated with these low frequency modes in real-time.

Small-signal stability software can be an essential addition to the real-time monitoring capabilities offered by PMU measurements. State estimation results coupled with small signal stability models can help to identify the origin of poorly damped oscillations. The identification of oscillatory parameters such as magnitude, damping and frequency are needed before one can select measures to increase the stability margin.

The PMU snapshot data recording can be activated by poorly damped oscillations registered by PMUs and identified by the Small-Signal Stability Monitoring applications. Parameters of these oscillations such as frequency, magnitude, and damping can be identified using special algorithms. Subsequent offline analysis using small-signal and transient stability models will reveal how close these models are to reality. The use of offline models will help to better understand the origin and nature of these oscillations. Questions such as what changes in the system cause oscillations and the identification of a small set of descriptive variables that capture the phenomena are also some of the central issues related to the existing modal analysis tools.

Research work could be conducted to investigate the validity of such an approach. The objective of this study could be to screen the WECC system for locations where the Operating Transfer Capability (OTC) is limited by oscillatory problems. Then the typical frequencies could be determined. The next step is to find the places where these oscillations are better observable, and associate these locations with PMU placement. Oscillation-related OTC limits could be compared with the existing nomograms, or may indicate the necessity of building additional nomograms. After such a set of verification and validation procedures, the results of the PMU-based modal analysis could be used to detect potential violations in real time. Finally this will lead to the improvement of the pre-calculated nomogram limits based on real-time PMU data by observing the differences between the pre-calculated OTC and the real transfers at which the oscillations start to grow.

3.0 ALGORITHMS FOR MONITORING SMALL-SIGNAL STABILITY WITH PHASOR MEASUREMENTS

The underlying assumption enabling swing-mode estimation is that the power system is primarily driven by random processes when operating in an ambient condition. An ambient condition is one where there is no significant disturbance occurring within the system. The primary driving function to the power system is the random variations of the loads. It has been shown that under such an assumption, the resulting power-system signals will be colored by the system dynamics. This coloring allows one to estimate the swing-mode frequencies and damping terms.

Consider the signal flow diagram in Figure 11 representing the excitation of a power system from random load variations. $\underline{v}(t)$ is a vector of random components added to each load; each element independent of the other. The output $y_i(t)$ is the i th measured signal at time t , and $\mu_i(t)$ is measurement noise located at the transducer. In general, $\mu_i(t)$ is a relatively small effect when quality instrumentation is employed; therefore, its effect is often negligible. Theory tells us that because $\underline{v}(t)$ is random, each $y_i(t)$ will also be random. But, $y_i(t)$ is colored by the dynamics of the system.




Figure 11: Signal flow diagram.

Assuming a linear system mode, the output y_i from Figure 11 can be written in auto-regressive moving-average (ARMA) form as

$$y_i(kT) = \sum_{j=1}^n a_j y_i(kT - jT) + \sum_{l=1}^p \left(\sum_{j=0}^{m_{il}} b_{ilj} v_l(kT - jT) \right) + \mu_k(kT), \quad i = 1, 2, \dots, n_o \quad (4)$$

where n_o is the number of output signals measured, T is the sample period, k is the discrete-time integer, n is the order of the system, p is the order of vector \underline{v} , and m_{il} is the MA order of the i th output for the l th input. The autocorrelation of y_i is defined to be

$$r_i(q) = E\{y_i(kT)y_i(kT - qT)\} \quad (5)$$

where $E\{\bullet\}$ is the expectation operator. Over a finite number of data points, the autocorrelation is approximated by

$$r_i(q) \cong \frac{1}{N} \sum_{k=q+1}^N y(kT)y(kT - qT) \quad (6)$$

where N is the total number of data points. Using the same analysis in [1], it can be shown that the autocorrelation satisfies

$$r_i(q) = -\sum_{j=1}^n a_j r_i(q - j), \quad q > m \quad (7)$$

where $m = \max(m_{ii})$. Another useful relationship involving the autocorrelation is

$$S_{ii}(\omega) = F\{r_i(q)\} = E\{Y_i(\omega)Y_i^*(\omega)\} \quad (8)$$

$$r_i(q) = F^{-1}\{S_{ii}(\omega)\} \quad (9)$$

where $F\{\bullet\}$ is the Fourier transform operator, $Y_i(\omega)$ is the Fourier transform of $y_i(t)$ at frequency ω , and $Y_i^*(\omega)$ is the conjugate of $Y_i(\omega)$. S_{ii} is termed the power spectral density (also referred to as the autospectrum) of y_i . Effectively, it represents the energy in a signal as a function of frequency. If one knows the Auto-Regressive (AR) a_j coefficients in (4), then the system poles (or modes) can be calculated from the following equations.

$$z_j = \text{roots}(z^n + a_1 z^{n-1} + \dots + a_n), \quad j = 1, 2, \dots, n \quad (10)$$

$$s_j = \frac{\ln(z_j)}{T} \quad (11)$$

3.1. Algorithms to Estimate the System Modes Using Synchronized Phasor Data

Estimating a power system's electromechanical modal frequency and damping properties using ambient time-synchronized signals is achieved by using parametric system identification methods. Three estimation algorithms to solve the AR coefficients and thus the system modes have been well studied for application purposes and they are:

- Modified extended Yule Walker (YW),
- Modified extended Yule Walker with spectral analysis (YWS), and
- Sub-space system identification (N4SID).

(1) Modified Extended Yule Walker (YW)

The original Yule Walker algorithm is used to estimate the AR parameters and thus the system poles. The extended modified Yule Walker (YW) algorithm is a modified version of the original Yule Walker algorithm with extension to multiple signals for the analysis of

ambient power system data, namely, frequency data, voltage angle data, and etc. The algorithm starts by expanding (7) into matrix form as

$$\begin{bmatrix} r_i(m) & r_i(m-1) & \cdots & r_i(m-n+1) \\ r_i(m+1) & r_i(m) & \cdots & r_i(m-n+2) \\ \vdots & \vdots & \ddots & \vdots \\ r_i(m+M-1) & r_i(m+M-2) & \cdots & r_i(m+M-n) \end{bmatrix} \begin{bmatrix} a_1 \\ a_2 \\ \vdots \\ a_n \end{bmatrix} = - \begin{bmatrix} r_i(m+1) \\ r_i(m+2) \\ \vdots \\ r_i(m+M) \end{bmatrix} \quad (12a)$$

or

$$R_i \underline{a} = -\underline{r}_i \quad (12b)$$

For each output, (12) can be concatenated into one matrix problem as

$$\begin{bmatrix} R_1 \\ R_2 \\ \vdots \\ R_{n_o} \end{bmatrix} \underline{a} = - \begin{bmatrix} \underline{r}_1 \\ \underline{r}_2 \\ \vdots \\ \underline{r}_{n_o} \end{bmatrix} \quad (13)$$

The steps for solving the YW algorithm involve

- Estimating autocorrelation terms using (6),
- Constructing autocorrelation matrix equations (13),
- Solving the equations (13) for the AR coefficients,
- Solving the coefficients equation (10) for the discrete-time modes, and
- Converting the discrete-time modes to the continuous-time modes using (11).

(2) Modified Extended Yule Walker with Spectral Analysis (YWS)

The modified extended Yule Walker with Spectral analysis (YWS) follows the same procedure as the YW method to estimate the system modes, i.e., that the system modes are solved from AR coefficients which in turns are solved from the system autocorrelation matrix equations. However, the YWS algorithm estimates the system autocorrelation terms from its spectrum (9), while the YW algorithm estimates the system autocorrelation terms directly from data samples (6).

(3) Sub-Space System Identification (N4SID)

The third algorithm considered for mode estimation is the time-domain subspace state-space system identification algorithm known as N4SID. The reader is referred to [2] and [3]. Application of the N4SID algorithm to ambient power system data is described in [4]. The algorithm used for this report is implemented in the Matlab function “n4sid” available with the system identification toolbox. Because of the complexity and length of the

algorithm, it is not repeated here. Similar to the YW and YWS algorithm, the N4SID algorithm provides an estimate of the system's characteristic equation parameters.

3.2. Mode Selection

When applying the previous mode estimation algorithms, one ends up estimating many “extra” modes due to numerical over fitting. A fundamental problem is determining which of the modes are actually contained in the system and which are numerical artifacts. This problem is addressed by developing a method of calculating the most “dominant” modes in a signal. The dominant modes are then judged to be the ones contained in the system.

Because the signals are random, one cannot directly calculate the energy of a given mode within the signal. But, one can estimate the “pseudo energy” of a given mode within the autocorrelation function. If one takes the Z-transform of the equation (7) and solves for $r_i(q)$ in parallel form, one obtains

$$r_i(q) = \sum_{j=1}^n B_{ij} z_j^{q-m-1}, \quad q > m \quad (14a)$$

where z_j is the j th discrete-time pole, and B_{ij} is termed the residue for pole z_j and output i referenced to time $m+1$. This is expanded into matrix form as

$$\begin{bmatrix} z_1^0 & z_2^0 & \cdots & z_n^0 \\ z_1^1 & z_2^1 & \cdots & z_n^1 \\ \vdots & \vdots & \ddots & \vdots \\ z_1^{M-1} & z_2^{M-1} & \cdots & z_n^{M-1} \end{bmatrix} \begin{bmatrix} B_{i1} \\ B_{i2} \\ \vdots \\ B_{in} \end{bmatrix} = \begin{bmatrix} r_i(m+1) \\ r_i(m+2) \\ \vdots \\ r_i(m+M) \end{bmatrix} \quad (14b)$$

Equation (11) can be solved for the unknown B_{ij} terms. The “pseudo mode energy” of mode j in signal i is then defined to be

$$E_{ij} = B_{ij}^* B_{ij} \sum_{q=0}^{M-1} \left[(z_j^q)^* (z_j^q) \right] \quad (15)$$

To select estimate a mode in a signal, the following steps are conducted:

- One of the three algorithms (YW, YWS, or N4SID) is used to estimate the system modes ($z_i, i=1, \dots, n$ for discrete-time; $s_i, i=1, \dots, n$ for continuous time).
- The pseudo modal energies are calculated by solving (14) in a least-squares sense and (15).
- The modes within a specified region of the s-plane are saved and ordered according to their energy.

3.3. Algorithm Tuning

To use each of the algorithms, several analysis parameters must be selected. This includes all the parameters in equations (4) through (15).

- N = number of data points used for analysis (required for all algorithms). Note that $T_{total} = T * N$.
- T = sample period for collecting data (required for all algorithms).
- n_o = number of signals to analyze (required for all algorithms).
- n = model order (required for all algorithms).
- m = MA order (required for YW, YWS, and mode selection algorithms).
- M_{AR} = number of samples of the autocorrelation function used to solve for the AR parameters. This equal to M in equation (9a). Required for the YW and YWS algorithms.
- N_{fft} = number of samples used for the *pwelch* function in YWS.
- M_{RES} = number of samples of the autocorrelation function used to solve for the residue parameters. This equal to M in equation (10b). Required for the all three algorithms.

Extensive research on how to select these parameters has been done [5]. The research includes testing and evaluating the algorithms by Monte-Carlo simulations on a test system as well as analysis of WECC PMU data. The recommended analysis parameters from the research are:

$$T = 0.2 \text{ sec.}$$

$$T_{total} = 5 \text{ minutes or greater}$$

$$n_o = 1 \text{ to } 4 \text{ signals}$$

$$n = 25, m = 10 \text{ for YW and YWS.}$$

$$n = 20, m = 5 \text{ for N4SID.}$$

$$M_{AR} = M_{RES} = 10 \text{ sec.}$$

The above algorithms were applied to western system data. Approximately 2 hours of ambient data was collected from several PMUs within the WECC system on March 7, 2006. Extensive spectrum analysis was conducted on the data to determine the modal content. Analysis of the data indicated that frequency error estimated from finite-difference of the voltage angles provided quality data.

Table 1 summarizes the results from the spectral analysis. As typical of the WECC system with Alberta connected, the system is dominated by the 0.265-Hz “Intertie” mode and the 0.385-Hz “Alberta” mode. Several higher-frequency weaker inter-area modes are also described in

Table 1.

The first step in the modal analysis is to select the appropriate signals. The goal is to select signals with high observability (i.e., large peaks in the power spectrum) of the “Intertie” and “Alberta” modes and low observability of the other modes. This is most easily done by

subtracting two signals that oscillate out of phase from each other at the frequencies of interest.
Scanning

Table 1, one sees that the following signals are excellent choices for estimating the two modes of interest:

- (Grand Coulee Handford) – (Big Creek 3 230kV)
- (John Day) – (Vincent 230kV)

The 10 min. analysis window was applied to just over two hours of ambient data by sliding it in 5 min. steps. This results in 25 total mode-meter analyses. For each case, the two modes with the largest pseudo-energy terms in the region of the s-plane bound by 0.2 Hz, 0.5 Hz, and 20% damping were estimated with a mode-meter algorithm. The s-domain plots of the results are shown in Figure 12. The two dominant “Intertie” and “Alberta” modes are observable within this data set and shown on the plots. All three algorithms are able to identify these modes with consistent results and comparable performance. Additionally, while the modal frequencies are relatively constant over the entire duration of the data set, there appears to be much greater variability in the % damping (i.e. 5% - 20% damping) over time. Additionally, a longer term (24 hours) behavior of the “Intertie” mode (frequency & damping) and corresponding California-Oregon Intertie (COI) loading conditions for different is shown in Figure 13. This plot shows a great deal of variability in the % damping over the 24 hour period.




Figure 12: Mode estimates for WECC data




Figure 13: Long-term Intertie mode trends (frequency & damping) with varying COI flows

Furthermore, in addition to the modes estimation algorithms discussed above, it is also desirable to understand the observability of a mode at a particular monitoring location. Such information will be helpful in identifying appropriate points for control actions towards mitigating poor damping situations. Waterfall plots, which are series of power-spectrum snapshots of a monitored signal over time, are important for such investigation. The waterfall plot for the COI flows over the latter half of 24 hour period is shown in Figure 14, where the power-spectral density within the frequency range of interest (y-axis) and its recent trends over time (x-axis) are illustrated. The magnitude of the power spectra shown along the z-axis (color-coded) truly indicates the power inherent in the selected signal and is interpreted as the square of the rms of the magnitude of the components in the signal along the frequency axis. Note that the variability observed in the % damping at 0.25 Hz (Figure 13) is also visible in the power-spectral density at the same 0.25 Hz – i.e. as this mode’s damping changes over time, the spectral peak at this modal frequency becomes more/less prominent. Such modal variability over longer term time scales (minutes and hours) needs further investigation.




Figure 14: Long-term Inertie mode spectral trends with varying COI flows

3.4. Implementation of Small-Signal Stability Monitoring Prototype Tool

During 2006, a *Small-Signal Stability Monitoring* application that utilizes the above mentioned algorithms to monitor and track the low frequency modes prevalent within the power system in real time and under ambient system conditions, was developed. The application underwent field trial at both the CA ISO and BPA, prior to being migrated onto production hardware and installed in the CA ISO control center in June 2007. A sample operator display from this tool is shown in Figure 15.




Figure 15: Small-Signal Stability Monitoring Display

Some of the visualization capabilities that are available within the Small-Stability Monitoring tool include:

- Color-coded 'speedometer' type gauges that provide information on damping ratios and damping frequencies of the observable modes in the system. The sub-areas within each gauge are color coded to represent different ranges of damping ratios – i.e., a 5%-20% damping ratio shown in green indicating a safe operating region; a 3%-5% damping ratio in yellow indicating an alert condition; and less than 3% damping ratio shown in red representing an alarm situation. The positions of the needles swing back and forth in real time to indicate the current damping ratios of the system modes.

- Mode tracking plot that offers valuable information on the most recent modal trends to operators (Figure 16). Here the most recent (red crosses) and the historical (white circles) modes are shown within a 2-dimensional Frequency (in Hz) vs. Damping (in %) plane. Hence, the recent damping ratio patterns can be traced by observing the trace of the modes along the horizontal axis on the plot. Similar to the above mentioned mode meter gauges, yellow and red lines set the thresholds for the alert- and alarm-level of damping ratio on the plot.
- Waterfall plot which is a joint time-frequency domain plot and an illustration of the power-spectral density within the frequency range of interest (typically 0.1Hz – 1Hz for inter-area electro-mechanical modes) and its recent trends over time.




Figure 16: Sample Mode Tracking Plot




Figure 17: Sample Waterfall Plot

It is important to mention that appropriate pre-processing of the data prior to running the algorithms is critical to performance the tool and the accuracy of the modal estimates. Data pre-processing stage includes removing outlier and missing data, detrending, normalization, anti-aliasing filtering and down sampling, etc. Additionally, to help focus on the interested range of frequency of the modes (i.e., the range of wide-area oscillations), proper post-processing is also desired. Post-processing includes setting the maximum number of modes for display, setting the maximum associated damping ratio, setting the energy threshold for the modes, and setting proper frequency range. These pre- and post-processing stages have been incorporated into the mode the prototype and are end-user configurable (Figure 18).




Figure 18: Block Diagram for the Small-Signal Stability Monitoring Tool.

In late 2007/early 2008, the Small Signal Stability tool's algorithms, visuals and feature set were further enhanced based on additional research and end user feedback. Some of the improvements included:

- Improved mode estimation algorithms and graphics to quantify the uncertainty associated with the mode estimates. Here, a newly developed 'bootstrapping' method was embedded into the tool that compute the uncertainty region or error bounds (a.k.a. confidence intervals) associated with each estimate and is illustrated as an ellipse on the same 2-D frequency vs. damping ratio plane representing the uncertainties in both the modal damping and frequency (Figure 19). A smaller ellipse would therefore signify greater confidence in the modal estimate while a large ellipse would indicate greater uncertainty.




Figure 19: Improved Mode Tracking Plot with Bootstrapping Ellipse

- Capability to archive modal frequency and damping estimates for long term trending analysis thereby facilitating the ability to perform long-term correlation analysis between modal performance and other key metrics (e.g., loading on key corridors).
- Ability to rewind, playback and recreate existing Small-Signal Stability monitoring displays using historical data in memory.
- Ability to load single or multiple phasor disturbance files and perform small-signal stability type of forensics to assess the stability of the power system prior to and after the event through various analysis techniques (e.g. spectral analysis, modal analysis). For example, the tool's spectral analysis display, shown in Figure 20, lets the user to analyze the spectral content of chosen signals using three primary calculations (1) *Power Spectral Density (PSD) or Auto-Spectrum* to identify sharp peaks indicative of strong oscillatory activity observable in the signal; (2) *Coherency*: to identify a signal's correlation or participation in a particular mode; (3) *Cross Spectral Density (CSD) or Cross-Spectrum*: to identify the relative phase information associated with a particular mode (i.e. mode shape information). Note: The PSD and CSD are calculated using Welch's periodogram averaging technique – the algorithm parameter settings (e.g. time window, percent overlap, FFT window length) may be changed through a user friendly GUI.




Figure 20: Sample Spectral Analysis Display.


4.0 MEASUREMENT BASED SENSITIVITIES AND VOLTAGE STABILITY MONITORING

4.1. Measurement based Sensitivities


It is well understood that with additional loading on the power system, there is degradation in the voltages across the system. This relationship is typically represented by the P-V or Q-V curves. Furthermore, the gradient at any point along such a curve provides the voltage sensitivity at that bus with respect to the loading conditions. The traditional method for obtaining this information is dependent on the system model, especially the load model, which is built by history data.

Phasor measurements offer the ability to obtain this very same information directly from the real time measurement without requiring any modeling information. In particular, PMU devices installed at a substation measure the voltage phasors (both magnitudes & angles) at a bus and the MW and MVAR flows on the monitored lines. With the precise time-synchronized alignment and the high sub-second resolution of these measurements, it is possible to trace out portions of the P-V or Q-V curves for a monitored critical load bus or corridor in real time. Additionally, there is enough loading variation within the system to estimate the local gradient of such curves which map changes in one variable (MW or MVARs) to changes in the other (voltages) – i.e., the current voltage sensitivities at that location/interface.

For illustration purposes, Figure 21 traces the P-V curves, and tracks the voltage sensitivities at the Malin 500 kV bus over time under different COI loading conditions. The sensitivities are computed using linear regression on the most recent data set collected over a 10 minute window. The results exemplify how the voltage sensitivity increases with increased loading as the system operating point moves further down along the P-V curve and closer to the voltage collapse point and can be used to anticipate low voltage problems. Additionally, is also possible to quickly detect discrete changes in the system such as control actions (e.g. insertion of cap banks), which cause these curves to shift outward (or inward).



(a)



(b)

Figure 21: P-V curves and voltage sensitivities at different loading levels across COI - (a) voltage sensitivity ~ 1kV/100MW under light loading conditions (b) voltage sensitivity ~ 3kV/100MW under increased loading conditions.

Different techniques may be used to perform the regression and obtain these sensitivities: (1) least squares linear regression, and (2) orthogonal regression. Initial results suggest orthogonal regression is preferable and is less prone to inaccuracies especially when a short time window is used (Figure 22).




Figure 22: Estimating sensitivities using (a) Least Squares Regression (b) Orthogonal Regression.

4.2. Voltage Stability Loading Margins

A literature review on the utilization phasor measurements to monitor voltage stability margins has shown that such measurements at load bus or across a key interface can also be used to estimate the maximum loading margins at the bus and define a Voltage Stability Index (VSI) for the bus/interface [8-11]. It is a well-known fact that for a two-bus system with a constant power load (i.e., a constant source behind an impedance and a load), the maximum loadability condition occurs when the voltage drop across the source impedance is equal to the voltage across the load. Hence, the idea is to use the phasor measurements at the bus to dynamically track in real-time the two-bus equivalent of the system. In particular, given the voltage and current phasor measurements at the bus (\bar{V} and \bar{I}), it is possible to estimate the parameters of the Thevenin equivalent system (\bar{E}_{th} and \bar{Z}_{th}) from a sliding window of discrete samples using a recursive least squares scheme (RLS). The maximum loadability condition corresponds to the case when $E_{th} = 2V$ and the Voltage Stability Index can be defined as:

$$VSI = \frac{V}{\Delta V} = \frac{Z_{app}}{Z_{th}} \quad (16)$$

where ΔV is the voltage drop across the Thevenin equivalent impedance and Z_{app} is the apparent load impedance (i.e., $|\bar{V}/\bar{I}|$). This indicator reaches unity at the maximum loadability point. Furthermore, since the Thevenin parameters are being tracked dynamically, they reflect any changes that may occur in the power system operating conditions and consequently provide the most accurate assessment of loadability estimates.

The very same methodology can also be used to compute Voltage Stability Index for the power transfer across a tie-line. By assuming a directional flow across the line, the line is replaced by a fictitious sink and source at the sending and receiving ends of the line respectively, that draw the same power as the tie-line flows. One can now replace the system with its Thevenin equivalent and compute the VSI for the tie-line flows as well.

Finally, if we assume that ‘ Z_{th} ’ isn’t changing significantly, we can also compute a Power Margin (PM) from the two-bus equivalent as:

$$\Delta S = \frac{(E_{th} - Z_{th} I_{th})^2}{4Z_{th}} \quad (17)$$

Again, operators may be alarmed if these indices fall below predetermined thresholds (e.g. 5% of the current load/flow).




Figure 23: Flow Chart for voltage stability assessment based on phasor measurements.

More recently, a new voltage stability analysis model has been proposed for a multiple-infeed load center where both sides of the interconnection to the load are assumed to be able to provide voltage support [21]. In this model, Thevenin equivalents are estimated at both sides of

the bus (Figure 24). In order to represent correctly the loads, the equivalent resistances cannot be ignored anymore.




Figure 24: Voltage stability analysis model for a multiple-infeed load center using phasor measurements.

To compute the equivalent parameters of the new model, the following least squares optimization problem needs to be solved (at least three measurements are required). Besides, the accuracy of the estimation highly depends on the sampling rate: it must be chosen so that data points are not too close to each other.

$$\min_{E_s, \delta_{s_i}, X_s, R_s, E_r, \delta_{r_i}, X_r, R_r} \left\| \begin{array}{c} E_r \sin(\delta_{r_i}) + R_r I \sin(\phi_i) + X_r I \cos(\phi_i) - V_i \\ E_s \sin(\delta_{s_i}) + R_s I \sin(\phi_i) + X_s I \cos(\phi_i) \\ E_r \sin(\delta_{r_i}) + R_r I \sin(\phi_i) + X_r I \cos(\phi_i) - V_i \\ E_r \sin(\delta_{r_i}) + R_r I \sin(\phi_i) + X_r I \cos(\phi_i) \\ \dots \\ \dots \end{array} \right\| \quad (18)$$

where:

$$\begin{aligned}
 I \cos(\phi_i) &= P_i / V_i \\
 I \sin(\phi_i) &= -Q_i / V_i
 \end{aligned}$$

The first advantage of such a model is that it provides a better representation of the real power system. Indeed, the fact that voltage support may come from both sides of the bus is now taken into account. The second important feature of this model is that it estimates the voltage stability margin of the system without having to make some hypothesis on the load model. Overall, it is

its simplicity that makes this model very easy to use for real time stability estimation of a transmission path.

In order to see whether this model gives accurate results, the multiple-infeed model is tested at load center within the CA ISO. The following table presents the values of the computed equivalent Thevenin parameters:

E_s	R_s	X_s	E_l	R_l	X_l
1.066	0.067	0.034	0.989	0.01	0.041

From these results, the P-V curves can be plotted (Figure 25). This method seems to give a good estimation of the voltage stability margin. However, it should be pointed out that the model was tested in an unstressed situation. Additional studies under stressed conditions are needed to further validate the approach.




Figure 25: Estimating voltage stability margins with phasor measurements: (a) P-V curve predicted by the multiple-feed load center model; (b) phase measurement data used in the model parameter estimation.

A limitation of the above approaches is that the initial margin estimates and stability indices incur abrupt jumps when discrete events such as generator limits are reached. However, given that system voltage collapse typically occurs at slower timescales, if these algorithms are used in a real-time environment where the estimates are updating periodically at frequent intervals, then such an application should be able to provide adequate early warning to the operator in spite of the above mentioned limitation.

4.3. Predicting Voltage Stability with Phasor Measurements

The synchronized voltage measurements also serve as a time series that can be used to develop an adaptive Auto-Regressive (AR) predictive model to project the voltage trends a short interval into the future [12] (Note: A similar AR model was proposed for the small-signal stability monitoring algorithms). This approach is especially useful to ascertain the outcome of a sudden disturbance injected into the system due to a fault or an outage. An AR model is ideal for expressing a signal as a mixture of exponentially decreasing and damped sinusoidal components (i.e., ' $Ae^{\alpha t} \sin(\omega t + \beta)$ ' where ' A ', ' α ', ' ω ' and ' β ' are the strength, damping, frequency and phase respectively). Hence, given ' N ' measurement samples over a predefined time window, the objective is to fit them to a ' p ' order Auto-Regressive model (AR- p) given by:

$$X_t = \sum_{i=1}^p \phi_i X_{t-i} + a_t \quad (19)$$

where ' X_t ' are the measurements, ' ϕ_i ' are the model parameters (also called prediction coefficients) and ' a_t ' is the white noise in the measurements. The Voltage Stability Index mentioned above can then be applied to the predicted trace for a fast stability assessment soon after the transient has been launched.

4.4. Implementation of Measurement based Sensitivity Prototype Tool

In late 2007, the phasor visualization tool was augmented with two new displays for measurement based Angle Sensitivity and Voltage Sensitivity. This has facilitate better understanding of Voltage-(Real/Reactive) Power and Phase Angle-Real Power relationships for key corridors and at critical generation and load buses where PMUs have been installed. The associated sensitivities (in kV/100MVAR or %/100MW) are also important stability indicators with respect to voltage and transient stability, and provide real time visual alarming to operators when these sensitivities exceed acceptable thresholds.

Figure 26 is a sample operator display for monitoring measurement based sensitivities. Here, the two signal pairs (e.g., voltage at a bus and loading at bus/flows across a corridor) for which the sensitivity is to be monitored and tracked are encircled by an ellipse, which is colored as per the sensitivity alarming threshold limits. Hence, multiple groups within the geographic display are illustrative of the various signal pairs for which the sensitivity is being computed in real time. For the one selected pair (highlighted in the display), the smaller panel on the top right provides the sensitivity trends color-coded to represent normal, alert or alarm levels. The corresponding P-V curve(s) is also shown in the bottom right with the most recent data points shown in red. In Figure 26, notice how the curve moves outward over time due to changing system conditions. The ability to track these curves and sensitivities in real time purely from system measurements, and therefore presenting the actual situation, is valuable information for the operator.




Figure 26: Voltage Sensitivity Monitoring Display

5.0 FREQUENCY RESPONSE MONITORING

A control area's contribution to frequency support is measured by the natural frequency response of its generators and load to frequency variations. It characterizes the typical frequency excursion (within the seconds timeframe) following a loss of a large generator on an Interconnection which is associated with primary control and is comprised of the following two components [13]:

- Natural arrest in frequency decline due to “load rejection” or reduced power consumption of frequency dependent loads (e.g. motors).
- The governing action of generating units responding to the declining frequency in the 3-10 seconds timeframe in an attempt to partially recover the frequency before secondary frequency regulation or Automatic Generation Control (AGC) units bring the frequency back to 60Hz or pre-event levels within 2-10 minutes (i.e., AGC time constants).

Traditionally, the frequency response characteristic (β'), expressed in MW/0.1Hz and a measure of frequency control stiffness, is calculated using 1-minute CPS data (one-minute averages of ACE and “frequency deviation from scheduled”) using the following equation [16]:

$$\text{Freq. Response}_{\text{interconnection}} = \text{Bias}_{\text{Sinterconnection}} - (\Delta \text{ACE}_{\text{net}} / \Delta \text{freq}) \quad (20)$$

where

$\text{Bias}_{\text{Sinterconnection}}$ = the interconnection frequency bias

ACE_{net} = the aggregate of the ACE for all the control areas in the interconnection

$\Delta \text{ACE}_{\text{net}}$ = the net ACE change between two consecutive minutes

Δfreq = the frequency change between two consecutive minutes

A larger value for β' , expressed in MW/0.1Hz, indicates a stiffer frequency control allowing less drop following the loss of generation [14].

Although the above mentioned approach has shown merit [16], time skews between the different measurements can introduce inaccuracies and spurious results. Furthermore, given that the timescales associated with frequency response and primary control are in seconds, utilizing 1-minute data for such analysis will have its obvious limitation. The time synchronization and the higher sub-second resolution of phasor measurements overcome these restrictions and are more apt in observing frequency response following generator trips and deducing frequency response characteristics.

As an example, Figure 27 shows the frequency response captured by the WECC phasor network. These observations are consistent with following excerpt from the CA ISO event log:

“01/15/2006 - 00:24 System frequency deviated from 59.995Hz to 59.947Hz and recovered to 59.961Hz by governor action when NWE Colstrip Unit 1 relayed while carrying 240 MW. System frequency returned to pre-disturbance level at 00:29.”

A straightforward calculation on this dataset shows the frequency response coefficient to be:

$$\beta = \Delta P / \Delta f = 240 / (59.991 - 59.961) = 800 \text{ MW} / 0.1 \text{ Hz} \quad (21)$$




Figure 27: Frequency response captured by the phasor measurement network due to the Colstrip unit outage – (a) the interconnection frequency response to the outage (b) the ringdown observed in the MW flows from the Colstrip bus.

Previous data has shown that the frequency response can vary significantly from one generation outage to another. With frequency response characteristic being an important element for reliable grid operations, developing a historical database of such events and correlating 'β' by peak/offpeak conditions, time of day, weekday/weekend, etc towards building

a better understanding of such trends is a worthwhile effort. Furthermore this process can be automated within the phasor system application:

- Identify generator trip events using a rate-of-change trigger (a 20mHz/second rate-of-change within a 1-second window that is persistent for 2 or more seconds is proven to work well for this purpose).
- Approximate the interconnection frequency as a spatial average of geographically dispersed group of reliable PMU measurements that have been predefined.
- Calculate the relative frequency change (Δf) between the pre-event interconnection frequency and its value 10-20 seconds into the event – i.e. the timeframe associated with primary control to partially recover and stabilize the frequency.
- Inspect real powerflows out of all monitored generation stations to identify MW loss (ΔP) associated with the outage – (Note: in the case that the generation station is not monitored, this may have to be manually entered after the fact through a user interface).
- Calculate and record the frequency response characteristic ($\Delta P/\Delta f$).

6.0 GRAPH THEORY BASED PATTERN RECOGNITION

Graph theory techniques can be used to characterize, monitor and assess the global behavior of the power grid. Specifically, the correlation between any two voltage angles is a measure of the electrical connectivity amongst those points: a higher correlation coefficient implies that those two points are directly (or indirectly) electrically connected having lower net intermediate impedance between them than if the correlation coefficient were of a higher value.

If, at each instance in time, one were to create a graph $G=\{V,E\}$, whose nodes $\{V\}$ correspond to each PMU in the system and whose edges $\{E\}$ between nodes denote correlation in phasor measurements. For example, the edge e_{ij} between nodes V_i and V_j is given by $E(x_i(t) x_j(t))$ where $x_i(t)$ is the phasor time series at node V_i , and $E()$ denotes expectation. Assuming an ergodic process during a measurement time window T and letting the vector X_i be denoted by $X_i = [x_i(1), \dots, x_i(T)]$, we get:

$$e_{ij} = X_i^T X_j, \quad (22)$$

Once graph $G(t)$ is formed by this process at time t , one could then perform network level processing on this graph to elicit some user-specified information. For example, the first step could be to segment this graph into a number of strongly connected segments, each of which is weakly connected to other segments. Several methods are available for doing this; one of which is to adapt a powerful set of techniques known as spectral clustering. These methods require the evaluation of a few smallest eigenvalues and eigenvectors of the adjacency matrix $A(t)$ of graph $G(t)$ (Note: $A(t)_{ij} = e_{ij}$). For a power network with thousands of nodes, this method will be computationally efficient enough for real time computation.

Segmenting the graph into spectral components should prove to be a valuable way of determining the main modes of the entire network without having to monitor individual PMUs. Within each segment one could compute the average signal or the typical signal (either a mean, median or an actual signal from a node in that segment) and this information would represent the generic steady-state or dynamic behavior for that segment.

The goal of this process is to obtain a small set of signals, one from each segment, which are sufficient to be monitored by a human operator for the purpose of real time systems monitoring. In contrast to some existing methods for obtaining a small number of monitorable signals (e.g. Principal Component Analysis), this proposed method relies on graph-theoretic analysis which considers the entire power network and its topology at each time point. The segments obtained by this method will be indicative of the extant network architecture at that time instant. Therefore the monitorable signals using this method is liable to be sensitive not only to absolute or relative signal change at each individual PMU in isolation, but also sensitive to the nature of their interaction with each other.

This method is a more efficient way of summarizing the entire phasor dataset, because it relies on a small number of strongly connected components within the network. During the summarizing process, one can ensure that no relevant data signal goes unreported. This contrasts with the PCA based methods, which monitor a pre-fixed small number of principal components and are insensitive to anomalous data, which appear merely as outliers to be rejected.

The network-level analysis approach can further be developed to perform anomaly detection at the topological level, where the entire network might be undergoing significant but incremental changes in response to an anomalous event as well as to identify the focal root cause of the anomalous behavior by evaluating graph-theoretic distance measures and other graph-theoretic tools. In particular, from the correlation of time-series data over several nodes, it is also possible to create a causality network, which is similar to the network describe earlier, but has directed edges with direction denoting causality. This kind of work has been successfully pioneered in the field of functional medical imaging. From such a causal network, the identification of the root cause or location becomes simply to look for the most highly connected node with outwardly-directed edges. As a bonus, the causal network allows for even more advanced diagnostics: one can detect not only the root cause, but also see the pattern of propagation of the anomaly across the network. It might be possible to identify risky nodes in the network after each event, and recommend corrective measures.

7.0 RTDMS SYSTEM ARCHITECTURE

The RTDMS platform for conducting phasor research and applications prototyping adheres to a Client/Server architecture where the RTDMS Data Management Server distributes the information to the RTDMS Client monitoring applications at multiple locations over LAN connection. The overall RTDMS system architecture is shown in Figure 28, and each of its different components are briefly described below.

At the CAISO, the Phasor Data Concentrator (PDC) receives multiple PDC data streams from each of the utility PDCs, packages those data streams together, and broadcasts the assembled data packet as a UDP stream in PDC Stream format. The *PDCStream/C37.118 Data Interface* has been designed to connect directly with the PDC output over a LAN, and to read in real-time the complete phasor data stream, and calculate various scaled and derived values (such as MW and MVAR). The *Data Quality Filter* component provides the capability to remove erroneous data and perform noise filtering to improve data quality. Any configuration changes, such as setting filtering options, entering PMU/Signal longitudes and latitudes, defining alarming and event archiving attributes, etc, are performed through RTDMS Data Management Server GUI.

The parsed phasor data received from the CAISO PDC and derived quantities are stored into a *Real-Time Buffer* in memory. This real-time data cache is intended to provide high performance data write/read capability for further processing or visualization. Additionally, the data will also be stored in a *SQL Database* for long-term trending and reporting purposes.

The *Alarm/Event Processor* component is designed as a Windows Service that retrieves data from the Real-Time Cache and processes this information using the set of alarming criteria. The results of the Alarm Processor and Trig Logic are saved back into the *Real-Time Buffer* for real-time alarming within the RTDMS Client applications, the SQL Server for offline alarm report generation, as well as logged into a text file for easy access within the Server. Alarming and event detection parameters are centrally configured at the RTDMS Server through the Server GUI.

Like the *Alarm/Event Processor*, the *Small-Signal Stability Module* is also an independent component that interfaces with the *Real Time Buffer* for data retrieval and results save-back. The *Small-Signal Stability Module* pre-processes the data, performs the mode estimation functions, and post-processes the answers. These results are saved back into the *Real Time Buffer* for real-time monitoring and alarming within the RTDMS Client applications, as well as the *RTDMS Database* for long-term trending. A Mode Definition GUI shall be provided on the server to centrally configure the modal estimation parameters and attributes.

The *RTDMS Client* applications (i.e. Visualization and Event Alarms, Small-Signal Stability Monitoring, Event Analyzer, etc) are stand-alone applications that can access the RTDMS Server through DCOM over a LAN connection for data retrieval from the Real-Time Cache and, its display in real-time, process this data into meaningful information, and display it using geographic and graphic displays. The *Report Generator* capability, however, retrieves data from the long-term archive (SQL database). The RTDMS displays enable the user to monitor and

track meaningful performance metrics with respect to predefined thresholds and will be alarmed whenever these thresholds are violated.




Figure 28: Real Time Dynamics Monitoring System Architecture.

8.0 CONCLUSION

This study explores various methodologies of applying phasor technology for improving stability nomograms, monitoring small-signal stability, measuring key sensitivities related to voltage stability or dynamic stability, assessing interconnection frequency response, and applying graph theory concepts for pattern recognition. Many of the ideas proposed here, such as the small-signal stability, measurement based sensitivities, etc, have already been implemented on the RTDMS phasor research platform and tested at CA ISO and BPA, while others are planned for development under a follow-on contract. The development and testing of such prototypes on the RTDMS with California ISO and BPA system operators has accelerated the adoption and use of time-synchronized phasor measurements for real-time applications in the Western Interconnection. As the network has grown and matured and RTDMS applications expanded, CA ISO has invested in upgrading the hardware infrastructure to support the system. The phasor real-time applications which initially ran on PCs/Workstation class machines in an isolated research environment have now migrated to production standards on the CAISO secure corporate network and supported by CAISO IT. The system is also operating reliably - over 90% of the devices reporting, 99% data availability, and no system down time. An indication of the improved reliability is that RTDMS is now at the Reliability Coordinator (RC) Desk in the Folsom Control Room and is an integral part of the real time operations decision making process. The system now offers a rich set of features for wide-area monitoring as well as analytics. This wide-area, common view will allow operators to evaluate stability margins across critical transmission paths, detect potential system instability in real time, and, in the future, take manual or initiate automatic actions to mitigate or dampen these potential problems. It will also enable California ISO, California and WECC utilities to explore closely related issues, such as determining the optimal location of additional phasor measurements, and to gain the experience with the technology required to develop these advanced real-time control applications.

9.0 References

1. Stoica, P., and R. Moses, *Introduction to Spectral Analysis*, Englewood Cliffs, NJ: Prentice Hall, 1997, pp. 103-106.
2. Pierre, J., D. Trudnowski, and M. Donnelly, "Initial Results in Electromechanical Mode Identification from Ambient Data," *IEEE Transactions on Power Systems*, vol. 12, no. 3, Aug. 1997, pp. 1245-1251.
3. Anderson, M., N. Zhou, J. Pierre, and R. Wies, "Bootstrap-Based Confidence Interval Estimates for Electromechanical Modes from Multiple Output Analysis of Measured Ambient Data," *IEEE Transactions on Power Systems*, vol. 20, no. 2, May 2005, pp. 943-950.
4. Van Overschee, P., B. De Moor, *Subspace Identification: Theory, Implementation, Application*, Dordrecht: Kluwer Academic publishers, 1996.
5. Ljung, L., *System Identification: Theory for the User*, 2nd Ed., Prentice Hall, 1999.
6. Zhou, N. and J. Pierre, "Electromechanical Mode Estimation of Power Systems from Injected Probing Signals Using a Subspace Method," *Proceedings of North American Power Symposium (NAPS)*, August 2004.
7. D. J. Trudnowski, J. R. Smith, T. A. Short, and D. A. Pierre, "An Application of Prony Methods in PSS Design for Multimachine Systems," *IEEE Transactions on Power Systems*, vol. 6, no. 2, pp. 118-126, Feb. 1991.
8. K. Vu, M.M. Begovic, D. Novosel, M.M. Saha, "Use of Local Measurements to Estimate Voltage-Stability Margin", *IEEE Transactions on Power Systems*, Vol. 14, No. 3, Aug. 1999, pp. 1029-1035.
9. D.E. Julian, R.P. Schulz, K.T. Vu, W.H. Quaintance, N.H. Bhatt, D. Novosel, "Quantifying Proximity to Voltage Collapse Using the Voltage Instability Predictor (VIP)", 2000 IEEE Power Engineering Society Summer Meeting, Vol. 2, 16-20 Jul. 2000, pp. 931-936.
10. W.H. Quaintance, K. Uhlen, D.E. Julian, J.O. Gjerde, K.T. Vu, L.K. Vormedal, "Raising Energy Transfer in Corridors Constrained by Voltage Instability - Statnett Case", 2000 IEEE Power Engineering Society Summer Meeting, Vol. 4, 16-20 Jul. 2000, pp. 2021-2026.
11. B. Milosevic, M. Begovic, "Voltage-Stability Protection and Control Using a Wide-Area Network of Phasor Measurements", *IEEE Transactions on Power Systems*, Vol. 18, No. 1, Feb. 2003, pp. 121-127.
12. C. Xu, J. Liang, Z. Yun, L. Zhang, "The Small-Disturbance Voltage Stability Analysis through Adaptive AR Model Based on PMU," *IEEE/PES Transmission and Distribution Conference & Exhibition*, Dalian, China, 2005.

13. NERC Frequency Task Force of the NERC Resources Subcommittee, "Frequency Response Standard Whitepaper - Draft", October 2003.
14. R.P. Schulz, "Modeling of Governing Response in the Eastern Interconnection", Proc. 1999 Winter Meeting IEEE Power Engineering Society, pp. 561-566.
15. J. Ingleson & M. Nagle, "Decline of Eastern Interconnection Frequency Response," presented at 1999 Fault & Disturbance Conference, Georgia Tech, May 3-4, 1999.
16. NERC Training Resources Working Group, "NERC Training Document – Understand and Calculate Frequency Response," February 20, 2003.
17. A. G. Phadke, "Synchronized phasor measurements in power systems", IEEE Computer Applications in Power, Vol. 6, Issue 2, pp. 10-15, April 1993.
18. J. Shi and J. Malik, "Normalized Cuts and Image Segmentation", IEEE Transactions on Pattern Analysis and Machine Intelligence, Vol. 22, No. 8, August 2000.
19. R. Myers, R. C. Wilson, and E. R. Hancock, "Bayesian Graph Edit distance" IEEE Transactions on Pattern Analysis and Machine Intelligence, Vol. 22, No. 6, June 2000.
20. Y. Chen, G. Rangarajan, J. Feng, M. Ding, 2004 "Analyzing multiple nonlinear time series with extended Granger causality". Physics Letters A 324, 26-35.
21. M. Parniani, J.H. Chow, L. Vanfretti, B. Bhargava, and A. Salazar, "Voltage Stability Analysis of a Multiple-Infeed Load Center Using Phasor Measurement Data, 2006 IEEE/PES Power Systems Conference and Exposition (IEEE Cat No. 06EX1305C), p 7 pp. 1299-1305, Nov. 2006.

BUS NAME	PSD (L,S, N) 0.265 Hz	Ref. = GC50 0.265 Hz Cxy, angle	PSD (L,S, N) 0.385 Hz	Ref. = GC50 0.385 Hz Cxy, angle	PSD (L,S, N) 0.400 Hz	Ref. = AULT 0.400 Hz Cxy, angle	PSD (L,S, N) 0.60 Hz	Ref. = DV01 0.60 Hz Cxy, angle	PSD (L,S, N) 0.616 Hz Sharp peak	Ref. = SYLM 0.616 Hz Cxy, angle
GC50.VA.Grand Coulee Hanford Voltage	L	Reference	L	Reference	N		N		N	
JDAY.VA.John Day Bus Voltage	L	1.0, 0 deg.	L	1.0, 0 deg.	N		N		N	
MALN.VA.Malin N.Bus Voltage	L	1.0, 0 deg.	L	1.0, 0 deg.	N		N		N	
COLS.VA.Colstrip Bus Voltage	L	0.95, 0 deg.	L	0.90, 0 deg.	N		N		N	
SYLM.VA.Symar Bus Voltage	L	0.90, 180 deg.	L	0.90, 180 deg.	N		N		L	Reference
MPLV.VA.Maple Valley Bus Voltage	L	1.0, 0 deg.	L	1.0, 0 deg.	N		N		N	
SUML.VA.Summer Lake 500 kV Voltage-N	L	1.0, 0 deg.	L	1.0, 0 deg.	N		N		N	
MCN5.VA.McNary 500 kV Voltage-S	L	1.0, 0 deg.	L	1.0, 0 deg.	N		N		N	
AULT.VA.Ault 345 kV Voltage (Craig)	N		N		L	Reference	N		N	
BEAR.VA.Bears Ears 345 kV Bus Voltage (B)	N		N		L	1.0, 0 deg.	N		N	
SHIP.VA.Shiprock 345 kV Voltage (San Juan)	S	0.6, 180 deg.	N		L	0.75, 0 deg.	N		L	0.1
VN01.VA.Vincent 230 kV Voltage	L	0.90, 180 deg.	L	0.90, 180 deg.	N		N		L	0.75, 0 deg.
DV01.VA.Devers 500 KV Bus Voltage	L	0.90, 180 deg.	L	0.90, 180 deg.	N		L	Reference	N	
MIDW5.VA.MIDWAY Bus Voltage	L	0.95, 0 deg.	L	0.9, 0 deg.	N		L	0.75, 180 deg.	S	0.75, 180 deg.
ML50.VA.ML500 Bus Voltage	L	0.97, 0 deg.	L	0.95, 0 deg.	N		L	0.75, 180 deg.	S	0.75, 180 deg.
PTSB.VA.PITSBG Bus Voltage	L	0.97, 0 deg.	L	0.95, 0 deg.	N		L	0.75, 180 deg.	S	0.75, 180 deg.

NOTES:

1. PSD content (L = large, S = small, N = none).
2. The 0.265-Hz mode is the N-S intertie mode.
3. The 0.385-Hz mode has a similar shape as the 0.265-Hz mode. It is likely the Alberta mode; we have no measurements from Alberta to verify this.
4. The 0.616-Hz sharp peak is likely an aliasing artifact due to the DC converters.
5. The 0.60-Hz mode is likely a southern California vs. the middle of California. Much of the spectral information is "masked" by the 0.616-Hz aliasing peak.
6. The 0.65-Hz mode is likely the BC Hydro vs. the northern US.

Table 1: Spectral content of WECC data



Arnold Schwarzenegger
Governor

REAL TIME SYSTEM OPERATION 2006 – 2007

Real-Time Voltage Security Assessment
Report on Algorithms and Framework

Prepared For:
California Energy Commission
Public Interest Energy Research Program

Prepared By:
Lawrence Berkeley National Laboratory

CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

APPENDIX B

Month Year
CEC-500-2008-XXX-APB

Prepared By:

Lawrence Berkeley National Laboratory
Joseph H. Eto, Principal Investigator
Manu Parashar and Abhijeet Agarwal, Electric Power Group
Yuri Makarov, Pacific Northwest National Laboratory
Ian Dobson, University of Wisconsin, Madison
Berkeley, CA 94720
Commission Contract No. 500-02-004
Commission Work Authorization No: MR-041

Prepared For:

Public Interest Energy Research (PIER)
California Energy Commission

Jamie Patterson
Contract Manager

Mike Gravely
Program Area Lead
ENERGY SYSTEMS INTEGRATION

Mike Gravely
Office Manager
ENERGY SYSTEMS RESEARCH

Martha Krebs, Ph.D.
PIER Director


Thom Kelly, Ph.D.
Deputy Director
ENERGY RESEARCH & DEVELOPMENT DIVISION

Melissa Jones
Executive Director



DISCLAIMER

This report was prepared as the result of work sponsored by the California Energy Commission. It does not necessarily represent the views of the Energy Commission, its employees or the State of California. The Energy Commission, the State of California, its employees, contractors and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the uses of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the California Energy Commission nor has the California Energy Commission passed upon the accuracy or adequacy of the information in this report.



**RTVSA REPORT
ON
ALGORITHMS & FRAMEWORK**

Prepared For
California Independent System Operator (CA ISO)

Prepared By
Consortium for Electric Reliability Technology Solutions (CERTS)

Funded By:
California Public Interest Energy Research
Transmission Research Program

Revised June 9, 2008

The work described in this report was coordinated by the Consortium for Electric Reliability Technology Solutions with funding provided by the California Energy Commission, Public Interest Energy Research Program, through the University of California/California Institute of Energy Efficiency under Work for Others Contract No. 500-02-004, MR-041.

PREPARED FOR:

California Independent System Operator

PREPARED BY:

Electric Power Group
Manu Parashar, Ph.D. - Principal Investigator
Abhijeet Agarwal - Investigator

Pacific Northwest National Laboratory
Yuri Makarov, Ph.D. - Principal Consultant

University of Wisconsin, Madison
Ian Dobson, Ph.D. - Consultant

DATE:

Revised June 2008

Acknowledgements

Special thanks to California ISO staff Dr. Soumen Ghosh, Dr. Matthew Varghese, Mr. Dinesh Salem Natarajan, Mr. Patrick Truong, Mr. Steve Gillespie, Mr. Bill Ellard, Mr. Catalin Micsa, Mr. Paul Bleuss and Mr. David Le for their consultations to the project.

Mr. Dave Hawkins (California ISO) for his expertise, comprehensive support, and advices.

Dr. Yuri V. Makarov and Dr. Ning Zhou (PNNL), for their role in suggesting the framework of the project, developing and selecting the methodology, participation in the brainstorm meetings, organizing face-to-face interviews and other contacts with the leading experts, advices, troubleshooting, literature review, and report writing.

Prof. Ian Dobson, (University of Wisconsin-Madison), for his role in suggesting and developing the methodology, participation in the brainstorm meetings and interviews, expertise and essential advices.

Dr. S. L. Greene (Price Waterhouse Coopers) for his help with the PSERC software.

Mr. Jim Cole (California Institute for Energy Efficiency) for sponsorship and support of this project, and participants of the TAC meeting for their thoughtful suggestions.

Mr. Joseph Eto (Lawrence Berkeley National Lab) for his support.

Participants of the CERTS surveys for their expertise and advice:

Prof. M. Anantha Pai (University of California – Berkeley)
Mr. Raymond L. Vice (Southern Company Services, Inc.)
Dr. Savu Savulescu (Energy Concepts International Corp.)
Dr. Michael Y. Vaiman and Mrs. Marianna Vaiman (V&R Energy Systems Research)
Dr. Alex M. Kontorovich (Israel)
Dr. Anatoliy Meklin (Pacific Gas and Electric)
Prof. Marija D. Ilic (Carnegie Mellon University)
Prof. Enrico De Tuglie (Politecnico di Bari, Italy)
Prof. Gerald T. Heydt (Arizona State University)
Mr. William Mittelstadt (Bonneville Power Administration)
Prof. Yixin Yu (Tianjin University, China)
Mr. Carson W. Taylor (Bonneville Power Administration)
Prof. H.-D. Chiang (Cornell University)
Dr. Navin Bhatt (American Electric Power)

Participants of the face-to-face interviews for their evaluation of the project and advice:

Prof. Ian Dobson (University of Wisconsin – Madison)
Prof. Vijay Vittal (Arizona State University)
Prof. Venkataramana Ajarapu (Iowa State University)
Dr. Zhao Yang Dong (University of Queensland, Australia)
Dr. Anatoliy Meklin (Pacific Gas and Electric)
Dr. Vitaliy Faybisovich (South California Edison)
Dr. Michael Vaiman and Dr. Marianna Vaiman (V&R Energy Systems Research)

TABLE OF CONTENTS

1. INTRODUCTION AND BACKGROUND 1

2. EXISTING VSA METHODS 2

2.1. STRESSING ALGORITHMS IN A SPECIFIED LOADING DIRECTION 3

2.2. STRESSING ALGORITHMS IN THE MOST CRITICAL DIRECTION..... 5

2.3. APPROXIMATION TECHNIQUES FOR SECURITY REGIONS 6

2.4. OTHER TECHNIQUES..... 7

3. OVERVIEW OF EXISTING TOOLS..... 8

3.1. OFF REAL TIME TOOLS 8

3.2. REAL TIME TOOLS 8

3.3. SOME LIMITATIONS OF EXISTING TOOLS..... 9

4. SURVEY SUMMARY AND RECOMMENDATIONS..... 10

4.1. SURVEY OVERVIEW 10

4.2. SUMMARY OF RESPONSES 10

4.3. CONCLUSIONS 11

4.4. RECOMMENDATIONS 11

5. CERTS REAL-TIME VOLTAGE SECURITY ASSESSMENT ALGORITHMS..... 12

5.1. RTVSA (REAL-TIME VOLTAGE SECURITY ASSESSMENT) FRAMEWORK 14

5.2. ALGORITHMS OVERVIEW 16

5.3. CONTINUATION METHOD 19

5.3.1. *Predictor & Corrector Equations and Algorithms* 20

5.3.2. *Criteria to Determine Proximity to PoC*..... 21

5.4. DIRECT METHODS TO CALCULATE THE EXACT BIFURCATION POINT 22

5.5. HYPERPLANES AT THE POINT OF COLLAPSE 22

5.6. STABILITY BOUNDARY ORBITING PROCEDURE 25

5.6.1. *Finding the Left Eigenvector* 26

5.6.2. *Changing the stress direction* 26

5.6.3. *Predictor step of the orbiting direct method*..... 27

5.6.4. *Step Selection Procedure* 28

5.6.5. *Corrector step of the orbiting direct method* 29

5.6.6. *Calculating $\frac{\partial}{\partial x} [J^T(x)L]$* 29

5.7. “SLICED BREAD” APPROACH 31

5.7.1. *“Sliced Bread” Procedure in Descriptor Space*..... 31

5.7.2. *The Algorithm in the Descriptor Space* 32

5.8.1. *Procedure for Determining the Minimum Set of Hyperplanes* 33

5.9. DESCRIPTOR SPACE FORMULATION..... 35

5.10. SPECIAL FEATURES OF THE RTVSA APPLICATION..... 37

6. APPENDIX A: HESSIAN METRIX OF POWER FLOW EQUATION 39

7. REFERENCES..... 58

LIST OF FIGURES

Figure 1: Multi Year Development Roadmap for CA ISO Voltage Security Assessment (VSA) Project	13
Figure 2: Conceptual view of Voltage Security Region	15
Figure 3: RTVSA Algorithms Flowchart	18
Figure 4: Predictor and Corrector Steps	20
Figure 5: Left eigenvector of $J(x)$	22
Figure 6: Tangent and approximating hyperplanes	24
Figure 7: Transition from Parameter Continuation to Orbiting	25
Figure 8: "Sliced bread" algorithm for the closed boundary	31
Figure 9: "Slice bread" algorithm for the open boundary	32
Figure 10: Tangent and approximating hyperplanes	34

1. Introduction and Background

Over the past 40 years, more than 30 major blackouts worldwide were related to voltage instability and collapse. Among them, at least 13 voltage-related blackouts happened in the United States, including two major blackouts in the Western Interconnection in 1996 and a wide-scale blackout in the Eastern Interconnection in 2003. Several times, the blackout investigation teams indicated the need for on-line power flow and stability tools and indicators for voltage performance system-wide in a real-time. These recommendations are not yet completely met by the majority of US power system control centers. The gap between the core power system voltage and reliability assessment needs and the actual availability and use of the voltage security analysis tools was a motivation to come forward with this project. The project aims to develop state-of-the-art methodologies, prototypes and technical specifications for the Real-Time Voltage Security Assessment (RTVSA) tools. These specifications can be later used by selected Vendors to develop industrial-grade applications for California Independent System Operator (CA ISO), other California Control Area Operators, and utilities in California.

Currently CA ISO's real time operations do not have a real-time dispatcher's Voltage Security Assessment tool and corresponding wide-area visuals to effectively manage the voltage and VAR resources on the transmission system and to identify the following:

- Voltage security margin calculation
- Worst-case contingencies leading to voltage collapse
- Abnormal reductions of nodal voltages
- Contingency ranks according to a severity index for system problems
- System conditions with insufficient stability margin
- Weakest elements within the grid
- Controls to increase the available stability margin and avoid instability

The objectives of this report are to present a comprehensive survey of algorithms available worldwide for the purpose of performing voltage security assessment, make recommendations on the most appropriate techniques, and describe a framework along with the algorithms that have been included in the prototype RTVSA tool.

The California Energy Commission (CEC), with input from CA ISO, requested an initiative to explore better avenues to optimize utilization of the existing transmission. As the first step to achieve this objective, Consortium for Electric Reliability Technology Solutions (CERTS)/Electric Power Group (EPG) formulated a survey to reach out to experts in this field for comments, information, suggestions, and recommendations. The choice of the PSERC (Power Systems Engineering Research Center) engine as a basis for building the VSA prototype was motivated by the results of the survey (described in Section 4). The algorithmic details can be found in Section 5.

2. Existing VSA Methods

Voltage instability and voltage collapse are complicated phenomena that depend on the interactions of multiple system components and power flow parameters including generators, excitation control and over excitation protection, voltage regulators, reactive power sources, components of the transmission and distribution system, such as switching capacitors, under load tap changers, static VAR compensators reaching reactive power limits and loads, such as induction motors, thermostats, manual activities that respond to the decaying voltage and attempt to restore the load to its original demand in spite of decaying voltage and other static and dynamic load characteristics. It is necessary to distinguish large-disturbance voltage stability, vulnerability to cascading events, and small disturbance voltage stability.

- *Large-disturbance voltage stability* deals with the system ability to maintain voltages after such disturbances as generation trips, load loss, and system faults. It is analyzed by modeling long-term system dynamics. Large-disturbance voltage stability is analyzed by solving a set of nonlinear differential or algebraic equations (time domain simulations or numerical solution) [1], [33]. The system is considered voltage stable if its post-transient voltage magnitudes remain limited by certain pre-established reliability limits (5-10% depending on the severity of disturbance).
- *Cascading voltage collapse* can be caused by a sequence of power system changes, as for example, when groups of induction motors stall in succession or when a series of generator reactive power limits are reached in succession. For cascading events, the NERC (North America Electric Reliability Council) and WECC (Western Electricity Coordination Council) reliability criteria require the grid planners to evaluate their risk and consequences [27]. There are just a few techniques developed to assist in understanding or simulating cascading collapses - see [42] for example. The main approach seems to be working out the sequence of events of each individual cascading outage with assistance from simulations. The more advanced time domain simulations can reproduce cascading outages. [31]
- *Small-disturbance stability* is concerned with the ability of the system to control voltages following small perturbations or gradual change of parameters such as system load. This type of steady state stability is analyzed by linearizing nonlinear differential equations at a given operating point [1]. Because of the fact that linear differential equations can be solved analytically, there is no need to solve them numerically. There are many methods to check stability of the linearized system without solving it, that is, by analyzing the matrix of its coefficients J (small-signal stability matrix or system Jacobian matrix¹). The most commonly used approach here involves computing the so-called eigenanalysis of matrix J [1]. The system is asymptotically stable (has positive damping) if all eigenvalues have negative real parts (are located on the left hand side of the complex plane). It is unstable otherwise (has negative damping). Eigenvalues λ are solutions of the characteristic equation $\det(J - \lambda I) = 0$, where I is the identity matrix. Alternatively, the eigenvalue problem can be rewritten as follows: $(J - \lambda I)R = 0$ or $(J^t - \lambda I)L = 0$, where nonzero vectors R and L are *the right and left eigenvectors*, and t is the symbol of matrix transposition.

The WECC Voltage Stability criterion mandates P-V and V-Q studies as the main approaches to analyze voltage stability margins [24].

P-V plots represent the load vs. the voltage of a selected bus. The load is defined as the bus load or the total load in an area or the system. P-V curves are calculated using the power flow solutions by step-by-step increasing the loads. The “nose point” of the curve corresponds to the maximum power which can be delivered to the load. The bus voltage at this point is the critical voltage. If the voltage of one particular bus approaches the nose point faster compared to the other buses, it is assumed that the system voltage stability margin is limited by this bus.

V-Q plots represent the bus voltage vs. reactive power of the same bus. To obtain the curve, a particular bus is assumed to be a voltage controlled bus. A series of power flow simulations are performed for

¹ The Jacobian matrix of a set of n equations in n variables is an $n \times n$ matrix of partial derivatives whose entries are the derivatives of each equation with respect to each variable.

various values of the bus voltage and the corresponding needed reactive injection. The V-Q curves are obtained by plotting the reactive power injection versus the voltage.

V-Q sensitivity analysis is conducted by linearizing the power flow problem and assuming that the active power injections are constant. The linearized system is reduced by eliminating voltage angle increments, and the resulting expression links voltage increments with the reactive power increments. The diagonal elements of the inverse *reduced Jacobian matrix* are sensitivities of the nodal voltages with respect to reactive power injections at the same buses. Large sensitivity indicated reduced stability margin. Negative sensitivity indicates instability.

Q-V modal analysis is based on the analysis of eigenvalues of the reduced Jacobian matrix. The magnitude of the eigenvalues gives the relative measure of the proximity to instability. When the system reaches instability, the modal analysis is helpful in identifying the voltage instability areas and elements which participate in each instability mode (eigenvalue).

Bus participation factors determine the buses associated with each stability mode. The size of bus participation factor indicates the effectiveness of remedial actions in stabilizing the corresponding mode. *Branch participation factors* (calculated for each mode) indicate which branches consume the most reactive power in response to an incremental change in reactive load. Generator *participation factors* indicate which generators supply the most reactive power in response to an incremental change in reactive power loading.

There is a huge interest and variety of methods for the voltage stability/security analysis. Universities, R&D organizations, individual developers and some vendors propose dozens of different promising methods and their modifications. At the same time, the industry has accepted just a few of these approaches as standard methods (i.e., the most traditional approaches such as P-V and V-Q simulations, and transient stability time-domain simulations), leaving the rest of the variety as purely experimental or supplementary tools. The degree of interest to the new VSA tools in the industry vary from one place to another, in some instances it is minimal. This is an unfortunate fact having in mind the importance of the voltage stability/security problem, the existing danger of massive voltage collapses in the U.S. power grids, and the lack of applications such as real-time tools actually used by the industry. One of the objectives pursued by this report is to analyze existing methods, and suggest some of them as state-of-the-art real-time VSA technologies for implementing them at the California ISO, other control areas, and utilities.

The first paper related to voltage instability apparently appeared in 1968 [32], [40]. Since then, numerous approaches for voltage stability assessment have been suggested. In this section, we will outline the techniques using the static voltage stability models with the emphasis on the saddle node bifurcations.

2.1. Stressing Algorithms in a Specified Loading Direction

Step-by-step loading: Traditional power flow calculation methods, such as Newton-Raphson method, are not capable of determining the voltage stability boundary point directly and accurately. They diverge before the point of collapse is reached. The idea of the step-by-step loading is to exploit the quadratic convergence of the Newton-Raphson method in the vicinity of a solution. The procedure starts from a balanced power flow by incrementing the nodal power injections in a specified stress direction using some initial step size. If the Newton-Raphson method converges, the increment is repeated. In case of divergence, the step is divided by two, and by doing so, the next solution point is brought closer to the solution already found along the loading direction. The procedure stops when the step size becomes smaller than some specified accuracy. This method allows the use of detailed power system model including an accurate modeling of equipment limits (such as generator capability limits, switching capacitor limits, transformer tap changer limits, and others) and discrete controls (such as transformer and switching capacitor steps). Computational divergence is not the best criterion to determine the point of collapse since it can be caused by different reasons. [46-48][64].

Step-by-step loading with the analysis of a static small-signal stability criterion: In this method, instead or in addition to the power flow divergence criterion, the determinant (or an eigenvalue with the maximum

real part, or the maximum singular value [65], or the distance between closely located power flow solutions [66]) of the small signal stability matrix J is calculated at each loading step. The moment when the determinant of J changes its sign is considered as the saddle node bifurcation point. This approach also helps to determine the small-signal stability boundary points corresponding to the saddle node or Hopf bifurcations if these points are met before the power flow feasibility boundary is reached [46].

Permanent or continuous loading: This technique uses the Matveev's method for solving the power flow problem [49]. It has been shown that the Matveev's numerical method always converges to a solution or to a point where the power flow Jacobian matrix is singular. The permanent loading (or continuous loading) algorithm [50] exploits that characteristic of the method. In this approach, the loading parameter is set large enough to make sure that the power flow problem does not have a solution (the point is outside of the power flow feasibility boundary in the parameter space). Beginning from the operating point, Matveev's method starts to iterate producing the sequence of points. Approaching the boundary, the step size becomes smaller and smaller. Finally, when the step size becomes small enough and the process is stopped in the vicinity of the power flow feasibility boundary. Due to linearization, the final point is not exactly the point, where the stress vector intersects the power flow feasibility boundary. To eliminate this deviation, a modification of the permanent loading procedure is proposed [51], [52]. In this modification, the permanent loading steps play a role of a "predictor". If the iterative process deviates too much from the loading direction, a "corrector" step is performed. Alternatively the permanent loading process is continued to the point of singularity, and only then the "corrector" step is implemented. This approach is one of the most commonly recognized and frequently used techniques in the industry.

Parameter continuation predictor-corrector methods are the most reliable power flow methods capable of reaching the point of collapse on the power flow feasibility boundary. The addition of new variables, called continuation parameters, determines the position of an operating point along some power system stress direction in the parameter space. The *predictor step* consists of an incremental movement of the power flow point along the state space trajectory, based on the linearization of the model. The *corrector step*, which follows each predictor step, consists in the elimination of the linearization error by balancing the power flow equations to some close point on the nonlinear trajectory.

Direct methods for finding the PoC in a given direction combine a parametric description of the system stress, based on the specified loading vector in the parameter space and a scalar parameter describing a position of an operating point along the loading trajectory and the power flow singularity condition expressed with the help of the Jacobian matrix multiplied by a nonzero right or the left eigenvector that nullifies the Jacobian matrix at the collapse point. Unlike the power flow problem, this reformulated problem does not become singular at the point of collapse and can produce the bifurcation point very accurately. In principle, the direct method allows finding the bifurcation points without implementing a loading procedure. There is however, a problem of finding the initial guesses of the state variables and the eigenvector that may be resolved by initial loading the system along the stress direction. By doing so, the initial guess of state variables can be obtained. To evaluate the initial guess for the eigenvector, the *Lanczos* or *inverse iteration*² methods can be applied to calculate the eigenvector corresponding to the minimum real eigenvalue [58]-[63].

Optimization methods are based on maximization of a scalar parameter describing the position of an operating point along the loading trajectory subject to the power flow balance constraints. The maximum point achieved by the approach corresponds to the point of collapse met on the selected stress trajectory. The solution of this constrained optimization problem is determined by the *Karush-Khun-Tucker conditions*³ that produce a set of equations similar to the ones used in the direct method in its variant employing the left eigenvector; *Lagrangian multipliers*⁴ of this problem actually is the left eigenvector

² Recommended algorithms for computing eigenvector and eigenvectors of the Jacobian matrix. A description of the inverse iteration method is also given in Section 5.5. For more information and references see Eric W. Weisstein. "Lanczos Algorithm." From MathWorld--A Wolfram Web Resource <http://mathworld.wolfram.com/LanczosAlgorithm.html>

³ The *Karush-Khun-Tucker conditions* define properties of a constraint optimization problem solution that can be used to find the optimal point without performing an optimization procedure – see Eric W. Weisstein. "Kuhn-Tucker Theorem." From MathWorld--A Wolfram Web Resource. <http://mathworld.wolfram.com/Kuhn-TuckerTheorem.html>

⁴ *Lagrangian multipliers* are variables that help to present a constraint optimization problem an unconstrained optimization problem under certain conditions – see Eric W. Weisstein. "Lagrange Multiplier." From MathWorld--A Wolfram Web Resource. <http://mathworld.wolfram.com/LagrangeMultiplier.html>

nullifying the power flow Jacobian matrix at the point of collapse. The collapse point can be found directly by solving the set of equations, which is very similar to the direct method, or by applying an optimization method such as the *interior point method*⁵ or an alternative *AEMPFAS**t optimization*⁶ procedure that is proven to be able to get very close to the point of collapse of concern [56], [67], [68].

Approaches analyzed in this section assume that the system stress directions are known and reflect some typical load and generation patterns. In the market-driven systems, the generator dispatches are based on their energy bids and transmission congestion, and they may be very different from one dispatch interval to another. Therefore several system stress directions may need to be separately or jointly considered.

2.2. Stressing Algorithms in the Most Critical Direction

Methods for finding the PoC (Point-of-Collapse) in the most critical direction employ the same ideas as the direct methods. The difference is that the stress direction in the parameter space is not fixed, and an additional condition requiring that the system stress vector will be a perpendicular vector with respect to the power flow feasibility boundary at the point of collapse is applied. This direction is called the *critical direction* determining the *shortest distance to instability*. The critical direction coincides with the direction of the left eigenvector nullifying the power flow Jacobian at the closest point of collapse [59], [70]-[73], [1].

By applying this approach, one can evaluate the *worst case stress direction* and the corresponding *critical voltage stability margin* for a given operating point in the parameter space. This is, of course, very useful additional information for the VSA purposes. At the same time, there are some potential problems with this technique that need to be addressed in practical calculations:

- The critical loading direction might be unrealistic or unlikely.
- Due to the nonlinear shape of the power flow feasibility boundary, besides the critical directions, some *sub-critical system stresses* with a comparable voltage stability margin might be observed [74]. In this situation, the critical loading direction does not provide a sufficient characterization of the voltage stability margin.
- The sub-critical stress directions correspond to the local minima of the distance to instability metric. By applying the method, it is hard to tell whether the result corresponds to the global or local minimum, what the other directions are and how many of them exist.

Parameter continuation methods for exploring power flow feasibility boundary. The robust predictor-corrector procedure can be successfully applied to explore the entire structure of the power flow feasibility boundary. Points on the solution boundary are described in the same way it is done in the direct method: using the power flow equations together with an equation which forces the power flow Jacobian to be singular. Contours describing the boundary are obtained by freeing two parameters of the system and following these contours [83].

High-order methods to follow the power flow feasibility boundary. The Newton-Raphson method is based on linearization of the power flow equations at each iteration. The high order method is a generalization of the Newton-Raphson method involving nonlinear terms of the Taylor series expansion [84]. It can be also considered as a parameter continuation technique. The method provides reliable solution of nonlinear algebraic problems up to points of singularity; convergence to a singular point if it occurs on the way of the iterative process; almost straight line motion of the iterative process in the space of power flow mismatches; and retention of zero mismatches. Once an initial point on the power flow feasibility boundary is found, further exploring of the boundary can be done by changing the stress vector in the

⁵ The *interior point method* is a linear or nonlinear programming method that achieves optimization by going through the middle of the solid defined by the problem rather than around its surface - see Eric W. Weisstein, "Interior Point Method." From MathWorld-- A Wolfram Web Resource. <http://mathworld.wolfram.com/InteriorPointMethod.html>

⁶ The AEMPFASt algorithm is a trade secret of the Optimal Technologies, Inc. The AEMPFASt software was extensively tested and evaluated by the California ISO. More information on the AEMPFASt can be found in [69].

direction of interest and applying the direct method for exploring the boundary. Since the singularity equation $J \cdot R$ is equal to zero at the initial point, the high order method keeps it near zero during the iteration process; this means that the solution point is automatically kept on the power flow feasibility boundary [85]. The advantages of the analyzed techniques are that they do not require repeating the loading process and calculating multiple interior points of the voltage security region many times to reveal parts of the power flow feasibility boundary.

2.3. Approximation Techniques for Security Regions

Hyperplane and quadratic approximations of the security region: One of the important problems that power system analysts and operators face when they use the concept of the power system security region is the problem of description of the security region's boundary. The simple tabular description is not adequate to the purposes of visualization and practical use by system operators and in the automated VSA systems. There is a need of an *analytical description and/or approximation* of the boundary. The analytical description usually means the use of linear or nonlinear inequalities applied to a certain number of *critical parameters* such as power flows, load levels, voltage magnitudes, etc.; if all inequalities are satisfied, the analyzed operating point is considered to be inside the security region; if any of the inequalities is violated, the point is considered to be outside the security region. The approximation means a sort of *interpolation* between the boundary points obtained by any of the methods considered in this section. It can be used as a part of the analytical boundary description (for the automated VSA systems), or separately for the purposes of visualization. The simplest approximation uses *linear inequalities*. The first known use of the approximation ideas was apparently related to the *operating nomograms* – see [78] for more details. The operating nomograms are usually represented visually as piecewise linear contours on a plane of two critical parameters. If three critical parameters are involved, the nomogram is represented by a number of contour lines; each of them corresponds to a certain value of the third parameter. It becomes difficult to visualize a nomogram for four or more critical parameters. The natural extension of the linearized stability nomograms for three or more critical parameters is based on the use of *hyperplanes* - the planes that are defined in the multidimensional parameter space as approximations of the stability boundary. These efforts are described in [80] (voltage stability boundary approximation), [82], [87], [88] (transient/dynamic stability boundary approximation), and other works.

In Russia, in a number of emergency control algorithms, a nonlinear approximation was successfully used to provide an analytical description of the stability boundary [89]. These approaches employ *quadratic inequalities*. The inequalities are applied to the nodal power injections, cutset power flows, and other parameters. The coefficients of these inequalities are pre-calculated offline based on multiple time domain or steady-state stability simulations.

The hyperplane and quadratic approximations have a number of significant advantages:

- They allow to quickly analyze the stability margin in real time
- Due to their formal mathematical nature, they allow to simultaneously consider thermal, voltage stability, transient stability and other constraints within the same framework.

ANN-based techniques [20], [78], [87], [90]-[98]: The idea behind the techniques based on the artificial neural networks is to select a set of critical parameters such as power flows, loads, and generator limits, and then train an ANN on a set of simulation data to estimate the security margin. The ANN model de facto provides an approximation of the stability boundary. The advantages of the ANN models include their ability to accommodate nonlinearities and they are very fast while performing in real time. At the same time, there are difficulties associated with building the training datasets and ANN training.

Pattern recognition methods establish a relationship between some selected parameters and the location of the system operating point with respect to the stability boundary [14,15]. Initially, training sets of stable and unstable operating points are generated, and a space reduction process is applied to reduce the dimensionality of the system model. Then the classifier functions (decision rules) are determined using

the training set. This function is engaged in real time to determine the stability margin of a given contingency [20], [99], [100].

QuickStab algorithm is an alternative method to quickly and approximately evaluate the voltage stability margin in a given loading direction. The idea of this technology was originally developed by Paul Dimo. It includes the voltage stability practical criterion $dQ/dV < 0$ and Dimo's network nodal equivalents (so called Zero Power Balance Networks or REI⁷ equivalents). Dimo's finding is that under certain modeling assumptions the practical stability margin can be expressed as a straightforward formula applied to the nodal equivalents [101], [102].

2.4. Other Techniques

Delta-plane method [113] is a new robust method for finding the power system load flow feasibility boundary on the plane defined by any three vectors of dependent variables (nodal voltages), called the Delta-plane. The method exploits some quadratic and linear properties of the load flow equations (X-ray theorem, [114]) and the power flow Jacobian written in rectangular coordinates. An advantage of the method is that it does not require an iterative solution of nonlinear equations (except the eigenvalue problem). Besides benefits of direct calculation of the power flow feasibility boundary points and visualization, the method is a useful tool for topological studies of power system multi-solution structures and stability regions. A disadvantage is that although the method works accurately in the state space, a mapping of its results into the parameter space is not a straightforward and accurate operation.

Hypercomplex power flow extensions allow reformulating the power problem so that the Jacobian matrix of the reformulated problem becomes non-singular along the power flow feasibility boundary so that the boundary can be explored using conventional numerical methods. A technique developed in Russia⁸ uses a combination of the complex and complex conjugate power flow equations along with the assumption that the complex and complex conjugate values of nodal voltages are independent variables. A similar technique developed in Ukraine assumes that the active and reactive components of the nodal voltages are complex numbers.

There is a *progression from one-directional methods* estimating the voltage stability margin in a specified direction *to multi-directional methods* evaluating the distances to instability, and further from the multi-directional methods *to the methods exploring the entire voltage security region* in the parameter space. In the market-driven systems, where the generation dispatches vary, the interactions between the various stresses can be accounted for by sensitivity methods or multi-directional and voltage security region techniques. *The use of power flow existence criterion* bears a potential danger of overestimating the actual voltage security margin in situations where the saddle node bifurcation, Hopf bifurcation, or transient stability conditions are violated before the power flow equations become inconsistent. Due to this consideration, the state-of-the-art methodology should be based on more precise voltage stability criteria.

⁷ REI – Radial Equivalent Independent

⁸ By A. M. Kantorovich

3. Overview of Existing Tools

P-V and V-Q simulation capabilities are provided by almost all industrial-grade VSA tools including ABB-VSA, PSS/TPLAN (Siemens), VSAT (Powertech), VSTAB (EPRI) and other applications as described in this section. An overview of voltage security assessment is provided below.

3.1. Off Real Time Tools

ABB Voltage Security Assessment (ABB-VSA): This application computes the voltage collapse P-V curves and critical operating MW limit for increasing loading condition both for the real time network condition as well as for worse contingencies⁹. In addition to the prediction of this critical point, ABB-VSA determines the set of weakest load flow buses in the system that exhibit the worst voltage drops, thus contributing to voltage collapse.

PSS/E Version 30 (Siemens) includes an additional fully automated feature that allows user to determine real power transfer or load level limit using P-V analysis or determine reactive margin with V-Q analysis. For the automatic contingency analysis, the TPLAN non-divergent power flow is used. For the automatic P-V and V-Q analyses, the IPLAN language¹⁰ script is used. For the post-contingency P-V and V-Q analyses, the Inertia/Governor Load Flow algorithm is used. In this algorithm, the speed governor action is modeled, as well as all automatic actions controlling voltages and frequency in the zero to three minute time frame.

VSAT (Powertech Labs, Inc.): The Powertech voltage security software provides the following capabilities: contingency analysis based on voltage security margin; transfer limits calculation between a source and a sink and between any 3 sources/sinks, voltage level, reactive power, and thermal limits; P-V and V-Q analyses; modal analysis, and remedial actions. Powertech has also developed a near real time application of the DSA Tools described below.

VSTAB, Version 5.2 (EPRI): VSTAB uses power flow based steady-state techniques for stability analysis. VSTAB automates contingency analysis and conducts P-V and V-Q simulations. VSTAB also performs a modal analysis by calculating smallest eigenvalues.

NEPLAN – Voltage Stability (BCP Busarello+Cott+Partner Inc., Switzerland): NEPLAN software implements V-Q analysis, P-V analysis, V-Q sensitivity analysis and modal analysis functionalities. NEPLAN – Voltage Stability helps to identify weak buses, areas, and branches, voltage sensitivity and voltage stability indices. The tool also allows selecting measures to increase voltage stability margin.

WPSTAB (National Technical University of Athens, Greece) is designed for the purpose of a long-term voltage stability and contingency evaluation. WPSTAB uses the Quasi Steady State approach based upon the time-scale decomposition of power system dynamics and a simplified representation of short-term dynamics, when focusing on long term phenomena. This program is used for the in-depth voltage stability analysis in the European Union OMASES project.

3.2. Real Time Tools

ABB's PSGuard: PSGUARD is a phasor measurement based platform that extends the basic functionality of Wide Area Measurement Systems to include real-time voltage stability assessment capability across key transmission corridors solely based on local measurements. It does this by estimating the amount of

⁹ R. Masiello, "Utilities Must Leverage Existing Resources and Upgrade Technology to Avoid Future Blackouts", Electric Energy T&D Magazine, pp. 44-47. May/June 2004.

¹⁰ The IPLAN language is used to control the host PSS/E program.

additional active power that can be transported on a transmission line or corridor without jeopardizing voltage stability.

Online application of DSA Tools (Powertech Labs, Inc., Canada): It conducts near-real-time security assessment based on the state estimator output. The DSA package runs voltage, transient, and small-signal analyses. The tool identifies violations, transient voltage and frequency dips, critical contingencies, and required remedial actions. Simplified analytical techniques are not used. The Powertech software can be integrated with the Energy Management System (EMS).

EPRI CAR Project: The Community Activity Room (CAR) describes the static security region calculated using a full AC power flow model or a linearized DC power flow model. The CAR uses the MW power injections at each bus as the independent variables and expresses the line flows through these variables. This eliminates the intermediate step of computing bus voltages and angles as would normally be required to solve a load flow. With the direct equations relating line flows to bus injections, it is then possible to express the line flow inequality constraints as functions of bus injections. The Community Activity Room's boundary is defined to be the intersection of all sets of constraints for the normal system topology and for all single branch contingency conditions. The CAR boundaries can be described using either deterministic or probabilistic approaches. The Community Activity Room can be used for online monitoring.

QuickStab (Energy Consulting International, Inc.): QuickStab provides a quick evaluation of the maximum loadability for a user-specified security margin. It also helps to identify generators and inertias that may cause instability. QuickStab has been integrated with EMS/SCADA systems as a real time tool.

ASTRE (University of Liège): The ASTRE software solves the base case, stresses the system in a pre-contingency situation, to simulate energy transactions, and filters out harmless contingencies. Security limits are determined through binary search organized in different ways. Beside security limit calculation, analysis and diagnosis facilities are provided.

3.3. Some Limitations of Existing Tools

- Many existing tools use *the power flow existence criterion* to compute the boundary. This has the dangerous potential to overestimate the actual voltage security margin in situations where the saddle node bifurcation, Hopf bifurcation, or transient stability conditions are violated before the power flow equations become divergent.
- The limitations of P-V/Q-V plots that represent the load versus the voltage of a selected bus become apparent when voltage collapses are not concentrated in a few buses. Some voltage collapses are regional or involve the entire system. P-V curves are calculated using the power flow solutions by step-by-step increasing the loads. The "nose point" of the curve corresponds to the maximum power which can be delivered to the load. The bus voltage at this point is the critical voltage. If the voltage of one particular bus approaches the nose point faster compared to the other buses, it is assumed that the system voltage stability margin is limited by this bus. This information does not capture the extent to which all the variables participate in the voltage collapse.

4. Survey Summary and Recommendations

4.1. Survey Overview

CERTS/EPG formulated a survey to reach out to the experts in the field of voltage security for comments, information, suggestions, and recommendations related to the VSA project. The surveys were sent to fifty one experts in universities and in the power industry. Sixteen reviewers responded and their responses are summarized in Table 1. Eight of these respondents are from the power industry and eight are from academia. Four proposals for commercial software were received from Bigwood, V&R, NETSSS, and ECI.

Table 1: Analysis of Survey Trends

ISSUE	RESPONSES / COMMENTS	CONCLUSION
Voltage Security Assessment (VSA) (Hyperplanes for security regions)	<ul style="list-style-type: none"> - Online hyperplane possible - Not as unproven as interior point methods. - Ideally suited for phenomena that is local. 	Hyperplanes well suited for VSA
Methodology for computing hyperplanes	<ul style="list-style-type: none"> - Loading & Generation Direction needed. - Stress path until voltage collapses. - At collapse, determine local boundary. 	Use left eigenvector approach
Direct versus Time-domain methods	<ul style="list-style-type: none"> - Time domain iterative methods are proven and robust, capable of handling intermediate discrete actions/events. Example: Generator limits being reached - Direct methods rely on simplistic models 	Direct Method could be used for fine-tuning the security boundaries after an iterative set of continuation power flows
Weak elements identification	<ul style="list-style-type: none"> - Voltage collapses are concentrated in certain regions in the sense that the voltage falls more in those regions. There is no single element that collapses. That is, voltage collapses occurs system wide with varying participation from all the system buses. 	The participation is computed from the right eigenvector of the Jacobian evaluated at voltage collapse corresponding to the zero eigenvalue.

4.2. Summary of Responses

The consensus opinion was that the hyperplane approach to defining security regions was ideally suited for voltage instability assessment. Voltage instability is more of a local area/region phenomenon. Several participants in the survey felt that full blown time domain classifiers should augment the algorithms that utilize Direct Methods. An engineer from a utility in Northern California said that it was not clear how switching conditions could be revealed without “time domain” simulations. A utility from the South shared its experience that it was unable to develop suitable production metrics because of the integration of both continuous (load growth) and non–continuous (contingency) factors into a single metric. The computational methods to be used in VSA could be grouped into 2 broad classes – the Iterative Approach using Continuation Power Flows and the Direct Method. The Direct Method does not provide information on any discontinuous events when the stress parameter is increased. These discontinuous events occur when a thermal, voltage or reactive limit is reached.

4.3. Conclusions

The majority of responses favor the use of the hyperplane approach in determining Voltage Security Assessment. Also, the majority of respondents do not see hyperplanes suitable for determining Dynamic Voltage Assessment at this time. Small Signal Stability Analysis is considered to be a good first step for Wide Area Stability Monitoring and assessment using phasor measurements.

4.4. Recommendations

The primary recommendation for such a tool is to use the hyperplane approach in computing security regions for Voltage Security Assessment. Others are:

- The computational engine for CA ISO's VSA is recommended to be the Continuation Power Flow. This tool has been tested and proven by several researchers in commercial and non-commercial software.
- An alternate recommendation is a hybrid approach, where a Direct Method could be used for fine-tuning the security boundaries after an iterative set of continuation power flows.

5. CERTS Real-Time Voltage Security Assessment Algorithms

The overall proposed roadmap and framework for the project was based on the literature review and survey results, and formulated through discussions with CA ISO and with active participation of CERTS consultants Dr. Yuri Makarov and Prof. Ian Dobson over conference calls and meetings in Pasadena (August 25-26, 2005) and in Madison (September 9, 2005).




Figure 1: Multi Year Development Roadmap for CA ISO Voltage Security Assessment (VSA) Project

The roadmap consists of three task tracks focusing on different aspects of the project including data requirements, algorithms research, and prototype development & testing. The multiple phases are a systematic progression starting with initial research, algorithm development and proof-of-concept simulations, and data integration and project expansion. The project time span was two years (2005-2006) with the potential expansion for the future years. The overall framework and the algorithmic building blocks (such as the Continuation Powerflow, Hyperplane Approximations, Direct Methods, etc) and their technical details are described in the sections to follow.

5.1. RTVSA (Real-Time Voltage Security Assessment) Framework

Based on CA ISO's analysis, the most promising method for determining the available voltage stability margin in real time is based on piece-wise linear approximation of the voltage collapse boundary in coordinates of independent power system parameters. The approximating conditions are calculated off-line as a set of inequalities specific for each analyzed contingency:

$$\begin{cases} a_{11}P_1 + \dots + a_{1n}P_n + b_{11}Q_1 + \dots + b_{1n}Q_n \leq c_1 \\ a_{21}P_1 + \dots + a_{2n}P_n + b_{21}Q_1 + \dots + b_{2n}Q_n \leq c_2 \\ \dots \\ a_{m1}P_1 + \dots + a_{mn}P_n + b_{m1}Q_1 + \dots + b_{mn}Q_n \leq c_m \end{cases} \quad (1)$$

The number of constraints m and the number of parameters P and Q included in each constraint are expected to be limited. Each face of the region approximates a part of the nonlinear region's boundary. The advantages to the proposed approach are:

- Fast and Convenient assessment: Having constraints (1) pre-calculated offline for each analyzed contingency, it is very easy to quickly determine in real time:
 - Whether the operating point is inside or outside the security region (by making sure that all approximating inequalities are satisfied)
 - Which constraints are violated (by identifying violated inequalities), and
 - What the most limiting constraints are (by calculating the distance from the current operating point to the approximating planes – see below).




Figure 2: Conceptual view of Voltage Security Region

- Easy-to-Calculate Security Margin: The distance d from the current operating point A to the nearest constraint face B determines the MVA security margin¹¹:

$$d_i = \frac{a_{i1}P_1^0 + \dots + a_{in}P_n^0 + b_{i1}Q_1^0 + \dots + b_{in}Q_n^0 - c_i}{\sqrt{a_{i1}^2 + \dots + a_{in}^2 + b_{i1}^2 + \dots + b_{in}^2}}$$

Where the current operating point $A = [P_1^0, \dots, P_n^0, Q_1^0, \dots, Q_n^0]$

The percent margin for each constraint i can be obtained based on a pre-established minimum admissible “MVA distance to instability” d^* :

$$d_i^{\%} = \min \left\{ \begin{array}{l} \frac{d_i}{d^*} \times 100\% \\ 100\% \end{array} \right\}$$

The resulting stability margin corresponds to the minimum distance, i.e. the distance to the closest constraint face:

$$D = \min_{(i)} d_i^{\%}$$

- Online computation of Parameter Sensitivities: The *normalized coefficients* of the set of hyperplane equations denoted by (1) are sensitivities that can be interpreted in several ways. These coefficients can be calculated trivially by the following mathematical expressions:

¹¹ We assume that the region is convex.

$$\frac{\partial D}{\partial P_j^0} = \frac{a_{ij}}{\sqrt{a_{i1}^2 + \dots + a_{in}^2 + b_{i1}^2 + \dots + b_{in}^2}}$$

$$\frac{\partial D}{\partial Q_j^0} = \frac{b_{ij}}{\sqrt{a_{i1}^2 + \dots + a_{in}^2 + b_{i1}^2 + \dots + b_{in}^2}}, j = 1, \dots, n$$

where D is critical vector $\vec{D} = \vec{AB}$ - see Figure 2.

The different representations of these coefficients include:

- 1) The locations in the network where the most sensitive controls are needed
- 2) The left eigenvector nullifying the power flow Jacobian matrix at the point of collapse
- 3) This eigenvector has an identical representation to *Lagrangian multipliers*¹² at PoC

5.2. Algorithms Overview

The important concepts that are used in the algorithm are stress direction (procedure), descriptor variables, state space, and parameter space.

The *stress direction (procedure)* specifies how the system parameters change from their base case values as a function of a scalar amount of stress. For example, generation and load participation factors can define a stress direction and the amount of generation can give a scalar amount of stress and these together can specify the changes in the bus power injections that is, any system state along the stress direction can be associated with certain value of a stress parameter such as the percent of the total load increase in an area. Each specific direction and value of the stress parameter uniquely defines the system state. This implies certain fixed patterns for varying the system generation and loads (for example, load participation factors, sequence of generator dispatch, and others – detailed examples can be found in this report). Stress directions can include some local system stresses addressing a particular voltage stability problem area, and global stresses such as the total load growth and the corresponding generation redispatch in the system.

Descriptor variables reflect the most influential or understandable combinations of parameters (or derivative parameters) that influence the voltage stability margin. Examples are the total area load, power flows in certain system paths, total generation, and others (the system operating nomograms' coordinates are good examples of descriptor parameters). In the simplest case, descriptor parameters can include some primary system parameters such as nodal voltages and nodal power injections. Descriptor variables help to adequately address global and local voltage stability margins without involving thousands of primary parameters. Certain subsets of descriptor variables can correspond to some local voltage stability problem areas.

The *state space* includes all system nodal voltage magnitudes and voltage phase angles.

The (independent) *parameter space* includes all nodal power injections (for P-Q buses) and real power injections and voltage magnitudes (for P-V buses).

The voltage stability boundary can be comprehensively (and uniquely) described in the parameter space (and the state space), but in this case the description would involve thousands of variables. Descriptor

¹² This representation is well suited to imply a 'Locational price' for an ancillary service such as the distance to voltage collapse specified in terms of dollars. *Lagrangian multipliers* specify the sensitivity of the constraints so that a constrained optimization problem becomes an unconstrained optimization problem – see Eric W. Weisstein. "Lagrange Multiplier" from MathWorld - A Wolfram Web Resource. <http://mathworld.wolfram.com/LagrangeMultiplier.html>

parameters help to reduce the dimensionality of the problem by considering the most influential combinations of parameters (or derivative parameters).

The *descriptor parameter space* includes all descriptor parameters. Since the points in the descriptor parameter space can be mapped into the points of the parameter and state spaces in many different ways (because of the limited number of descriptor parameters space dimensions), certain fixed system stress procedures should be introduced to make this mapping adequate and unique.

The developed RTVSA algorithm operates in the parameter space or descriptor space as described in Section 5.9.

The developed RTVSA algorithms consist of the following steps (which has been illustrated in a flowchart under Figure 3):

1. **Initial system stressing procedure** for a given stress direction **to reach a vicinity of the Point of Collapse (PoC)** in this direction. This step is implemented using the Parameter Continuation Method described in Section 5.3. The Continuation Method is one of the most reliable power flow computation methods; it allows approaching the PoC and obtaining the initial estimates of system state variables needed for the subsequent steps. The selected form of the continuation methods includes predictor and corrector steps.
2. **The direct method** – see Section 5.4 – is used then **to refine the PoC location** along the initial stress direction (the continuation method would require multiple iterations to find the PoC with the required accuracy). At least one of the power flow Jacobian matrix eigenvalues must be very close to zero at the PoC.
3. **The inverse iteration method or Arnoldi algorithm** is applied **to find the left eigenvector corresponding to the zero eigenvalue at PoC** – see Section 5.5. The left eigenvectors are used to build the set of approximating hyperplanes.
4. **The stability orbiting procedure is then applied to trace the voltage stability boundary along a selected slice.** This procedure is a combination of a predictor-corrector method and the transposed direct method. Details are given in Section 5.6.
5. In case of divergence, the algorithm is repeated starting from Step 1 for a new stress direction predicted at the last iteration of the orbiting procedure. Divergence may be caused, for example, by singularities of the stability boundary shape along the slice.
6. For a given voltage stability problem area and the corresponding descriptor parameters, **the “sliced bread procedure” is applied to explore the voltage stability boundary and build the set of approximating hyperplanes** – see Section 5.7.
7. The approach to build the minimum set of hyperplanes based on the desired accuracy of the approximation is given in Section 5.8.
8. The algorithm described above is implemented in the descriptor space as described in Section 5.9.




Figure 3: RTVSA Algorithms Flowchart

The developed RTVSA algorithm performs voltage security assessment calculations under both offline and real-time modes.

The *offline calculations* produce an approximated voltage stability region (a 2-D, 3-D, or a higher dimensional nomogram) based on multi-directional stressing situation presenting the interaction and tradeoffs between different stressing directions. The pre-calculated voltage stability region is an inner intersection of stability regions for the set of user-specified contingencies. The offline calculations should be conducted periodically (ideally, several times a day) to update the approximated voltage security region and to reflect the most recent changes in the system.

The *real-time calculations* are conducted in real time (after each converged State Estimation cycle) to determine the current or future position of the system operating point against the walls of the approximated voltage stability region, and to calculate such essential security information as the available stability margin (distance to instability), the most limiting contingency, the most dangerous system stress directions, weak elements causing potential instability, and the recommended preventive and enhancement controls that help to increase the margin in an efficient way.

Note: The *offline calculations* can also be conducted in real time if a few stressing directions representative of the actual system loading, given by the real time dispatch schedule, planned outages, and load forecast, and/or predetermined stresses are to be considered separately. In such a scenario, the available security margins, distance to instability, the most limiting contingency, weak elements causing potential instability, and the recommended preventive and enhancement controls that help to increase the margin in an efficient way can be obtained in real-time using the algorithms proposed in this document.

5.3. Continuation Method

The CERTS-RTVSA (Real Time Voltage Security Assessment) algorithm is based on methods that were originally used in the NSF-PSERC algorithm found at <http://www.pserc.cornell.edu/tcc/>. The algorithm is a variation of the predictor-corrector type of the continuation power flow.

In the generic continuation power flow framework, $\Phi(z)$ is $\mathbf{n}+1$ dimensional and represents the power flow equations augmented by a parameter $\Delta\lambda$ that is free to change, Δx is the \mathbf{n} dimensional change in the state vector, $\Delta\lambda$ is $\mathbf{1}$ dimensional and Δz is $\mathbf{n}+1$ dimensional.

$$\Delta z = [\Delta x, \Delta\lambda]^T$$

$$\frac{\partial\Phi}{\partial x} \Delta x + \frac{\partial\Phi}{\partial\lambda} \Delta\lambda = 0$$

where $\frac{\partial\Phi}{\partial\lambda}$ represents the stress vector

In the nomenclature used here, the 'Parameters' are defined as injections such as real power P_i and reactive power Q_i inputs, and the 'States' are defined as voltage magnitudes V and angles δ (Note: The 'Descriptive' variables that classify the security regions could either be a linear combination of Parameters or States, or Cut Set Power Flows).

The system Φ above is under-determined and the Tangent Vector Δz is non-unique, unless one further constrains one of its elements. In the Ajarapu-Christy [55] algorithm, the variable that moves the fastest in the previous iteration is constrained. If $\Delta\lambda$ is always constrained, then the reduced Tangent Vector can be defined as

$$\frac{\Delta x}{\Delta \lambda} = -\frac{\partial \Phi^{-1}}{\partial x} \frac{\partial \Phi}{\partial \lambda}$$

Note that $\partial \Phi / \partial \lambda$ is the vector of “participation factors” of the set of buses forming the Sink. In other words, if the change in Net System Load represented by $\Delta \lambda$ moves by 1 MW, then $\partial \Phi / \partial \lambda$ denotes the distribution of the 1 MW across the buses constituting the Sink.

Additionally, the sinks and source have distinctly different roles in the computations used to apply stress. The sinks are considered parameters of the model while the sources are variables. Stress is applied by incrementing the stress sinks and then solving the power flow problem to determine the variables.

The proposed CERTS-RTVSA algorithm uses a variation of the above method which is described below.

5.3.1. Predictor & Corrector Equations and Algorithms

Predictor Equation:

$$\begin{cases} \frac{\partial \Phi}{\partial z} \Delta z = 0 \\ e_i^t \Delta z = 1 \end{cases} \Leftrightarrow \begin{bmatrix} \frac{\partial \Phi}{\partial z} \\ \text{-----} \\ e_i^t \end{bmatrix} \Delta z = \begin{bmatrix} 0 \\ \text{-----} \\ 1 \end{bmatrix}$$

where e_i^t is a zero string with only i^{th} element equal to 1.

Corrector Equation:

Use Newton Raphson to solve $\Phi(z) = 0$
 $\Delta z_i = 0$




Figure 4: Predictor and Corrector Steps

The main steps in the CERTS-RTVSA predictor algorithm are:

1. Solve the predictor equation and normalize the length of the composite predictor vector Δz by division by $\sqrt{\Delta z^t \Delta z}$

2. Select the step size length s based on the maximum values $\Delta\delta_{\max}$ and ΔV_{\max} and the current value of the step multiplier γ .

Select s so that $s \max \{ \Delta V \} = \gamma \Delta V_{\max}$, while $s \max \{ \Delta \delta \} \leq \gamma \Delta \delta_{\max}$,

or $s \max \{ \Delta \delta \} = \gamma \Delta \delta_{\max}$, while $s \max \{ \Delta V \} \leq \gamma \Delta V_{\max}$,

whatever is achieved first. Note that in both the **predictor**[†] and the **corrector**[‡] equation the i^{th} index corresponds to the state that first reaches the maximum.

3. Scale the predictor vector Δz by s so that $\Delta z^* = s \Delta z$
4. Use Δz^* for solving the corrector equation
5. If the power flow for the corrector equation **does not** converge
 - a. **Halve** the step multiplier γ
 - b. Do **not** update z
 - c. Go to Step 2
6. If power flow for the corrector equation **does** converge
 - a. **Halve** the step multiplier if (γ is **greater than** γ_{\min} & $\Delta\lambda$ changes sign). Go to Step 2
 - b. Update z and Go to Step 1
7. Criteria for stopping
 - a. Stop if γ is **less than** γ_{\min} in Step 5
 - b. Stop if $\Delta\lambda$ changes sign & γ is **less than** γ_{\min} in Step 6

The maximum value of the step size is a criterion for limiting the deviation in states between each iteration. It is specified separately in per unit (pu) voltage and electrical degrees, $\Delta\delta_{\max}$ and ΔV_{\max} and has been selected as 0.08 radians (5 deg) and 0.05 pu based on engineering experience and experiments. Additionally, the initial step multiplier γ will be halved in the algorithm depending on

1. Whether the power flow is non-convergent
2. Whether γ is greater than the specified minimum multiplier γ_{\min}

5.3.2. Criteria to Determine Proximity to PoC

1. Small Elements on the Diagonal of the Triangularized Power Flow Jacobian Matrix
2. Power Flow Jacobian Matrix Condition Number
3. Minimum Singular Value

Some of the disadvantages of the above criteria are that these do not capture the sudden changes of power flow equations due to discrete events such as capacitor switching or handling reactive power constraints on generators. It misses the PoC points where the power flow becomes inconsistent without a singularity of the power flow Jacobian matrix due to discrete events mentioned above. In addition (2) & (3) are also computationally expensive. Some of the problems outlined here that relate to difficulties in determining the exact PoC are alleviated by the Direct Method, described next.

5.4. Direct Methods to Calculate the Exact Bifurcation Point

The exact location of the PoC can be calculated by solving the following system:

$$\begin{cases} F(x) + \beta D = 0 \\ J(x)R = 0 \\ R^T R = 1 \end{cases}$$

where $J(x)$ is the power flow Jacobian matrix and R is the right eigenvector corresponding to the zero eigenvalue of $J(x)$. The loading direction D is exactly the same as the one used in the predictor-corrector procedure.

To solve the above set of equations, it is important to select good initial guesses for unknown parameters x , β , and R . For x and β , use the values produced by the predictor-corrector method nearby the PoC. For R , a good initial guess would be the normalized increment of state variables Δx nearby the bifurcation point. An example is the difference between two successive iterations close to PoC, as given below.

$$R_0 \approx \frac{x_i - x_{i-1}}{\|x_i - x_{i-1}\|}, \quad x_i \rightarrow \text{PoC}$$

This recommendation is based on the fact that the trajectory of the state variables tends to the right eigenvector R in a small neighborhood of the PoC.

5.5. Hyperplanes at the Point of Collapse

To determine the approximating hyperplane, the left eigenvector L is needed. This vector is an orthogonal vector with respect to the power flow feasibility boundary at the PoC in Figure 5. In order to calculate the left eigenvector, an inverse iteration technique is recommended¹³.




Figure 5: Left eigenvector of $J(x)$

¹³ The RTVSA code was implemented using Arnoldi algorithm

The algorithm behind the inverse iteration method is as follows. Consider the linear system:

$$\left[J'(x \rightarrow x_{PoC}) - \lambda_{i-1} \cdot E \right] \cdot \tilde{L}_i = L_{i-1}$$

where $J(x \rightarrow x_{PoC})$ is the power flow Jacobian matrix calculated near the PoC; λ_{i-1} is an estimate of an eigenvalue; E is the identity matrix, and L_{i-1} and \tilde{L}_i are successive estimates of the left eigenvalue. It is recommended to normalize vector \tilde{L}_i at each iteration as follows:

$$L_i = \frac{\tilde{L}_i}{\|\tilde{L}_i\|}$$

The eigenvalue estimate λ_i can be improved by applying the following correction:

$$\lambda_i = \lambda_{i-1} + \frac{1}{\tilde{L}_i \cdot L_{i-1}}$$

In the vicinity of the PoC, the initial guess of λ should be selected as zero, $\lambda_0 = 0$.

The inverse iteration method usually demonstrates quick convergence. The exception is the case with closely located eigenvalues. Bad selection of the left eigenvector may slow down the iteration process. The recommended initial choice is $L_0 = D$ (loading direction).

The tangent hyperplane $p = F(x)$ can be easily found by applying the following formula:

$$L' \cdot [p - PoC] = 0 \rightarrow p = F(x)$$

Note that:

- The approximating hyperplane is a tangent plane with respect to the load flow feasibility boundary if it is smooth at the PoC.
- If the load flow feasibility boundary is convex, the entire tangent hyperplane lies outside the boundary. This prevents the direct use of the tangent hyperplane as the approximating hyperplane because of the overestimation of the actual margin – see Figure 6. Instead, a more conservative approximation by secant hyperplanes is suggested.
- L is a perpendicular vector with respect to the hyperplane.
- The hyperplane is actually a $(n - 1)$ subspace of the n -dimensional space $F(x)$.

The following section describes the procedure to obtain an approximation of the power flow feasibility region by secant approximating hyperplane. It is assumed that the procedure is performed in the space of k parameters (nodal injections or descriptive parameters in the sequel) $p = \{p_1, p_2 \dots p_k\}$, and that the process is organized for a pair of parameters p_i and p_j that are varied while the rest are kept constant.




Figure 6: Tangent and approximating hyperplanes

Effectively, this means that the power flow feasibility boundary is cut by a plane, and that we consider one cut set (“slice”) at a time to build the entire approximation. The following in the hyperplane building procedure:

1. Suppose we determined the first point of collapse PoC_1 , the normalized left eigenvector L_1 , $\|L_1\| = 1$, and the corresponding tangent hyperplane $L_1^t \cdot (p - PoC_1) = 0$ - see Figure 6.
2. The approximating hyperplane is obtained by parallel shifting the tangent hyperplane along vector L_1 by the distance $(d + m)$, there d and m is the user specified distances. Distance d regulates the accuracy of approximation and the number of required hyperplanes, distance m introduces an additional security margin. The approximating hyperplane equation becomes

$$L_1^t \cdot (p - PoC_1) = d + m$$

3. Now we start moving along the intersection boundary and the cut set plane (p_i, p_j) . As it will be described below, this motion can be implemented as another type of the parameter continuation procedure, where the intermediate points of collapse are available.
4. For each intermediate PoC, we will check the distance r to the tangent hyperplane determined at PoC_1 . We are looking for a point PoC_2 where this distance is slightly less or equal to the user specified distance d :

$$r = \frac{\|L_1^t \cdot (PoC_2 - PoC_1)\|}{\|L_1^t\|} \leq d, \quad r \approx d$$

5. Continue moving in the same direction checking the distance r from the tangent hyperplane to the PoC_2 . We are looking for the PoC_3 where

$$r = \frac{\|L_3^t \cdot (PoC_3 - PoC_2)\|}{\|L_3^t\|} \leq d, \quad r \approx d$$

6. Calculate the new approximating hyperplane

$$L_3 \cdot (p - PoC_3) = d + m$$

7. Repeat the procedure by continuing the motion along the slice and measuring the distance of the hyperplane from the PoC₃, and so on.

5.6. Stability Boundary Orbiting Procedure

This section of the document describes a procedure to orbit the static voltage stability boundary. The procedure includes the following steps (illustrated in Figure 7 below):

- o Finding the left eigenvector L – this step is repeated one time for the first point found on the boundary that has been already found with the help of the parameter continuation method and the direct method.
- o Changing the stress direction to orbit the boundary.
- o Predictor step of the orbiting direct method.
- o Corrector step of the orbiting direct method.

The last three steps are repeated in the same sequence to follow the boundary.




Figure 7: Transition from Parameter Continuation to Orbiting
(π, σ – Predictor and Corrector Steps of the Continuation Method,
 π_D, σ_D – Predictor and Corrector Steps of the Orbiting Direct Method)

They are essential parts of the “sliced bread” procedure that has been described in Section 5.7, and have been used along with the hyperplane building and approximation procedure. This procedure does not account for sequential generator loading procedure (i.e. when the generators are loaded one by one following a certain sequence); however, it can be incorporated in the parameter space concept described in section 5.9 of this document.

5.6.1. Finding the Left Eigenvector

In order to calculate the left eigenvector, it is recommended to use the inverse iteration technique as described in section 5.5. The transposed direct method is suggested as an alternative approach.

Transposed Direct Method

The Transposed Direct Method can be applied as an alternative of the inverse iteration method. It consists of solving the system (1) using the Newton-Raphson method.

Transposed Direct Method Equations [2*nbus+1+nPV +2*nbus+1+nPV+1]:

$$F_{D-trans}(x_D) = \begin{cases} P(\theta, V) - P_D \beta_1 + T_D' \beta_2 = 0 & \text{- Active Power Balance [nbus]} \\ Q(\theta, V) + Q_{PV} + T_D'' \beta_2 = 0 & \text{- Reactive Power Balance [nbus]} \\ \Delta \theta_{RB} = 0 & \text{- Reference Bus Equation [1]} \\ \Delta V_{PV} = 0 & \text{- PV Bus Equations [nPV]} \\ J'(x)L = 0 & \text{- Singularity Condition [2*nbus+1+nPV]} \\ L'L = 1 & \text{- Nonzero condition For the Left Eigenvector [1]} \end{cases} \quad (1)$$

Transposed Direct Method Variables x_D [2*nbus+1+nPV +2*nbus+1+nPV+1]:

$$\begin{aligned} \theta & \quad \text{- Voltage Phase Angles [nbus]} \\ V & \quad \text{- Voltage Magnitudes [nbus]} \\ \beta_1 & \quad \text{- Source Factors (Distributed Slack Bus Factors) [1]} \\ Q_{PV} & \quad \text{- PV Bus Reactive Power Injections [nPV]} \\ \beta_2 & \quad \text{- Sink Factor (Stress Factor) [1]} \\ L & \quad \text{- Left Eigenvector [2*nbus+1+nPV]} \end{aligned} \quad (2)$$

Equation set (1) is very similar to the Direct Method equations set except that the last two equations in (1) are written for the left eigenvector L instead of the right eigenvector R .

The recommended initial choice of L is again $L_0 = \begin{bmatrix} T_D' \\ T_D'' \\ 0 \\ 0 \end{bmatrix}$ (stress direction).

5.6.2. Changing the stress direction

We will use equation

$$\Phi(z) = \begin{cases} F(x) + \gamma \cdot e_i + \eta \cdot e_j = 0 \\ J'(x) \cdot L = 0 \\ L' \cdot L = 1 \end{cases} \quad (3)$$

Where

$$F(x) = \begin{cases} P(\theta, V) - P_D \beta_1 + T_D' \beta_2 = 0 & \text{- Active Power Balance [nbus]} \\ Q(\theta, V) + Q_{PV} + T_D'' \beta_2 = 0 & \text{- Reactive Power Balance [nbus]} \\ \Delta \theta_{RB} = 0 & \text{- Reference Bus Equation [1]} \\ \Delta V_{PV} = 0 & \text{- PV Bus Equations [nPV]} \end{cases} \quad (4)$$

e_i and e_j are unit vectors spanning the “slice” plane (p_i, p_j) - see Figure 7, and $z = [x, L, \gamma, \eta]$.

In (4), parameter β_2 is fixed, and two additional unknown parameters γ and η are added. By varying γ and η , one can explore the entire plane (p_i, p_j) .

5.6.3. Predictor step of the orbiting direct method

Set (3) has one unknown more than the number of equations. It can be used to organize the prediction-correction process.

The predictor equation becomes:

$$\begin{bmatrix} J(x) & 0 & e_i & e_j \\ \frac{\partial}{\partial x}[J'(x)L] & J'(x) & 0 & 0 \\ 0 & L' & 0 & 0 \\ \text{-----} & \text{-----} & \text{-----} & \text{-----} \\ & E_r' & & \end{bmatrix} \cdot \begin{bmatrix} \Delta x \\ \Delta L \\ \Delta \gamma \\ \Delta \eta \end{bmatrix} = - \begin{bmatrix} F(x) + \gamma \cdot e_i + \eta \cdot e_j \\ J'(x)L \\ L'L - 1 \\ Step \end{bmatrix} \quad (5)$$

where E_r' is the extended unit vector, and $Step$ is the step size. Note that E_r' contains $2 \cdot n_{bus} + 1 + n_{PV} + 2 \cdot n_{bus} + 1 + n_{PV} + 2$ elements.

T_D', T_D'' – fixed and equal to the initial loading direction;

β_2 – fixed and equal to the value achieved by applying the direct method procedure;

x – variable, initially set equal to the values achieved by applying the direct method procedure;

L – variable, initially set equal to the vector obtained by the inverse iterations procedure or by the transposed direct method; and

γ, η – variables.

Equation (5) needs to be carried out only once for each predictor step.

5.6.4. Step Selection Procedure

To force the procedure around the boundary, one of the last two elements in E_r (corresponding to either e_i or e_j) must be fixed, and the remaining elements must be zeros.

Algorithm:

1. Find a unit vector that belongs to the “slice” (e_i, e_j) and is orthogonal to L . This can be done by solving the following system

$$\begin{aligned} L^t \cdot (\bar{\gamma} \cdot e_i + \bar{\eta} \cdot e_j) &= 0 \\ (\bar{\gamma})^2 + (\bar{\eta})^2 &= 1 \end{aligned} \tag{6a}$$

To solve (6a), let us express $\bar{\eta}$ from the first equation in (6a), $\bar{\eta} = -\bar{\gamma} \cdot \frac{L^t \cdot e_i}{L^t \cdot e_j}$, and substitute it

into the second equation, $(\bar{\gamma})^2 + (\bar{\gamma})^2 \left(\frac{L^t \cdot e_i}{L^t \cdot e_j} \right)^2 = 1$. Therefore, (6a) has the following solution:

$$\begin{aligned} \bar{\gamma} &= \sigma \cdot \sqrt{\frac{1}{1 + \left(\frac{L^t \cdot e_i}{L^t \cdot e_j} \right)^2}} \\ \bar{\eta} &= -\bar{\gamma} \cdot \frac{L^t \cdot e_i}{L^t \cdot e_j} \end{aligned} \tag{6b}$$

where $\sigma = \pm 1$. Unit vector $\mu = \bar{\gamma} \cdot e_i + \bar{\eta} \cdot e_j$ gives a locally optimal orbiting direction of the steady state stability boundary within the “slice” (e_i, e_j) .

2. At the initial orbiting point PoC_0 (Figure 7), assume $\sigma = +1$ and go to the next step. At the subsequent steps, do the following.
 - o Assume $\sigma = +1$.
 - o Find vector $\mu = \bar{\gamma} \cdot e_i + \bar{\eta} \cdot e_j$ for $\bar{\gamma}$ and $\bar{\eta}$ determined using (6b).
 - o Find vector $\xi = \Delta\gamma \cdot e_i + \Delta\eta \cdot e_j$ using $\Delta\gamma$ and $\Delta\eta$ determined at a previous predictor-corrector step.
 - o Check the cosine of the angle θ between vectors ξ and μ , $\cos \theta = \frac{\mu^t \cdot \xi}{\|\mu\| \cdot \|\xi\|}$.
 - o If $\cos \theta$ is negative, reverse signs of $\bar{\gamma}$ and $\bar{\eta}$ (i.e. assume that $\sigma = -1$).
3. Set the last two elements in E_r equal to $\bar{\gamma}$ and $\bar{\eta}$. Set initial guesses $\Delta\gamma = Step \cdot \bar{\gamma}$ and $\Delta\eta = Step \cdot \bar{\eta}$.

The idea behind this step is as follows. The last equation in (5) is $E_r(i) \cdot \Delta\gamma + E_r(j) \cdot \Delta\eta = Step$, where $E_r(i)$ and $E_r(j)$ are the last two elements in E_r . Since they are equal to $\bar{\gamma}$ and $\bar{\eta}$, we have $\bar{\gamma} \cdot \Delta\gamma + \bar{\eta} \cdot \Delta\eta = Step$. This condition will keep $\Delta\gamma$ and $\Delta\eta$ close to the locally optimal orbiting direction $\mu = \bar{\gamma} \cdot e_i + \bar{\eta} \cdot e_j$ as possible, and help to keep the step size closer to the one selected by the User ($Step$). Parameter $Step$ must be always positive.

5.6.5. Corrector step of the orbiting direct method

The correction equation looks exactly as (5) with $Step$ substituted by zero:

$$\begin{bmatrix} J(x) & 0 & e_i & e_j \\ \frac{\partial}{\partial x}[J'(x)L] & J'(x) & 0 & 0 \\ 0 & L' & 0 & 0 \\ \hline & & E_r' & \end{bmatrix} \cdot \begin{bmatrix} \Delta x \\ \Delta L \\ \Delta \gamma \\ \Delta \eta \end{bmatrix} = - \begin{bmatrix} F(x) + \gamma \cdot e_i + \eta \cdot e_j \\ J'(x)L \\ L'L - 1 \\ 0 \end{bmatrix} \quad (7)$$

Equation (7) needs to be repeated until a convergence solution is obtained for each corrector step.

Vector E_r should be the same as determined in the predictor step.

Note that after each predictor-corrector step, we get a point of the power flow feasibility boundary and the left eigenvector - that is all what is needed for the hyperplane approximation (section 5.5) and the “slice bread” procedure described in the next section.

The corrector step of the orbiting direct method may not converge for various reasons, for example, singularities of the stability boundary shape along the slice. In this case, the VSA algorithms are repeated starting from the Continuation Method (section 5.3) for a new stress direction predicted at the last iteration of the orbiting procedure.

5.6.6. Calculating $\frac{\partial}{\partial x}[J'(x)L]$

Calculating the matrix $\frac{\partial}{\partial x}[J'(x)L]$ can be done using the Hessian matrices (described in Appendix A) - second derivatives of the mismatch function $F(x)$. This is what is recommended for the vendor's implementation. To minimize the programming effort to build the prototype tool, approximate expressions can be applied as described below. However, they are more complicated and require more computational effort.

Function $F(x)$ can be represented as its Taylor series:

$$\begin{aligned}
 F(x + \mathcal{G}R) &= F(x) + \mathcal{G}J(x)R + \frac{1}{2}W_2(\mathcal{G}R, \mathcal{G}R) + \frac{1}{6}W_3(\mathcal{G}R, \mathcal{G}R, \mathcal{G}R) + \dots \\
 F(x - \mathcal{G}R) &= F(x) - \mathcal{G}J(x)R + \frac{1}{2}W_2(\mathcal{G}R, \mathcal{G}R) - \frac{1}{6}W_3(\mathcal{G}R, \mathcal{G}R, \mathcal{G}R) + \dots
 \end{aligned} \tag{8}$$

Where $W_2(\mathcal{G}R, \mathcal{G}R)$ and $W_3(\mathcal{G}R, \mathcal{G}R, \mathcal{G}R)$ are the second- and third-order terms of the expansion. It is obvious that $W_2(\mathcal{G}R, \mathcal{G}R) = W_2(-\mathcal{G}R, -\mathcal{G}R)$, $W_2(\mathcal{G}R, \mathcal{G}R) = \mathcal{G}^2W_2(R, R)$, $W_3(\mathcal{G}R, \mathcal{G}R, \mathcal{G}R) = -W_3(-\mathcal{G}R, -\mathcal{G}R, -\mathcal{G}R)$, and that $W_3(\mathcal{G}R, \mathcal{G}R, \mathcal{G}R) = \mathcal{G}^3W_3(R, R, R)$.

By subtracting equations in (8),

$$F(x + \mathcal{G}R) - F(x - \mathcal{G}R) = 2\mathcal{G}J(x)R + \frac{\mathcal{G}^3}{3}W_3(R, R, R) + \dots \tag{9}$$

and

$$J(x)R = \frac{1}{2\mathcal{G}}[F(x + \mathcal{G}R) - F(x - \mathcal{G}R)] - \frac{\mathcal{G}^2}{6}W_3(R, R, R) + \dots \tag{10}$$

Finally, by differentiating (10), one can get

$$\frac{\partial}{\partial x}[J(x)R] = \frac{1}{2\mathcal{G}}[J(x + \mathcal{G}R) - J(x - \mathcal{G}R)] + o^2(\mathcal{G}) \tag{11}$$

By substituting R by e_k , where e_k is a unit vector,

$$\frac{\partial}{\partial x}[J(x) \cdot e_k] = \frac{1}{2\mathcal{G}}[J(x + \mathcal{G}e_k) - J(x - \mathcal{G}e_k)], \mathcal{G}e_k \rightarrow 0 \tag{12}$$

Now,

$$\begin{aligned}
 &\frac{1}{2\mathcal{G}}L^t[J(x + \mathcal{G}e_k) - J(x - \mathcal{G}e_k)], \mathcal{G}e_k \rightarrow 0 \stackrel{(15)}{=} L^t \frac{\partial}{\partial x}\{J(x) \cdot e_k\} \\
 &= \frac{\partial}{\partial x}\{L^t \cdot J(x) \cdot e_k\} = \frac{\partial}{\partial x}\{[L^t \cdot J(x)] \cdot e_k\} \\
 &= \frac{\partial}{\partial x}\{e_k^t \cdot [L^t \cdot J(x)]\} = \frac{\partial}{\partial x}\{e_k^t \cdot [J^t(x) \cdot L]\} \\
 &= e_k^t \frac{\partial}{\partial x}[J^t(x) \cdot L]
 \end{aligned} \tag{13}$$

Row vector $e_k^t \frac{\partial}{\partial x}[J^t(x) \cdot L]$ is the k -th row of the matrix $\frac{\partial}{\partial x}[J^t(x) \cdot L]$. Therefore, to calculate

$\frac{\partial}{\partial x}[J^t(x) \cdot L]$, one need to apply (13) to get each its row k .

5.7. “Sliced Bread” Approach

The proposed “sliced bread” approach helps to explore the entire power flow feasibility boundary in the descriptor space and approximate it by a reasonable number of hyperplanes.

5.7.1. “Sliced Bread” Procedure in Descriptor Space

The “slice” is a cut set of the boundary obtained by varying a pair of descriptor parameters d_i and d_j while the rest of the parameters remain constant. The released parameters form a cut set plane. These parameters may be limited by some limits:

$$\begin{aligned} d_i^{\min} &\leq d_i \leq d_i^{\max} \\ d_j^{\min} &\leq d_j \leq d_j^{\max} \end{aligned} \quad (1)$$

Also, within the slice, the power flow feasibility boundary could be closed (Figure 8) or open (Figure 9). Each slice is traced and approximated using the algorithm described above. The possible criteria to stop tracing the slice is are as follow:

- Acceptable distance D between the last approximating hyperplane and the first PoC in the “slice”; for instance, in Figure 8, this condition is




Figure 8: "Sliced bread" algorithm for the closed boundary

A – First “slice” is finished due to the “round trip” condition

A-B – Transition from the first to the second “slice”

C – Second “slice” is finished due to acceptable distance between the tangent hyperplane calculated at C and PoC₆

D – No more slices because p_k reaches p_{kmin}

$$r = \frac{\|L_5^t \cdot (PoC_5 - PoC_1)\|}{\|L_5\|} \leq D, \quad r \approx D$$

where L is the left eigenvector, and/or

- The “round trip” condition based on the analysis of the projections of the left eigenvectors L on the cut set plane. These projections form certain angles with the coordinate axes, for instance, with p_i :

$$\varphi_i = \arccos\left(\frac{L \cdot e_i}{\|L\|}\right) \quad (2)$$

E.g., for Figure 8, this angle changes from its initial value about -90° to its next value -50° , then to $+40^\circ$, and so on. When this angle makes a full circle so that it passes again -90° , this can be used as a criterion to stop tracing this particular slice.

- Cases when one of the descriptor parameters reaches its maximum or minimum value (points A and B in Figure 9).

The first slice can be selected at the maximum value of the fixed parameters, for instance, for $d_k = d_{k \max}$ in Figure 8 and Figure 9. When the “slice” is finished, the procedure goes to the next slide. For this purpose, one of the fixed parameters is temporarily released (e.g., d_k in Figure 8 and Figure 9), while one of the free parameters is temporarily fixed (e.g., d_j). The transition is implemented with the help of the same procedure that was used to approximate the “slice”. The transition process ends when all fixed parameters reach their minimum values.




Figure 9: "Slice bread" algorithm for the open boundary

- A – First “slice” is finished because $d_j = d_{j \max}$**
- B – Second “slice” is finished because $d_j = d_{j \min}$**
- C – Procedure stops because $d_k = d_{k \min}$**

5.7.2. The Algorithm in the Descriptor Space

1. Calculate the base case point in X , P and D , that is x_0 , p_0 and d_0 .
2. Specify an initial stress direction in D , Δd_0 using inverse mapping $\Delta p_0 = Tdir = Vector^{-1}(\Delta d_0)$.
3. Specify the first slice (d_i, d_j) in D .
4. Map the slice into P , $(p_i, p_j) = (e_i, e_j) = Plane^{-1}(d_i, d_j)$

5. Perform the parameter continuation method and direct method to determine PoC_0 in X and P . Find the left eigenvector L_0 and hyperplane H_0 .
6. Map PoC_0 , L_0 and H_0 back into D : $PoC_{0D} = Point(PoC_{0P})$, $L_{0D} = Vector(L_{0P})$, and $H_{0D} = Plane(H_{0P})$.
7. Initiate the Boundary Orbiting Procedure step along the slice (e_i, e_j) in P .
8. If the BOM step diverges, repeat the parameter continuation method and direct method to determine PoC_1 in X and P . Find the left eigenvector L_1 and hyperplane H_1 . Go to 10.
9. Otherwise, determine PoC_1 in X and P as a result of the BOM step. Find the left eigenvector L_1 and hyperplane H_1 .
10. Map PoC_1 , L_1 and H_1 back into D , $PoC_{1D} = Point(PoC_{1P})$, $L_{1D} = Vector(L_{1P})$, and $H_{1D} = Plane(H_{1P})$.
11. Check the slice stop tracing criteria as described in Section 5.7.1. Go to the next slice in D and start from Step 1.
12. Otherwise map the (d_i, d_j) into P again at the new point, $(p_i, p_j) = (e_i, e_j) = Plane^{-1}(d_i, d_j)$.

5.8. Minimum Set of Hyperplanes

The objective of obtaining the minimum set of hyperplanes is to test the performance and accuracy of the proposed VSA technology, which includes the following steps:

- Selection of critical loading directions for a selected problem area
- Performance of the predictor-corrector loading procedure
- Calculation of the points of collapse and tangent hyperplanes
- Calculation of the approximating hyperplanes (secant hyperplanes)
- Evaluate the accuracy of approximation using the proposed approach and accuracy metric
- Decide on whether the proposed selection of loading directions is adequate to the study areas

5.8.1. Procedure for Determining the Minimum Set of Hyperplanes

The following steps describe the procedure to determine the minimum set of hyperplanes:

1. Perform the predictor-corrector procedure for each selected loading direction – Sections 5.3.
2. Determine the Points of Collapse (PoC) - Section 5.4.
3. Apply inverse iterations method to calculate the left eigenvector L at the PoC – Section 5.5.
4. Calculate the tangent and secant hyperplanes – Section 5.5. To determine the required margin $(d+m)$, use 5, 10, 15, and 20% ($j=1, 2, \dots, 4$) (configurable) of the maximum loading in the most limited direction. As a result, get four sets of secant hyperplanes for each direction, corresponding to the different margin $(d+m)$ – Figure 10 (taken from section 5.5).

The tangent hyperplane equation is:

$$L_i^t \cdot (p - PoC_i) = 0$$

The secant approximating hyperplane equation is:

$$L_i^s \cdot (p - PoC_i) = (d + m)_j$$




Figure 10: Tangent and approximating hyperplanes

5. Select 10-20 additional loading directions for each area and perform the step-by-step loading procedure for the original and additional loading vectors. Evaluate the PoC_k for each direction k assuming that this is the point of divergence.
6. For each evaluated PoC_k , calculate the distance to each of the approximating hyperplanes at different margins $(d+m)_j$ using the following formula:

$$r_{ijk} = \frac{\|L_i^t \cdot (PoC_k - PoC_i)\|}{\|L_i\|} - (d + m)_j$$

7. Summarize these experimental results for each area in the following table:

Hyperplane		Loading Vector 1	Loading Vector 2	...	Loading Vector k
1	5%				
	10%				
	15%				
	20%				
2	5%				
	10%				
	15%				
	20%				
...	5%				
	10%				
	15%				
	20%				
i	5%				
	10%				
	15%				
	20%				

Distances from PoC to Hyperplanes

8. Analyze the angles between the loading vectors D_k and the left eigenvectors L_k . These angles can be calculated as follows:

$$\theta_{ik} = \arccos \frac{L_i^t \cdot D_k}{\|L_i\| \cdot \|D_k\|}$$

Mark all cells in the table corresponding to the case when $|\theta_{ik}| > 60^\circ$ (configurable). Those are the cases when hyperplane i forms a sharp angle with the loading direction k , and the distance metric r_{ijk} could be misleading. If the marked cells fill an entire column, the corresponding loading direction should be added to the original list of loading directions for which approximating hyperplanes are calculated (the entire procedure should be repeated for the added hyperplane).

9. Analyze the columns for the loading vectors D_1, \dots, D_k . Start with the $j=5\%$ cells initially. Check whether at least one distance in the column k stays within the 5% distance to the 5% approximating hyperplane. If yes, do nothing. If none of the distances are in the 5% range, check whether D_k is a direction for which an approximating hyperplane is built. If it is not, add a new approximating hyperplane to the list, but allow only 5% margin (don't calculate hyperplanes for any margins other than 5% for the newly added direction). If the analyzed direction is already the one that has an associated hyperplane, this means that the 5% accuracy is not achievable for that direction. This means that verification is not possible for that accuracy.
10. Repeat step 9 for all other margins. If finally for each loading direction we have at least one distance within 5, 10, 15 ...%, our verification is successful for the corresponding accuracy.

5.9. Descriptor Space Formulation

In this section, the formulation for descriptor variables has been discussed and the formulas for normal vector to nomogram boundaries have been derived.

Parameter space

The parameter space contains the generator and load power injections and is sometimes augmented with other states or parameters. There is a hypersurface in the parameter space corresponding to voltage collapse. Our software starts from base case parameters P_0 and given a pattern of stress and computes points on the hypersurface, the corresponding margin to voltage collapse and the normal vector to the hypersurface. It can also compute curves on the hypersurface.

One-dimensional margin to voltage collapse

We specify the pattern, or participation of all injections in a column vector k . Then the changes in injections are $m \times k$ where m is a scalar parameterization of the system stress. If the base case parameters are P_0 , then the stressed system parameters parameterized by m is the column vector

$$P = P_0 + m \times k$$

It can be useful to normalize k so that m is expressed in some convenient way and in convenient units. For example, if the parts of k corresponding to generator injections are normalized to have L1 norm, then m measures the generation margin in L1; that is, the sum of the generation increases.

A bulk change descriptor variable μ is a quantity such as an area load increase or an import across a cutset. μ is (for a given network structure) an affine function of the parameters P so that

$$\mu = h \times P = h \times (P_0 + m \times k)$$

where h is a row vector. Note that the matrix multiplication $h \times (P_0 + m \times k)$ is the same as the dot product between h^t and $(P_0 + m \times k)$. (This formula assumes that the base case $\mu = h \times P_0$, but this can be easily generalized as needed by adding a suitable constant). h is a fixed row vector that can be computed from the network equations. For example, h for a cutset flow μ is computed by summing line flows for lines in the cutset as a function of injections. The scaling of h is chosen so that μ is in

convenient units such as MW of import through the cutset or MW of load. At the voltage collapse, we get:

$$\mu^* = h (P_0 + m^* \times k)$$

If we now assume a fixed stress direction or injection participation k , then m is also a function of μ :

$$m = \frac{\mu - h \times P_0}{h \times k}$$

Specifying μ and k now defines the system stress m and k . That is, the system stress can be specified by the amount of a bulk change of injections μ and also assuming the pattern, or participation of all injections in the column vector k .

In summary, we can formulate the one-dimensional margin to voltage collapse as follows: We make the assumption of the participation factors k . Then we can specify an amount of stress by descriptor μ and the margin to voltage collapse can be specified by the descriptor margin $\mu^* = h (P_0 + m^* \times k)$.

Two-dimensional voltage collapse nomogram

Here we define two bulk change descriptor variables μ and η so the descriptor variables are the column vector $d = (\mu, \eta)^T$ (superscript T indicates matrix transpose)¹⁴. Now h is a vector function given by the $2 \times$ (number of parameters) matrix $h = (h_1^T, h_2^T)^T$ so that

$$d = (\mu, \eta)^T = h \times P = h (P_0 + m \times k)$$

The nomogram curve is given by $(\mu^*, \eta^*)^T = h (P_0 + m^* \times k)$ as k varies (note that m^* is a function of k). We assume that the nomogram curve is given (locally) by:

$$g(d) = g((\mu, \eta)^T) = 0$$

If we now assume two fixed stress directions or injection participations k_1 and k_2 , so that

$$P = P_0 + m_1 \times k_1 + m_2 \times k_2,$$

then

$$\begin{aligned} d = (\mu, \eta)^T &= h (P_0 + m_1 \times k_1 + m_2 \times k_2) \\ &= d_0 + M (m_1, m_2)^T \end{aligned}$$

where M is the 2×2 matrix

$$M = [h \times k_1, h \times k_2]$$

Then $(m_1, m_2)^T$ and P are also affine functions of $(\mu, \eta)^T$:

$$\begin{aligned} (m_1, m_2)^T &= M^{-1} ((\mu, \eta)^T - h \times P_0) \\ P &= P_0 + (k_1, k_2) \times (m_1, m_2)^T \\ &= P_0 + (k_1, k_2) \times M^{-1} \times (d - d_0) \end{aligned}$$

Specifying $(\mu, \eta)^T$ and k_1 and k_2 now defines the system stress in terms of injections P . That is, the system stress can be specified by the amount of a bulk change of injections $(\mu, \eta)^T$ and also assuming the patterns, or participations of all injections in the column vectors k_1 and k_2 .

¹⁴ For example, for the San Diego region, we could have $(\mu, \eta)^T = (\text{path 45/CFE import, SDG\&E import})^T$ or $(\mu, \eta)^T = (\text{SDG\&E generation, SDG\&E load})^T$

In summary, we can formulate a two-dimensional margin to voltage collapse as follows: We make the assumption of the participation factor vectors k_1 and k_2 . Then we can specify an amount of stress by descriptor vector $d = (\mu, \eta)^T$. The voltage collapse boundary can be specified by the curve $g(d) = 0$ in the nomogram. It is important to note the dependence of the nomogram curve on the choice of k_1 and k_2 .

Relation between parameter space and nomogram normals

The descriptor parameters d considered here are affine functions of the parameter space parameters P given by

$$d = d_0 + h \times P$$

where h is a matrix.

As explained above, the nomogram curve is given by an equation

$$g(d) = 0$$

The nomogram curve has normal vector given by the row vector D_g . D_g has two components. The nomogram curve immediately induces a corresponding hypersurface in the parameter space defined by the equation

$$g(d_0 + h \times P) = 0$$

Differentiating $g(d_0 + h \times P)$ with respect to P gives the normal vector to the parameter space hypersurface

$$\text{hyperspace normal} = D_g \times h$$

This formula expresses the parameter space normal in terms of the nomogram curve normal and the transformation matrix h .

Now we express the nomogram curve normal in terms of the parameter space normal. Assume as above a choice of k_1 and k_2 so that

$$P = P_0 + (k_1, k_2) \times M^{-1} \times (d - d_0)$$

Let the parameter space hypersurface be given by an equation

$$f(P) = 0$$

The hypersurface has normal vector given by the row vector D_f . Then the nomogram curve is given by

$$f(P_0 + (k_1, k_2) \times M^{-1} \times (d - d_0)) = 0$$

Differentiating the left hand side with respect to d gives the normal vector to the nomogram curve

$$\text{nomogram normal} = D_f \times (k_1, k_2) \times M^{-1}$$

This formula expresses the nomogram normal in terms of the parameter space normal and a linear transformation.

5.10. Special Features of the RTVSA Application

The RTVSA application is based on an extensive analysis of the existing VSA approaches, by surveying the leading power system experts' opinion worldwide, and also with feedback from industrial advisors. The mismatch between the core power system reliability needs and the availability of the VSA tools was a motivation to design the following special features into the RTVSA application.

- The underlying concepts are applicable to the simple one-dimensional approach or the more complex multi-directional stressing to explore the entire voltage security region in the parameter space or in full P-Q injection space.

- The RTVSA tool has the ability of analyzing the effects of multiple transfers. There are no restrictions in distributing the source and sink over a large number of buses in geographically distant locations in the system. A non-local treatment of congestion¹⁵ is crucial because conservatism causes costly curtailment of profitable power transfers and a suboptimal use of the transmission system.
- The RTVSA algorithm¹⁶ in Phase 2 uses the parameter continuation method, which is one of the most reliable power flow methods capable of reaching the point of collapse on the power flow feasibility boundary. New variables called the continuation parameters are added and represents a position of a power flow operating point along some power system stress direction in the parameter space. The *predictor step* consists in an incremental moving of the power flow operating point along the state space trajectory, based on the linearization of the problem. The *corrector step*, that follows each predictor step, consists in elimination of the linearization error by balancing the power flow equations to some close point on the nonlinear trajectory.
- The RTVSA algorithm in Phase 3 use Direct methods for finding the PoC, which combines the parametric description of the system stress and the power flow singularity condition expressed with the help of the Jacobian matrix multiplied by a nonzero right or the left eigenvector that nullifies the Jacobian matrix at the collapse point. In principle, the Direct Method avoids implementing a loading procedure. There may be problems of finding the initial guesses of the state variables and the eigenvector that may be resolved by initial loading the system along the stress direction. By doing so, the initial guess of variables can be obtained. Many inaccuracies of the step-by-step loading methods that do not exactly converge to the PoC will be avoided by implementing the Direct Method. There are savings in computational expenses because of the absence of iterations even though the Direct Method solves a problem almost double in dimension to the step-by-step loading methods.
- The RTVSA algorithm determines the “right eigenvector” and the “left eigenvector” at the PoC. The weak elements are based on the right eigenvector and provide the extent to which variables participate in voltage collapse. This determines weak areas and also whether the collapse is an angle collapse. Large sensitivities of the margin to PoC indicate controllable parameters. These are represented by the left eigenvector and can be quantified for suitable corrective action by ranking the increase in margin with respect to a unit MW or MVAR in generator response.
- Sensitivity computations relate changes in data to changes in transfer capability. The uncertainty in the transfer capability due to uncertainty in the data was quantified in Phase 4 of the RTVSA algorithm. These computations revealed which data is significant in the transfer calculations.

¹⁵ Congestion can be quantified more precisely as the combined effect of multiple power transfers exceeding the transfer capability of the transmission system.

¹⁶ The RTVSA algorithm falls into the class of non-divergent power flow methods that manipulate the step size of the Newton-Raphson method. If the power flow mismatches indicate divergence, the step size is reduced until convergence occurs or the step becomes very small. A very small step size is considered to be an indicator of the point of collapse.

6. Appendix A: Hessian Matrix of Power Flow Equation

Ning Zhou, PNNL, Richland, WA 99352
10/06/2006~10/16/2006

I. SCALAR VERSION OF SECOND DERIVATIVES OF POWER INJECTIONS	39
II VECTORIZED JACOBIAN	43
III VECTORIZED HESSIAN.....	44
IV. DERIVATIVE OF TRANSPOSED JACOBIAN MULTIPLIED BY LEFT EIGENVECTOR.....	49
V. NOTATION AND MATRIX IDENTITY:.....	56
REFERENCE.....	57

This document describes procedures of calculating the Hessian Matrix of Power flow equations. It also discusses the vectorization procedure, which may improve the implement efficiency using Matlab. The calculation procedure of the $\frac{\partial}{\partial x} [J^t(x) \cdot L]$ is also derived.

I. Scalar Version of Second Derivatives of Power Injections

This section gives the identities for calculating the elements of Jacobian and Hessian matrix of power injection. Note that all the elements are in the scalar format. Thus, it may not be efficient to implement the algorithm using Matlab.

Note:

- Matlab is not very efficient to implement 'for' loop.
- The notation used is similar to the notation used in [1].
- The power injection and first derivative equations are extracted from [1].

- Real Power Injection**

$$P_i = V_i \sum_{j=1}^{nbus} V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

First derivative w.r.t θ_i . (with fixed i)

$$\frac{\partial P_i}{\partial \theta_i} = -V_i \sum_{j=1}^{nbus} V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij}) - V_i^2 B_{ii}$$

- Second derivative wrt θ_i**

$$\frac{\partial^2 P_i}{\partial \theta_i \partial \theta_i} = -V_i \sum_{j=1}^{nbus} V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij}) + V_i^2 G_{ii}$$

- Second derivative wrt θ_j (for $j > i$)**

$$\frac{\partial^2 P_i}{\partial \theta_i \partial \theta_j} = V_i V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- Second derivative wrt V_i**

$$\frac{\partial^2 P_i}{\partial \theta_i \partial V_i} = - \sum_{j=1}^{nbus} V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij}) - V_i B_{ii}$$

- **Second derivative wrt V_j (for $j <> i$)**

$$\frac{\partial P_i^2}{\partial \theta_i \partial V_j} = -V_i (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

First derivative w.r.t θ_j (for $j <> i$, with fixed i and j .)

$$\frac{\partial P_i}{\partial \theta_j} = V_i V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt θ_i**

$$\frac{\partial P_i^2}{\partial \theta_j \partial \theta_i} = V_i V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- **Second derivative wrt θ_j**

$$\frac{\partial P_i^2}{\partial \theta_j \partial \theta_j} = -V_i V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- **Second derivative wrt θ_k (for $k <> i$, $k <> j$)**

$$\frac{\partial P_i^2}{\partial \theta_j \partial \theta_k} = 0$$

- **Second derivative wrt V_i**

$$\frac{\partial P_i^2}{\partial \theta_j \partial V_i} = V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt V_j**

$$\frac{\partial P_i^2}{\partial \theta_j \partial V_j} = V_i (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt V_k (for $k <> i$, $k <> j$)**

$$\frac{\partial P_i^2}{\partial \theta_j \partial V_k} = 0$$

First derivative w.r.t V_i . (with fixed i)

$$\frac{\partial P_i}{\partial V_i} = \sum_{j=1}^{nbus} V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij}) + V_i G_{ii}$$

- **Second derivative wrt θ_i**

$$\frac{\partial P_i^2}{\partial V_i \partial \theta_i} = -\sum_{j=1}^{nbus} V_j \cdot (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij}) - V_i B_{ii}$$

- **Second derivative wrt θ_j (for $j <> i$)**

$$\frac{\partial P_i^2}{\partial V_i \partial \theta_j} = V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt V_i**

$$\frac{\partial P_i^2}{\partial V_i \partial V_i} = 2G_{ii}$$

- **Second derivative wrt V_j (for $j <> i$)**

$$\frac{\partial P_i^2}{\partial V_i \partial V_j} = G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij}$$

First derivative w.r.t V_j . (with fixed i and j , for $j <> i$)

$$\frac{\partial P_i}{\partial V_j} = V_i \cdot (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- **Second derivative wrt θ_i**

$$\frac{\partial P_i^2}{\partial V_j \partial \theta_i} = -V_i \cdot (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt θ_j**

$$\frac{\partial P_i^2}{\partial V_j \partial \theta_j} = V_i \cdot (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt θ_k (for $k \neq i$, and $k \neq j$)**

$$\frac{\partial P_i^2}{\partial V_j \partial \theta_k} = 0$$

- **Second derivative wrt V_i**

$$\frac{\partial P_i^2}{\partial V_j \partial V_i} = G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij}$$

- **Second derivative wrt V_j**

$$\frac{\partial P_i^2}{\partial V_j \partial V_j} = 0$$

- **Second derivative wrt V_k (for $k \neq i$, and $k \neq j$)**

$$\frac{\partial P_i^2}{\partial V_j \partial V_k} = 0$$

- **Reactive Power Injection**

$$Q_i = V_i \sum_{j=1}^{nbus} V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

First derivative w.r.t θ_i . (with fixed i)

$$\frac{\partial Q_i}{\partial \theta_i} = V_i \sum_{j=1}^{nbus} V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij}) - V_i^2 G_{ii}$$

- **Second derivative wrt θ_i**

$$\frac{\partial Q_i^2}{\partial \theta_i \partial \theta_i} = -V_i \sum_{j=1}^{nbus} V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij}) - V_i^2 B_{ii}$$

- **Second derivative wrt θ_j (for $j \neq i$)**

$$\frac{\partial Q_i^2}{\partial \theta_i \partial \theta_j} = V_i V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt V_i**

$$\frac{\partial Q_i^2}{\partial \theta_i \partial V_i} = \sum_{j=1}^{nbus} V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij}) - V_i G_{ii}$$

- **Second derivative wrt V_j (for $j \neq i$)**

$$\frac{\partial Q_i^2}{\partial \theta_i \partial V_j} = V_i (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

First derivative w.r.t θ_j . (with fixed i and j , for $j \neq i$)

$$\frac{\partial Q_i}{\partial \theta_j} = -V_i V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- **Second derivative wrt θ_i**

$$\frac{\partial Q_i^2}{\partial \theta_j \partial \theta_i} = V_i V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt θ_j**

$$\frac{\partial Q_i^2}{\partial \theta_j \partial \theta_j} = -V_i V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt θ_k (for $k \neq i$, and $k \neq j$)**

$$\frac{\partial Q_i^2}{\partial \theta_j \partial \theta_k} = 0$$

- **Second derivative wrt V_i**

$$\frac{\partial Q_i^2}{\partial \theta_j \partial V_i} = -V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- **Second derivative wrt V_j**

$$\frac{\partial Q_i^2}{\partial \theta_j \partial V_j} = -V_i (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- **Second derivative wrt V_k (for $k \neq i$, and $k \neq j$)**

$$\frac{\partial Q_i^2}{\partial \theta_j \partial V_k} = 0$$

First derivative w.r.t V_i . (with fixed i)

$$\frac{\partial Q_i}{\partial V_i} = \sum_{j=1}^{nbus} V_j (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij}) - V_i B_{ii}$$

- **Second derivative wrt θ_i**

$$\frac{\partial Q_i^2}{\partial V_i \partial \theta_i} = \sum_{j=1}^{nbus} V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij}) - V_i G_{ii}$$

- **Second derivative wrt θ_j (for $j \neq i$)**

$$\frac{\partial Q_i^2}{\partial V_i \partial \theta_j} = -V_j (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- **Second derivative wrt V_i**

$$\frac{\partial Q_i^2}{\partial V_i \partial V_i} = -2B_{ii}$$

- **Second derivative wrt V_j (for $j \neq i$)**

$$\frac{\partial Q_i^2}{\partial V_i \partial V_j} = G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij}$$

First derivative w.r.t V_j . (with fixed i and j , for $j \neq i$)

$$\frac{\partial Q_i}{\partial V_j} = V_i (G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij})$$

- **Second derivative wrt θ_i**

$$\frac{\partial Q_i^2}{\partial V_j \partial \theta_i} = V_i (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- **Second derivative wrt θ_j**

$$\frac{\partial Q_i^2}{\partial V_j \partial \theta_j} = -V_i (G_{ij} \cos \theta_{ij} + B_{ij} \sin \theta_{ij})$$

- **Second derivative wrt θ_k (for $k \neq i$ and $k \neq j$)**

$$\frac{\partial Q_i^2}{\partial V_j \partial \theta_k} = 0$$

- **Second derivative wrt V_i**

$$\frac{\partial Q_i^2}{\partial V_j \partial V_i} = G_{ij} \sin \theta_{ij} - B_{ij} \cos \theta_{ij}$$

- **Second derivative wrt V_j**

$$\frac{\partial Q_i^2}{\partial V_j \partial V_j} = 0$$

- **Second derivative wrt V_k (for $k \neq i$ and $k \neq j$)**

$$\frac{\partial Q_i^2}{\partial V_j \partial V_k} = 0$$

II Vectorized Jacobian

This section gives the vectorized Jacobian matrix. The method has been cross-validated through the comparison with the Matlab codes in [2]. Prof. DeMarco's contributions are credited in the Matlab codes. Note that the vectorized Jacobian can be implemented efficiently using Matlab.

$$\begin{aligned}
 S &= \text{diag}(\vec{V}) \cdot \text{conj}(\vec{I}) \\
 &= \text{diag}(\vec{V}) \cdot \text{conj}(Y \cdot \vec{V}) \\
 &= \begin{bmatrix} V_1 & \\ & V_2 \end{bmatrix} \cdot \begin{bmatrix} e^{j\theta_1} & \\ & e^{j\theta_2} \end{bmatrix} \cdot \text{conj}(Y) \cdot \begin{bmatrix} e^{-j\theta_1} & \\ & e^{-j\theta_2} \end{bmatrix} \cdot \begin{bmatrix} V_1 \\ V_2 \end{bmatrix}
 \end{aligned} \tag{2.1}$$

2.1) Vectorized Jacobian wrt V

$$\begin{aligned}
 \frac{\partial S}{\partial V} &= \frac{\partial}{\partial V} \{ \text{diag}(\vec{V}) \cdot \text{conj}(\vec{I}) \} \\
 &= \text{diag}(\vec{V}) \cdot \frac{\partial \text{conj}(\vec{I})}{\partial V} + \text{diag}[\text{conj}(\vec{I})] \cdot \frac{\partial \vec{V}}{\partial V} \\
 &= \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} e^{-j\theta_1} & & \\ & \ddots & \\ & & e^{-j\theta_{nbus}} \end{bmatrix} + \text{diag}[\text{conj}(Y \cdot \vec{V})] \cdot \begin{bmatrix} e^{j\theta_1} & & \\ & \ddots & \\ & & e^{j\theta_{nbus}} \end{bmatrix} \\
 &= \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \text{diag} \left[\text{conj} \left(\frac{\vec{V}}{V} \right) \right] + \text{diag}[\text{conj}(Y \cdot \vec{V})] \cdot \text{diag} \left[\frac{\vec{V}}{V} \right]
 \end{aligned} \tag{2.2}$$

$$\frac{\partial P}{\partial V} = \text{real} \left(\frac{\partial S}{\partial V} \right) \quad \frac{\partial Q}{\partial V} = \text{imag} \left(\frac{\partial S}{\partial V} \right) \tag{2.3}$$

2.2) Vectorized Jacobian wrt θ

$$\begin{aligned}
\frac{\partial S}{\partial \theta} &= \frac{\partial}{\partial \theta} \{diag(\vec{V}) \cdot conj(\vec{I})\} \\
&= diag(\vec{V}) \cdot \frac{\partial conj(\vec{I})}{\partial \theta} + diag[conj(\vec{I})] \cdot \frac{\partial \vec{V}}{\partial \theta} \\
&= diag(\vec{V}) \cdot conj(Y) \cdot \begin{bmatrix} -jV_1 e^{-j\theta_1} & & \\ & \ddots & \\ & & -jV_{nbus} e^{-j\theta_{nbus}} \end{bmatrix} + diag[conj(Y \cdot \vec{V})] \cdot \begin{bmatrix} jV_1 e^{j\theta_1} & & \\ & \ddots & \\ & & jV_{nbus} e^{j\theta_{nbus}} \end{bmatrix} \\
&= diag(\vec{V}) \cdot conj(Y) \cdot diag(conj(j \cdot \vec{V})) + diag[conj(Y \cdot \vec{V})] \cdot diag(j \cdot \vec{V})
\end{aligned} \tag{2.4}$$

$$\frac{\partial P}{\partial \theta} = real\left(\frac{\partial S}{\partial \theta}\right) \quad \frac{\partial Q}{\partial \theta} = imag\left(\frac{\partial S}{\partial \theta}\right) \tag{2.5}$$

III Vectorized Hessian

Suppose that $J(x) \in R^{N \times N}$ is the “full Jacobian” matrix. Then, the *Hessian* matrix can be expressed as $\frac{\partial}{\partial x} [vec(J(x))] \in R^{N^2 \times N}$. The vectorized Hessian matrix can be implemented more efficiently using Matlab than the scalar version.

$$\mathbf{3.1)} \quad \frac{\partial}{\partial \theta} \left(\frac{\partial S}{\partial \theta_i} \right)$$

$$\frac{\partial S}{\partial \theta_i} \triangleq \frac{\partial S_1}{\partial \theta_i} + \frac{\partial S_2}{\partial \theta_i} = diag(\vec{V}) \cdot conj(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ -jV_i e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} + diag[conj(Y \cdot \vec{V})] \cdot \begin{bmatrix} 0_{(i-1)} \\ jV_i e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \tag{3.1.1}$$

$$\frac{\partial}{\partial \theta} \left(\frac{\partial S_1}{\partial \theta_i} \right) = [diag(\vec{V}) \cdot conj(Y)] \cdot \begin{bmatrix} 0 \\ -V_i e^{-j\theta_i} \\ 0 \end{bmatrix} + diag \left\{ conj(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ -jV_i e^{-j\theta_i} \\ 0_{(n-i)} \end{bmatrix} \right\} \cdot \begin{bmatrix} jV_1 e^{j\theta_1} & & \\ & \ddots & \\ & & jV_{nbus} e^{j\theta_{nbus}} \end{bmatrix} \tag{3.1.2}$$

$$= [diag(\vec{V}) \cdot conj(Y)] \cdot \begin{bmatrix} 0 \\ -V_i e^{-j\theta_i} \\ 0 \end{bmatrix} + diag \left\{ diag(j\vec{V}) \cdot conj(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ -jV_i e^{-j\theta_i} \\ 0_{(n-i)} \end{bmatrix} \right\}$$

$$\begin{aligned}
\frac{\partial}{\partial \theta} \left(\frac{\partial S_2}{\partial \theta_i} \right) &= \text{diag}[\text{conj}(Y \cdot \vec{V})] \cdot \begin{bmatrix} 0 & & \\ & -V_i e^{j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ \begin{bmatrix} 0_{(i-1)} \\ jV_i e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \cdot \text{conj}(Y) \cdot \begin{bmatrix} -jV_i e^{-j\theta_i} & & \\ & \ddots & \\ & & -jV_{nbus} e^{-j\theta_{nbus}} \end{bmatrix} \\
&= \text{diag} \left\{ \text{diag}[\text{conj}(Y \cdot \vec{V})] \cdot \begin{bmatrix} 0_{(i-1)} \\ -V_i e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} + \text{diag} \left\{ \begin{bmatrix} 0_{(i-1)} \\ jV_i e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \cdot \text{conj}(Y) \cdot \text{diag}[\text{conj}(j\vec{V})]
\end{aligned} \tag{3.1.3}$$

Thus,

$$\begin{aligned}
\frac{\partial}{\partial \theta} \left(\frac{\partial S}{\partial \theta_i} \right) &= \underbrace{\left[\text{diag}(\vec{V}) \cdot \text{conj}(Y) \right] \cdot \begin{bmatrix} 0 & & \\ & -V_i e^{-j\theta_i} & \\ & & 0 \end{bmatrix}}_{\text{Type I}} + \underbrace{\text{diag} \left\{ \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ V_i e^{-j\theta_i} \\ 0_{(n-i)} \end{bmatrix} \right\}}_{\text{Type II}} \\
&+ \underbrace{\text{diag} \left\{ \text{diag}[\text{conj}(Y \cdot \vec{V})] \cdot \begin{bmatrix} 0_{(i-1)} \\ -V_i e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\}}_{\text{Type II}} + \underbrace{\text{diag} \left\{ \begin{bmatrix} 0_{(i-1)} \\ V_i e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \cdot \text{conj}(Y) \cdot \text{diag}[\text{conj}(\vec{V})]}_{\text{Type III}}
\end{aligned} \tag{3.1.4}$$

$$\mathbf{3.2) \quad \frac{\partial}{\partial V} \left(\frac{\partial S}{\partial \theta_i} \right)}$$

$$\frac{\partial S}{\partial \theta_i} \stackrel{\Delta}{=} \frac{\partial S_1}{\partial \theta_i} + \frac{\partial S_2}{\partial \theta_i} = \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ -jV_i e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} + \text{diag}[\text{conj}(Y \cdot \vec{V})] \cdot \begin{bmatrix} 0_{(i-1)} \\ jV_i e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \tag{3.2.1}$$

$$\begin{aligned}
\frac{\partial}{\partial V} \left(\frac{\partial S_1}{\partial \theta_i} \right) &= \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0 & & \\ & -j e^{-j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ -jV_i e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \cdot \begin{bmatrix} e^{j\theta_i} & & \\ & \ddots & \\ & & e^{j\theta_{nbus-1}} \end{bmatrix} \\
&= \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0 & & \\ & -j e^{-j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ \begin{bmatrix} e^{j\theta_i} & & \\ & \ddots & \\ & & e^{j\theta_{nbus-1}} \end{bmatrix} \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ -jV_i e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\}
\end{aligned} \tag{3.2.2}$$

$$\frac{\partial}{\partial V} \left(\frac{\partial S_2}{\partial \theta_i} \right) = \text{diag}[\text{conj}(Y \cdot \bar{V})] \cdot \begin{bmatrix} 0 & & \\ & j e^{j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ \begin{bmatrix} 0_{(i-1)} \\ j V_i e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \text{conj}(Y) \cdot \begin{bmatrix} e^{-j\theta_i} & & \\ & \ddots & \\ & & e^{-j\theta_{nbus}} \end{bmatrix} \quad (3.2.3)$$

$$\begin{aligned} \frac{\partial}{\partial V} \left(\frac{\partial S}{\partial \theta_i} \right) &= \frac{\partial}{\partial V} \left(\frac{\partial S_1}{\partial \theta_i} \right) + \frac{\partial}{\partial V} \left(\frac{\partial S_2}{\partial \theta_i} \right) \\ &= \text{diag}(\bar{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0 & & \\ & -j e^{-j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ \begin{bmatrix} e^{j\theta_i} & & \\ & \ddots & \\ & & e^{j\theta_{nbus}} \end{bmatrix} \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ -j V_i e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \\ &+ \text{diag}[\text{conj}(Y \cdot \bar{V})] \cdot \begin{bmatrix} 0 & & \\ & j e^{j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ \begin{bmatrix} 0_{(i-1)} \\ j V_i e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \text{conj}(Y) \cdot \begin{bmatrix} e^{-j\theta_i} & & \\ & \ddots & \\ & & e^{-j\theta_{nbus}} \end{bmatrix} \end{aligned} \quad (3.2.4)$$

3.3) $\frac{\partial}{\partial \theta} \left(\frac{\partial S}{\partial V_i} \right)$

$$\frac{\partial S}{\partial V_i} \triangleq \frac{\partial S_1}{\partial V_i} + \frac{\partial S_2}{\partial V_i} = \begin{bmatrix} V_i e^{j\theta_i} & & \\ & \ddots & \\ & & V_{nbus} e^{j\theta_{nbus}} \end{bmatrix} \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} + \text{diag} \left\{ \text{conj}(Y) \cdot \begin{bmatrix} V_i e^{-j\theta_i} \\ \vdots \\ V_{nbus} e^{-j\theta_{nbus}} \end{bmatrix} \right\} \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{j\theta_i} \\ 0_{(i-1)} \end{bmatrix} \quad (3.3.1)$$

$$\begin{aligned}
\frac{\partial}{\partial \theta} \left(\frac{\partial S_1}{\partial V_i} \right) &= \begin{bmatrix} V_1 e^{j\theta_1} & & \\ & \ddots & \\ & & V_{nbus} e^{j\theta_{nbus}} \end{bmatrix} \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0 & & \\ & -je^{-j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \cdot \begin{bmatrix} jV_1 e^{j\theta_1} & & \\ & \ddots & \\ & & jV_{nbus} e^{j\theta_{nbus}} \end{bmatrix} \\
&= \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0 & & \\ & -je^{-j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \cdot j \cdot \text{diag}(\vec{V}) \\
&= \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0 & & \\ & -je^{-j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ j \cdot \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\}
\end{aligned} \tag{3.3.2}$$

$$\begin{aligned}
\frac{\partial}{\partial \theta} \left(\frac{\partial S_2}{\partial V_i} \right) &= \text{diag} \left\{ \text{conj}(Y) \cdot \begin{bmatrix} V_1 e^{-j\theta_1} \\ \vdots \\ V_{nbus} e^{-j\theta_{nbus}} \end{bmatrix} \right\} \cdot \begin{bmatrix} 0 & & \\ & je^{j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ \begin{bmatrix} 0_{(i-1)} \\ e^{j\theta_i} \\ 0_{(i-1)} \end{bmatrix} \right\} \cdot \text{conj}(Y) \cdot (-j) \cdot \text{diag} \left\{ \begin{bmatrix} V_1 e^{-j\theta_1} \\ \vdots \\ V_{nbus} e^{-j\theta_{nbus}} \end{bmatrix} \right\} \\
&= \text{diag} \left\{ \text{diag}[\text{conj}(Y \cdot \vec{V})] \cdot \begin{bmatrix} 0 \\ je^{j\theta_i} \\ 0 \end{bmatrix} \right\} + \text{diag} \left\{ \begin{bmatrix} 0_{(i-1)} \\ e^{j\theta_i} \\ 0_{(i-1)} \end{bmatrix} \right\} \cdot \text{conj}[Y \cdot j \cdot \text{diag}(\vec{V})]
\end{aligned} \tag{3.3.3}$$

$$\begin{aligned}
\frac{\partial}{\partial \theta} \left(\frac{\partial S}{\partial V_i} \right) &\stackrel{\Delta}{=} \frac{\partial}{\partial \theta} \left(\frac{\partial S_1}{\partial V_i} \right) + \frac{\partial}{\partial \theta} \left(\frac{\partial S_2}{\partial V_i} \right) \\
&= \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0 & & \\ & -je^{-j\theta_i} & \\ & & 0 \end{bmatrix} + \text{diag} \left\{ j \cdot \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \\
&\quad + \text{diag} \left\{ \text{diag}[\text{conj}(Y \cdot \vec{V})] \cdot \begin{bmatrix} 0 \\ je^{j\theta_i} \\ 0 \end{bmatrix} \right\} + \text{diag} \left\{ \begin{bmatrix} 0_{(i-1)} \\ e^{j\theta_i} \\ 0_{(i-1)} \end{bmatrix} \right\} \cdot \text{conj}[Y \cdot j \cdot \text{diag}(\vec{V})]
\end{aligned} \tag{3.3.4}$$

$$3.4) \quad \frac{\partial}{\partial V} \left(\frac{\partial S}{\partial V_i} \right)$$

$$\frac{\partial S}{\partial V_i} \triangleq \frac{\partial S_1}{\partial V_i} + \frac{\partial S_2}{\partial V_i} = \text{diag}(\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} + \text{diag}[\text{conj}(Y \cdot \vec{V})] \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{j\theta_i} \\ 0_{(i-1)} \end{bmatrix} \quad (3.4.1)$$

$$\begin{aligned} & \frac{\partial}{\partial V} \left(\frac{\partial S_1}{\partial V_i} \right) \\ &= \text{diag} \left\{ \text{conj}(Y) \cdot \begin{bmatrix} \bar{0}_{i-1} \\ e^{-j\theta_i} \\ \bar{0}_{nbus-i} \end{bmatrix} \right\} \cdot \begin{bmatrix} e^{j\theta_1} & & \\ & \ddots & \\ & & e^{j\theta_{nbus}} \end{bmatrix} \\ &= \text{diag} \left\{ \begin{bmatrix} e^{j\theta_1} & & \\ & \ddots & \\ & & e^{j\theta_{nbus}} \end{bmatrix} \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} \end{aligned} \quad (3.4.2)$$

$$\frac{\partial}{\partial V} \left(\frac{\partial S_2}{\partial V_i} \right) = \text{diag} \begin{bmatrix} 0_{(i-1)} \\ e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \cdot \text{conj}(Y) \cdot \begin{bmatrix} e^{-j\theta_1} & & \\ & \ddots & \\ & & e^{-j\theta_{nbus}} \end{bmatrix} \quad (3.4.3)$$

Thus,

$$\begin{aligned} & \frac{\partial}{\partial V} \left(\frac{\partial S}{\partial V_i} \right) \triangleq \frac{\partial}{\partial V} \left(\frac{\partial S_1}{\partial V_i} \right) + \frac{\partial}{\partial V} \left(\frac{\partial S_2}{\partial V_i} \right) \\ &= \text{diag} \left\{ \begin{bmatrix} e^{j\theta_1} & & \\ & \ddots & \\ & & e^{j\theta_{nbus}} \end{bmatrix} \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ e^{-j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \right\} + \text{diag} \begin{bmatrix} 0_{(i-1)} \\ e^{j\theta_i} \\ 0_{(nbus-i)} \end{bmatrix} \cdot \text{conj}(Y) \cdot \begin{bmatrix} e^{-j\theta_1} & & \\ & \ddots & \\ & & e^{-j\theta_{nbus}} \end{bmatrix} \end{aligned} \quad (3.4.4)$$

IV. Derivative of Transposed Jacobian Multiplied by Left EigenVector

To implement the transposed direct method, we need to calculate $\frac{\partial}{\partial x}[J^t(x) \cdot L]$ as described in [3]. An approximate expression for calculating $\frac{\partial}{\partial x}[J^t(x) \cdot L]$ is described in [3]. This section describes a procedure using the Hessian Matrix, which is an accurate expression. Also, the implementing efficiency using Matlab is also considered.

4.1) Basic formula

$$\frac{\partial}{\partial x}[J^t(x) \cdot L] = \frac{\partial}{\partial x}[L^t \cdot J(x)] = (I_p \otimes L^t) \frac{\partial}{\partial x}[\text{vec}(J(x))] = \begin{bmatrix} L^t \frac{\partial}{\partial x}[J_{*1}(x)] \\ L^t \frac{\partial}{\partial x}[J_{*2}(x)] \\ \vdots \\ L^t \frac{\partial}{\partial x}[J_{*N}(x)] \end{bmatrix} = \begin{bmatrix} L^t \frac{\partial}{\partial x}[\frac{\partial}{\partial x_1} F(x)] \\ L^t \frac{\partial}{\partial x}[\frac{\partial}{\partial x_2} F(x)] \\ \vdots \\ L^t \frac{\partial}{\partial x}[\frac{\partial}{\partial x_N} F(x)] \end{bmatrix}$$

$$\begin{bmatrix} L_{P_1} & L_{P_2} & L_{Q_1} & L_{Q_2} & L_{\Delta\theta_{RB}} & L_{\Delta V_{PV}} \end{bmatrix} \cdot \begin{bmatrix} \theta_1 & \theta_2 & V_1 & V_2 & \beta_1 & Q_{PV} \\ \frac{\partial P_1}{\partial \theta_1} \\ \frac{\partial P_2}{\partial \theta_1} \\ \frac{\partial Q_1}{\partial \theta_1} \\ \frac{\partial Q_2}{\partial \theta_1} \\ \frac{\partial \Delta\theta_{RB}}{\partial \theta_1} \\ \frac{\partial \Delta V_{PV}}{\partial \theta_1} \end{bmatrix} \quad (4.1)$$

Notation:

$F(x)$ is defined in (1.3) of [4]

$N=2 \cdot n_{bus} + 1 + n_{pv}$

$$x = [\theta; V; \beta_1; Q_{pv}] \in \mathbb{R}^{N \times 1}$$

$L \in \mathbb{R}^{N \times 1}$ is the left eigen-vector of the Jacobian *matrix*.

$J(x) \in \mathbb{R}^{N \times N}$ is the “full Jacobian” matrix

Vec(*) operator vectorizes a matrix by stacking its columns. For example,

$$\text{vec}\left(\begin{bmatrix} 1 & 2 \\ 3 & 4 \end{bmatrix}\right) = \begin{bmatrix} 1 \\ 3 \\ 2 \\ 4 \end{bmatrix}$$

$\frac{\partial}{\partial x} [\text{vec}(J(x))] \in \mathbb{R}^{N^2 \times N}$ is the Hessian *matrix*.

$$\text{Kronecker product: } A \otimes B = \begin{bmatrix} A_{11}B & A_{12}B & \cdots & A_{1n}B \\ A_{21}B & A_{22}B & \cdots & A_{2n}B \\ \vdots & \vdots & \ddots & \vdots \\ A_{m1}B & A_{m2}B & \cdots & A_{mn}B \end{bmatrix}$$

4.2) To improve coding efficiency

Combined with (4.1), the matrix multiplications described in [section III: Vectorized Hessian] can be implemented more efficiently considering their structure features.

There are three types of structure:

4.2.1) Type I

Definition:

$$\left[\text{diag}(\bar{V}) \cdot \text{conj}(Y) \right] \cdot \begin{bmatrix} 0 \\ -V_i e^{-j\theta_i} \\ 0 \end{bmatrix} \Rightarrow A \cdot \begin{bmatrix} 0 \\ k_i \\ 0 \end{bmatrix} \quad (4.2)$$

Left eigen-vector multiplication:

$$\begin{bmatrix} L_p \\ L_Q \end{bmatrix}^t \cdot \begin{bmatrix} \text{real} \left(A \cdot \begin{bmatrix} 0 \\ k_i \\ 0 \end{bmatrix} \right) \\ \text{imag} \left(A \cdot \begin{bmatrix} 0 \\ k_i \\ 0 \end{bmatrix} \right) \end{bmatrix} = \begin{bmatrix} L_p & L_Q \end{bmatrix}^t \cdot \begin{bmatrix} \text{real} [0 \quad k_i A_{*i} \quad 0] \\ \text{imag} [0 \quad k_i A_{*i} \quad 0] \end{bmatrix} = \begin{bmatrix} 0 & \text{real}(k_i L_p^t A_{*i}) + \text{imag}(k_i L_Q^t A_{*i}) & 0 \end{bmatrix} \quad (4.3)$$

, where A_{*i} stands for the i^{th} column of A matrix .

Matrix format

$$\text{Let: } B = A \cdot \begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix}$$

$$\begin{aligned} & \text{diag} \left\{ \begin{bmatrix} L_p \\ L_Q \end{bmatrix}^t \cdot \begin{bmatrix} \text{real}(B) \\ \text{imag}(B) \end{bmatrix} \right\} \\ &= \text{diag} \left\{ \begin{bmatrix} L_p \\ L_Q \end{bmatrix}^t \cdot \begin{bmatrix} \text{real} \left(A \cdot \begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix} \right) \\ \text{imag} \left(A \cdot \begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix} \right) \end{bmatrix} \right\} = \text{diag} \left\{ \begin{bmatrix} L_p & L_Q \end{bmatrix}^t \cdot \begin{bmatrix} \text{real}([k_1 A_{*1} \quad k_i A_{*i} \quad k_n A_{*n}]) \\ \text{imag}([k_1 A_{*1} \quad k_i A_{*i} \quad k_n A_{*n}]) \end{bmatrix} \right\} \\ &= \text{diag} \left\{ \begin{bmatrix} \text{real}(k_1 L_p^t A_{*1}) + \text{imag}(k_1 L_Q^t A_{*1}) & \text{real}(k_i L_p^t A_{*i}) + \text{imag}(k_i L_Q^t A_{*i}) & \text{real}(k_n L_p^t A_{*n}) + \text{imag}(k_n L_Q^t A_{*n}) \end{bmatrix} \right\} \end{aligned} \quad (4.4)$$

Notice that each row of (4.4) is same as (4.3). Thus (4.4) can be used to calculate the (4.3) in matrix format

4.2.2) Type II

Definition:

$$\text{diag} \left\{ \text{diag}(j\vec{V}) \cdot \text{conj}(Y) \cdot \begin{bmatrix} 0_{(i-1)} \\ -jV_i e^{-j\theta_i} \\ 0_{(n-i)} \end{bmatrix} \right\} \Rightarrow \text{diag} \left\{ A \cdot \begin{bmatrix} 0 \\ k_i \\ 0 \end{bmatrix} \right\} \quad (4.5)$$

Left eigen-vector multiplication:

$$\begin{bmatrix} L_p \\ L_Q \end{bmatrix}^t \cdot \begin{bmatrix} \text{real} \left(\text{diag} \left\{ A \cdot \begin{bmatrix} 0 \\ k_i \\ 0 \end{bmatrix} \right\} \right) \\ \text{imag} \left(\text{diag} \left\{ A \cdot \begin{bmatrix} 0 \\ k_i \\ 0 \end{bmatrix} \right\} \right) \end{bmatrix} = \begin{bmatrix} L_p & L_Q \end{bmatrix}^t \cdot \begin{bmatrix} \text{diag} \{ \text{real}(k_i A_{*i}) \} \\ \text{diag} \{ \text{imag}(k_i A_{*i}) \} \end{bmatrix}$$

$$= L_p^t \text{diag} \{ \text{real}(k_i A_{*i}) \} + L_Q^t \text{diag} \{ \text{imag}(k_i A_{*i}) \}$$

(4.6)

, where A_{*i} stands for the i^{th} column of A matrix .

Matrix format

$$B \stackrel{\Delta}{=} A \cdot \begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix}$$

$$\begin{aligned}
& \begin{bmatrix} \mathit{real}(B)^t & \mathit{imag}(B)^t \end{bmatrix} \cdot \begin{bmatrix} \mathit{diag}(L_P) \\ \mathit{diag}(L_Q) \end{bmatrix} \\
&= \begin{bmatrix} \mathit{real} \left(A \cdot \begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix} \right)^t & \mathit{imag} \left(A \cdot \begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix} \right)^t \end{bmatrix} \cdot \begin{bmatrix} \mathit{diag}(L_P) \\ \mathit{diag}(L_Q) \end{bmatrix} \\
&= \left\{ \begin{bmatrix} \mathit{diag}(L_P) \\ \mathit{diag}(L_Q) \end{bmatrix}^t \cdot \begin{bmatrix} \mathit{real} \left(A \cdot \begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix} \right) \\ \mathit{imag} \left(A \cdot \begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix} \right) \end{bmatrix} \right\}^t = \left\{ \begin{bmatrix} \mathit{diag}(L_P) & \mathit{diag}(L_Q) \end{bmatrix} \cdot \begin{bmatrix} \mathit{real}([k_1 A_{*1} & k_i A_{*i} & k_n A_{*n}]) \\ \mathit{imag}([k_1 A_{*1} & k_i A_{*i} & k_n A_{*n}]) \end{bmatrix} \right\}^t \\
&= \begin{bmatrix} \mathit{real}(k_1 \mathit{diag}(L_P) \cdot A_{*1}) + \mathit{imag}(k_1 \mathit{diag}(L_Q) \cdot A_{*1}) & \mathit{real}(k_i \mathit{diag}(L_P) \cdot A_{*i}) + \mathit{imag}(k_i \mathit{diag}(L_Q) \cdot A_{*i}) & \mathit{real}(k_n \mathit{diag}(L_P) \cdot A_{*n}) + \mathit{imag}(k_n \mathit{diag}(L_Q) \cdot A_{*n}) \end{bmatrix} \\
&= \begin{bmatrix} \mathit{real}(\mathit{diag}(k_1 A_{*1}) \cdot L_P) + \mathit{imag}(\mathit{diag}(k_1 A_{*1}) \cdot L_Q) & \mathit{real}(\mathit{diag}(k_i A_{*i}) \cdot L_P) + \mathit{imag}(\mathit{diag}(k_i A_{*i}) \cdot L_Q) & \mathit{real}(\mathit{diag}(k_n A_{*n}) \cdot L_P) + \mathit{imag}(\mathit{diag}(k_n A_{*n}) \cdot L_Q) \end{bmatrix} \\
&= \begin{bmatrix} \mathit{real}(L_P^t \cdot \mathit{diag}(k_1 A_{*1})) + \mathit{imag}(L_Q^t \cdot \mathit{diag}(k_1 A_{*1})) \\ \mathit{real}(L_P^t \cdot \mathit{diag}(k_i A_{*i})) + \mathit{imag}(L_Q^t \cdot \mathit{diag}(k_i A_{*i})) \\ \mathit{real}(L_P^t \cdot \mathit{diag}(k_n A_{*n})) + \mathit{imag}(L_Q^t \cdot \mathit{diag}(k_n A_{*n})) \end{bmatrix} \\
&= \begin{bmatrix} L_P^t \cdot \mathit{real}(\mathit{diag}(k_1 A_{*1})) + L_Q^t \cdot \mathit{imag}(\mathit{diag}(k_1 A_{*1})) \\ L_P^t \cdot \mathit{real}(\mathit{diag}(k_i A_{*i})) + L_Q^t \cdot \mathit{imag}(\mathit{diag}(k_i A_{*i})) \\ L_P^t \cdot \mathit{real}(\mathit{diag}(k_n A_{*n})) + L_Q^t \cdot \mathit{imag}(\mathit{diag}(k_n A_{*n})) \end{bmatrix}
\end{aligned} \tag{4.7}$$

Notice that each row of (4.7) is same as (4.6). Thus (4.7) can be used to calculate the (4.6) in matrix format.

4.2.2) Type III

Definition:

$$\text{diag} \left\{ \begin{bmatrix} 0_{(i-1)} \\ jV_i e^{j\theta_i} \\ 0_{(n\text{bus}-i)} \end{bmatrix} \right\} \cdot \text{conj}(Y) \cdot \text{diag}[\text{conj}(j\vec{V})] \Rightarrow \begin{bmatrix} 0 & & \\ & k_i & \\ & & 0 \end{bmatrix} A \quad (4.8)$$

Left eigen-vector multiplication:

$$\begin{bmatrix} L_P \\ L_Q \end{bmatrix}^t \cdot \begin{bmatrix} \text{real} \left(\begin{bmatrix} 0 \\ k_i \\ 0 \end{bmatrix} A \right) \\ \text{imag} \left(\begin{bmatrix} 0 \\ k_i \\ 0 \end{bmatrix} A \right) \end{bmatrix} = \begin{bmatrix} L_P^t & L_Q^t \end{bmatrix} \begin{bmatrix} \text{real} \left(\begin{bmatrix} 0 \\ k_i A_{i*} \\ 0 \end{bmatrix} \right) \\ \text{imag} \left(\begin{bmatrix} 0 \\ k_i A_{i*} \\ 0 \end{bmatrix} \right) \end{bmatrix} = L_{P_i} \cdot \text{real}(k_i A_{i*}) + L_{Q_i} \cdot \text{imag}(k_i A_{i*}) \quad (4.9)$$

, where A_{i*} stands for the i^{th} row of A matrix .

Matrix format

$$\text{Let: } B \stackrel{\Delta}{=} \begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix} \cdot A$$

$$\begin{aligned}
& \begin{bmatrix} \text{diag}(L_p) \\ \text{diag}(L_Q) \end{bmatrix}^t \cdot \begin{bmatrix} \text{real}(B) \\ \text{imag}(B) \end{bmatrix} \\
&= \begin{bmatrix} \text{diag}(L_p) \\ \text{diag}(L_Q) \end{bmatrix}^t \cdot \begin{bmatrix} \text{real} \left(\begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix} \cdot A \right) \\ \text{imag} \left(\begin{bmatrix} k_1 & & \\ & k_i & \\ & & k_n \end{bmatrix} \cdot A \right) \end{bmatrix} = \begin{bmatrix} \text{diag}(L_p) & \text{diag}(L_Q) \end{bmatrix} \cdot \begin{bmatrix} \text{real} \begin{pmatrix} k_1 A_{1*} \\ k_i A_{i*} \\ k_n A_{n*} \end{pmatrix} \\ \text{imag} \begin{pmatrix} k_1 A_{1*} \\ k_i A_{i*} \\ k_n A_{n*} \end{pmatrix} \end{bmatrix} \\
&= \text{diag}(L_p) \cdot \text{real} \begin{pmatrix} k_1 A_{1*} \\ k_i A_{i*} \\ k_n A_{n*} \end{pmatrix} + \text{diag}(L_Q) \cdot \text{imag} \begin{pmatrix} k_1 A_{1*} \\ k_i A_{i*} \\ k_n A_{n*} \end{pmatrix} \\
&= \begin{bmatrix} L_{P_1} \cdot \text{real}(k_1 A_{1*}) + L_{Q_1} \cdot \text{imag}(k_1 A_{1*}) \\ L_{P_i} \cdot \text{real}(k_i A_{i*}) + L_{Q_i} \cdot \text{imag}(k_i A_{i*}) \\ L_{P_n} \cdot \text{real}(k_n A_{n*}) + L_{Q_n} \cdot \text{imag}(k_n A_{n*}) \end{bmatrix} \tag{4.10}
\end{aligned}$$

Notice that each row of (4.10) is same as (4.9). Thus (4.10) can be used to calculate the (4.9) in matrix format.

V. Notation and Matrix Identity:

5.1) Notation:

$$\theta_{ij} = \theta_i - \theta_j$$

$$Y_{ij} = G_{ij} + jB_{ij} \quad (2.4)$$

$$\text{diag}(\vec{V}) = \begin{bmatrix} V_1 e^{j\theta_1} & & \\ & \ddots & \\ & & V_{nbus} e^{j\theta_{nbus}} \end{bmatrix}$$

$$\vec{V} = \begin{bmatrix} V_1 e^{j\theta_1} \\ \vdots \\ V_{nbus} e^{j\theta_{nbus}} \end{bmatrix}$$

5.2) Basic Identity:

$$\sin' x = \cos x \quad \cos' x = -\sin x$$

$$S = \text{diag}(\vec{V}) \cdot \text{conj}(\vec{I}) \quad \text{or} \quad S = \text{diag}(\text{conj}(\vec{I})) \cdot (\vec{V})$$

$$= \text{diag}(\vec{V}) \cdot \text{conj}(Y \cdot \vec{V}) \quad = \text{diag}(\text{conj}(Y \cdot \vec{V})) \cdot \vec{V}$$

$$\text{diag}(f) \cdot g = \text{diag}(g) \cdot f$$

$$\frac{\partial A f(x)}{\partial x} = A \frac{\partial f(x)}{\partial x}$$

$$\text{diag}(f) \cdot \text{diag}(g)$$

$$= \text{diag}\{\text{diag}(f) \cdot g\}$$

$$= \text{diag}\{\text{diag}(g) \cdot f\}$$

$$\begin{aligned}\frac{\partial}{\partial x}\{diag[f(x)] \cdot g(x)\} &= \frac{\partial}{\partial x}\{diag[g(x)] \cdot f(x)\} \\ &= diag[f(x)] \cdot \frac{\partial}{\partial x}\{g(x)\} + diag[g(x)] \cdot \frac{\partial}{\partial x}\{f(x)\}\end{aligned}$$

$$diag(\vec{V}) = \begin{bmatrix} V_1 & \\ & V_2 \end{bmatrix} \cdot \begin{bmatrix} e^{j\theta_1} & \\ & e^{j\theta_2} \end{bmatrix} = \begin{bmatrix} e^{j\theta_1} & \\ & e^{j\theta_2} \end{bmatrix} \cdot \begin{bmatrix} V_1 & \\ & V_2 \end{bmatrix}$$

$$\vec{V} = \begin{bmatrix} e^{j\theta_1} & \\ & e^{j\theta_2} \end{bmatrix} \cdot \begin{bmatrix} V_1 \\ V_2 \end{bmatrix} = \begin{bmatrix} V_1 & \\ & V_2 \end{bmatrix} \cdot \begin{bmatrix} e^{-j\theta_1} \\ e^{-j\theta_2} \end{bmatrix}$$

$$D[f(x)g(x)] = (g(x)^\top \otimes \mathbf{I}_m)f'(x) + (\mathbf{I}_p \otimes f(x))g'(x).$$

Reference

- [1] Ali Abur, *Power System State Estimation Theory and implementation*, Marcel Dekker, Inc, 2004
- [2] PSERC's matlab code of Predictor-Corrector Algorithm.
- [3] Yuri Makarov, *Stability Boundary Orbiting Procedure*, Sept. 2006.
- [4] Yuri Makarov, *Understanding of Transition from PSERC Predictor-Corrector Algorithm to Direct Method*, July 28, 2006

7. REFERENCES

- [1] P. Kundur, *Power System Stability and Control*, New York: McGraw-Hill, 1994.
- [2] S. Lindahl, "Case studies of recent blackouts", CRIS International Workshop on Power System Blackouts ~ Causes, Analyses, and Countermeasures, Lund, Sweden, May 3, 2004.
- [3] Final Report on the August 14, 2003 Blackout in the United States and Canada: Causes and Recommendations, U.S. – Canada Power System Outage Task Force, April 5, 2004. Available online at <http://www.nerc.com/~filez/blackout.html>
- [4] G. Doorman, G. Kjölle, K. Uhlen, E. S. Huse, and N. Flatabó, "Vulnerability of the Nordic Power System", Report to the Nordic Council of Ministers, SINTEF Energy Research, May 2004. Available online at <http://sparky.harvard.edu/hepg/Papers/Doorman.vul.nordic.system.0504.pdf>
- [5] A. Kurita and T. Sakurai, "The Power System Failure on July 23, 1987 in Tokyo", in Proceedings of the 27th Conference on Decision and Control, December 1988.
- [6] G.C. Bullock, "Cascading Voltage Collapse in West Tennessee, August 22, 1987", Georgia Institute of Technology 44th Annual Protective Relaying Conference, May 2-4 1990.
- [7] "The Electric Power Outages in the Western United States, July 2-3, 1996", DOE Report to the President, August 2, 1996. Available online at ftp://www.nerc.com/pub/sys/all_updl/docs/pubs/doerept.pdf
- [8] "Western Systems Coordinating Council Disturbance Report for the Power System Outage that Occurred on the Western Interconnection on August 10, 1996", October 18, 1996. Available online at ftp://www.nerc.com/pub/sys/all_updl/docs/pubs/AUG10FIN.pdf
- [9] "California ISO System Disturbance Report: December 8, 1998 - San Francisco Area". Available online at <http://www.caiso.com/docs/1999/03/31/1999033116341717931.pdf>
- [10] N. Dizdarevic, M. Majstrovic, S. Cudjic Coko, N. Mandic, and J. Bonovic, "Causes, Analyses and Countermeasures with Respect to Blackout in Croatia on January 12, 2003", CRIS International Workshop on Power System Blackouts ~ Causes, Analyses, and Countermeasures, Lund, Sweden, May 3, 2004.
- [11] "Technical Analysis of the August 14, 2003, Blackout: What Happened, Why, and What Did We Learn?", Report to the NERC Board of Trustees by the NERC Steering Group, July 13, 2004. Available online at ftp://www.nerc.com/pub/sys/all_updl/docs/blackout/NERC_Final_Blackout_Report_07_13_04.pdf
- [12] "Power failure in Eastern Denmark and Southern Sweden on 23 September 2003", Final report on the course of events, Ekraft System, November 4, 2003. Available online at <http://www.elkraft-system.dk>
- [13] "The Black-Out In Southern Sweden and Eastern Denmark", 23 September, 2003, Preliminary Report, PM 2003-10-02, Svenska Kraftnät. Available at http://www.svk.se/upload/3195/Disturbance_Sweden_DenmarkSept23.pdf
- [14] "Interim Report of the Investigation Committee on the 28 September 2003 Blackout in Italy", Press Release, Union for the Coordination of Transmission of Electricity UCTE, Brussels, Belgium, October 3, 2003. Available online at <http://www.energie-schweiz.ch/imperia/md/content/medienmitteilungen/mm06-122003/82.pdf>

- [15] "Black-Out: The Events Of 28 September 2003", Press Release, Gestore Rete Transmisione Nazionale, Italy, October 1, 2003. Available online at <http://www.grtn.it/eng/documentinewsstatiche/blackout28set03.pdf>
- [16] C. Vournas, "Technical Summary on the Athens and Southern Greece Blackout of July 12, 2004". Available online at http://www.pserc.org/Greece_Outage_Summary.pdf
- [17] Отчет по расследованию аварии в ЕЭС России, произошедшей 25.05.2005. Председатель комиссии по расследованию аварии В.К.Паули, 18 июня 2005г. [Report on failure inquiry in UES of Russia that took place at May 25,2005 – in Russian]. Available online at: http://www.mosenergo.ru/download/r410_account.zip.
- [18] "Voltage Stability of Power Systems: Concepts, Analytical Tools, and Industry Experience", IEEE Special Publication90TH0358-2-PWR, 1990.
- [19] "Modeling of Voltage Collapse Including Dynamic Phenomena", CIGRE Task Force 38-02-10, 1993.
- [20] P. W. Sauer, K. Tomsovic, J. Dagle, S. Widergren, T. Nguyen, and L. Schienbein, "Integrated Security Analysis", Final Report, CERTS, July 2004. Available online at http://certs.lbl.gov/CERTS_P_RealTime.html
- [21] "Memorandum on the Development and the Reasons of the East Coast US Blackout on August 14, 2003", Department of Relay Protection and Automatics, SO-CDA, September 10, 2003 – in Russian.
- [22] S. Vakhterov, "It Was Possible to Avoid the Blackout", Power Market, No. 1, 2004. – In Russian.
- [23] Y. V. Makarov, V. I. Reshetov, V. A. Stroev, and N. I. Voropai, "Blackout Prevention in the United States, Europe and Russia", Proceedings of the IEEE - Special Issue on Power Technology & Policy "Forty years after the 1965 Blackout", Vol. 93, No. 11, November 2005, pp. 1942-1955 (Invited paper).
- [24] "Voltage Stability Criteria, Undervoltage Load Shedding Strategy, and Reactive Power Reserve Monitoring Methodology", Final Report, Reactive Power Reserve Work Group, Western Electricity Coordinating Council, May 1998. Available online at <http://www.wecc.biz/modules.php?op=modload&name=Downloads&file=index&req=getit&lid=1038>
- [25] T. Van Cutsem and R. Maillhot, "Validation of a Fast Voltage Stability Analysis Method on the Hydro-Quebec System", IEEE Transactions on Power Systems, Vol. 12, No. 1, pp. 282-292, February 1997.
- [26] B. Gao, G. K. Morrison, and P. Kundur, "Voltage Stability Evaluation Using Modal Analysis", IEEE Trans. on Power Systems, Vol. 7, No. 4, November 1992, pp. 1529-1542.
- [27] "Reliability Criteria", Western Electricity Coordinating Council, April 2005. Available online at <http://www.wecc.biz/modules.php?op=modload&name=Downloads&file=index&req=getit&lid=1029>
- [28] C. W. Taylor, Power System Voltage Stability. New York: McGraw-Hill, 1994.
- [29] T.J.E Miller, Editor, Reactive Power Control in Electric Systems. New York: John Wiley & Sons, 1982
- [30] H. K Clark, "More attention to reactive [power] and voltage will present opportunities to improve grid reliability", DOE Blackout forum, December 22, 2003. Available online at http://www.electricity.doe.gov/govforums/view_thread2.cfm?post_id=186.
- [31] T. Van Cutsem, I. Dobson (Editor), C. DeMarco, D. Hill, I. Hiskens, T. Overbye, M. Venkatasubramanian, C. Vournas, Basic Theoretical Concepts, Chapter 2, IEEE Voltage Stability Work Group Report, April 1998. Available online at <http://eceserv0.ece.wisc.edu/~dobson/WG/>.

- [32] B.M. Weedy and B.R. Cox, "Voltage stability of radial power links", Proc. IEEE, Vol.115, pp. 528-536, April 1968.
- [33] P. M. Anderson and A. A. Fouad. Power System Control and Stability, IEEE Press, New York 1994.
- [34] A. M. Lyapunov, The General Problem of the Stability of Motion, London, Washington DC, Taylor & Francis, 1992.
- [35] R. Seydel, From Equilibrium to Chaos: Practical Bifurcation and Stability Analysis, Springer-Verlag, New York, 1994.
- [36] S. Strogatz, Nonlinear Dynamics and Chaos: with Applications in Physics, Biology, Chemistry, and Engineering, Addison-Wesley, Reading MA, 1994.
- [37] Thompson, J.M.T., Stewart, H.B., Nonlinear Dynamics and Chaos: Geometrical Methods for Engineers and Scientists, John Wiley, New York, 1986.
- [38] E.H. Abed, P.P. Varaiya, "Nonlinear Oscillations in Power Systems", International Journal of Electric Energy and Power Systems, vol. 6, no. 1, January 1984, pp. 37-43.
- [39] C.-W. Tan, M. Varghese, P. Varaiya, F.F. Wu, "Bifurcation, Chaos, and Voltage Collapse in Power Systems", Proceedings of the IEEE, Special issue on nonlinear phenomena in power systems, November 1995, vol. 83, no. 11, pp. 1484-1539.
- [40] V. Ajjarapu and B. Lee, "Bibliography on Voltage stability", Available online at <http://www.ee.iastate.edu/~venkatar/Biblio/biblio.html#Group5>.
- [41] V. A. Venikov, V. A. Stroeve, V. I. Idelchick, and V. I. Tarasov, "Estimation of electric power system steady-state stability in load flow calculation", IEEE Trans. on Power Apparatus and Systems, Vol. PAS-94, pp.1034 - 1041, May/June 1975.
- [42] R. C. Hardiman, M. Kumbale, and Y. V. Makarov, "An Advanced Tool for Analyzing Multiple Cascading Failures", Proceedings of the 8th International Conference on Probabilistic Methods Applied to Power Systems, Iowa State University, Ames, Iowa, September 12-16, 2004.
- [43] I. Dobson, "The Irrelevance of Load Dynamics for the Loading Margin to Voltage Collapse and its Sensitivities", in L. H. Fink, Editor, Bulk power system voltage phenomena III, voltage stability, security & control, Proceedings of the ECC/NSF workshop, Davos, Switzerland, August 1994.
- [44] C.A. Canizares, Conditions for saddle-node bifurcations in AC/DC power systems, Electrical Energy & Power Systems, Vol. 17, No. 1, pp. 61-68, 1995.
- [45] Y. V. Makarov, D. H. Popovic, and D.J. Hill, "Stabilization of Transient Processes in Power Systems by an Eigenvalue Shift Approach", IEEE Transactions on Power Systems, Vol. 13, Issue 2, May 1998, pp. 382 – 388.
- [46] Yu. E. Gurevich, L.E. Libova, and A.A. Okin, "Design of Stability and Emergency Control Automatic Devices in Power Systems", Energoatomizdat, Moscow, 1990 – in Russian.
- [47] R. R. Austria, X. Y. Chao, N. P. Reppen, and D. E. Welsh, "Integrated Approach to Transfer Limit Calculations", IEEE Computer Applications in Power, January 1995, pp. 48-52.
- [48] B. Gao, G.K. Morison and P. Kundur, "Towards the Development of a Systematic Approach for Voltage Stability Assessment of Large-Scale Power Systems", IEEE Transactions on Power Systems, Vol. PWRS-11, No. 3, August 1996, pp. 1314-1324.

- [49] V.A. Matveev, "A Method of Numeric Solution of Sets of Nonlinear Equations", Zhurnal Vychislitelnoi Matematiki I Matematicheskoi Fiziki, Vol. 4, No. 6, pp. 983-994, 1964 - in Russian.
- [50] V.I. Tarasov, "Implementation of a Permanent Loading Procedure to Definition of Load Flows on a Limit of Aperiodic Steady-State Stability", Voprosy primeneniya matematicheskikh metodov pri upravlenii regimami i razvitiem elektricheskikh sistem, Irkutsk, pp. 50-56, 1975 – in Russian.
- [51] A.M. Kontorovich, Y.V. Makarov and A. A. Tarakanov, "Improvements of a Permanent Loading Technique to Compute Load Flows on Stability Margin", Trudy LPI, No. 380, pp. 37-41, 1982 - in Russian.
- [52] A. M. Kontorovich and Y. V. Makarov, "A permanent loading technique for fast analysis of power system stability limit load flows", USSR National Scientific and Technical Conference "Problems of Stability and Reliability of the USSR Power System", Dushanbe, 1989 – In Russian.
- [53] P. Kessel and H. Glavitsch, "Estimating the voltage stability of a power system", IEEE Transactions on Power Delivery, Vol.PWRD-1, No. 3, July 1986, pp. 346-354.
- [54] G. B. Price, "A generalized circle diagram approach for global analysis of transmission system performance", IEEE Trans. Power Apparatus and Systems, Vol. PAS-103, No. 10, pp. 2881-2890, October 1984, pp. 2881-2890.
- [55] V. Ajjarapu and C. Christy, "The Continuation Power Flow : A Tool to Study Steady State Voltage Stability," IEEE Transactions on Power Systems, Vol. 7, No. 1, February 1992, pp. 416-423.
- [56] T. Van Cutsem, C. Vournas, "Voltage Stability of Electric Power Systems", Kluwer Academic Publishers (Power Electronics and Power Systems Series), Boston, 1998
- [57] A. Bihain, G. Burt, F. Casamatta, T. Koronides, R. Lopez, S. Massucco, D. Ruiz-Vega, and C. Vournas, "Advanced Perspectives and Implementation of Dynamic Security Assessment in the Open Market Environment", CIGRE 2002, France, August 2002.
- [58] J. Jarjis and F.D. Galiana, "Quantitative Analysis of Steady State Stability in Power Networks", IEEE Trans. On Power Apparatus and Systems, Vol. PAS-100, No. 1, January 1981, pp. 318-326.
- [59] A.M. Kontorovich, A.V. Kryukov, Y.V. Makarov, et al, Methods of stability indices computations for complicated power systems, Publishing House of the Irkutsk University, Irkutsk, 1988 (in Russian).
- [60] C.A. Cañizares and F.L. Alvarado, "Computational Experience with the Point of Collapse Method on Very Large AC/DC Systems", Proceedings: Bulk Power System Voltage Phenomena - Voltage Stability And Security, ECC/NSF Workshop, Deep Creek Lake, MD, August 1991; published by ECC Inc., Fairfax, Virginia.
- [61] T. Van Cutsem, "A method to compute reactive power margins with respect to voltage collapse", IEEE Trans. on Power Systems} Vol. 6, No. 1, February 1991, pp. 145-156.
- [62] C. A. Cañizares, , F. L. Alvarado, C. L. DeMarco, I. Dobson, W. F. Long, "Point of Collapse Methods Applied to AC/DC Power Systems", IEEE Transactions on Power Systems, Vol. 7, Issue 2, May 1992, pp. 673 – 683.
- [63] I. Dobson, "Observations on the Geometry of Saddle Node Bifurcation and Voltage Collapse in Electrical Power Systems", IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications, Vol. 39, Issue 3, March 1992, pp. 240 – 243.

- [64] P. W. Sauer and B. C. Lesieutre, "Power System Load Modeling", J. H. Chow, P. V. Kokotovic and R. J. Thomas, (Editors), *Systems and Control Theory for Power Systems*, Springer-Verlag 1995, pp. 283-313.
- [65] P. A. Löf, T. Smed, G. Andersson, and D. J. Hill, "Fast Calculation of a Voltage Stability Index," *IEEE Trans. Power Systems*, vol. 7, no. 1, pp. 54–64, February 1992.
- [66] Y. Tamura, H. Mori, and S. Iwamoto, "Relationship Between Voltage Instability and Multiple Load Flow Solutions in Electric Power Systems," *IEEE Trans. on Power Apparatus and Systems*, Vol. PAS-102, pp.1115 --1123, May 1983.
- [67] C.J. Parker, I.F. Morrison, and D. Sutanto, "Application of an Optimization Method for Determining the Reactive Margin From Voltage Collapse in Reactive Power Planning," *IEEE Trans. Power Systems*, Vol. 11, No. 3, August 1996, pp. 1473–1481.
- [68] G.D. Irisarri, X. Wang, J. Tong, and S. Mokhtari, "Maximum Loadability of Power Systems Using Interior Point Non-linear Optimization Method," *IEEE Trans. Power Systems*, Vol. 12, No. 1, February 1997, pp. 162-172.
- [69] "Operations Review of June 14, 2000 PG&E Bay Area System Events Using AEMPFAS[®]T Software", Consultant Report P500-03-085F, Prepared by CERTS for the California Energy Commission, October 2003.
- [70] I. Dobson and L. Lu, "Computing an Optimal Direction in Control Space to Avoid Saddle Node Bifurcation and Voltage Collapse in Electric Power Systems", *IEEE Trans. on Automatic Control*, Vol. 37, No. 10, October 1992, pp. 1616-1620.
- [71] I. Dobson, L. Lu and Y. Hu, "A Direct Method for Computing a Closest Saddle Node Bifurcation in the Load Power Parameter Space of an Electric Power System", *IEEE International Symposium on Circuits and Systems*, Singapore, June 1991, pp. 3019-3022.
- [72] I. Dobson and L. Lu, "New Methods for Computing a Closest Saddle Node Bifurcations and Worst Case Load Power Margin for Voltage Collapse", *IEEE Trans. on Power Systems*, Vol. 8, No. 3, August 1993, pp. 905-913.
- [73] F. Alvarado, I. Dobson and Y. Hu, "Computation of Closest Bifurcations in Power Systems", *IEEE Trans. on Power Systems*, Vol. 9, No. 2, May 1994, pp. 918-928.
- [74] Y.V. Makarov, Q. Wu, D.J. Hill, D.H. Popovic and Z.Y. Dong, "Coordinated Steady-State Voltage Stability Assessment and Control", *Proc. International Conference on Advances in Power System Control, Operation and Management APSCOM'97*, Wanchai, Hong Kong, November 11-14, 1997.
- [75] J. Kanetkar and S. Ranade, "Compact Representation of Power System Security - A Review," *Proceedings of the North American Power Symposium*, Reno, Nevada, 1992, pp. 312-321.
- [76] F. D. Galiana, "Power Flow Feasibility and the Voltage Collapse Problem", *Proceedings of 23rd CDC*, Las Vegas, NV, December 1984, pp. 485-487.
- [77] P. Kessel and H. Glavitsch, "Estimating the Voltage Stability Regions of a Power System," *IEEE Transactions Power Delivery*, Vol. PWRD-1, July 1986, pp. 346-354.
- [78] J. D. McCalley, S. Wang, R. T. Treinen, and A. D. Papalexopoulos, "Security Boundary Visualization for Systems Operation", *IEEE Transactions on Power Systems*, Vol. 12, No. 2, May 1997, pp. 940-947.
- [79] G. Zhou and J. D. McCalley, "Composite Security Boundary Visualization", *IEEE Transactions on Power Systems*, Vol. 14, No. 2, May 1999, pp. 725-731.

- [80] J. Su, Y. Yu, H. Jia, P. Li, N. He, Z. Tang, and H. Fu, "Visualization of Voltage Stability Region of Bulk Power System", Proceedings of International Conference on Power System Technology PowerCon 2002, Vol. 3, 2002, pp. 1665-1668.
- [81] M. A. Pai, "Power System Stability", Amsterdam, The Netherlands: North Holland, 1981.
- [82] Y. Zeng and Y. Yu, "A Practical Direct Method for Determining Dynamic Security Regions of Electrical Power Systems", Proceedings of the International Conference on Power System Technology PowerCon 2002, Vol. 2, 2002, pp. 1270-1274.
- [83] I. A. Hiskens and R. J. Davy, "Exploring the Power Flow Solution Space Boundary", IEEE Transactions on Power Systems, Vol. 16, No. 3, August 2001.
- [84] Y.V. Makarov, V.A. Maslennikov, and D.J. Hill, "Calculation of Oscillatory Stability Margins in the Space of Power System Controlled Parameters", Proc. of the International Symposium on Electric Power Engineering Stockholm Power Tech, Vol. Power Systems, Stockholm, Sweden, June 1995, pp. 416-422.
- [85] Y. V. Makarov and I. A. Hiskens, "A continuation method approach to finding the closest saddle node bifurcation point", Proceedings of the NSF/ECC Workshop on Bulk Power System Voltage Phenomena III, Davos, Switzerland, August 1994. Published by ECC Inc., Fairfax, Virginia.
- [86] K. Huang and H. Yee, "Improved Tangent Hyperplane Method for Transient Stability Studies", Proceedings of the International Conference on Advances in Power System Control APSCOM-91, Vol. 1, 5-8 November, 1991, pp. 363 – 366.
- [87] M. Djukanovic, D. J. Sobajic, and Y.-H. Pao, "Learning Tangent Hypersurfaces for Fast Assessment of Transient Stability, Proceedings of the Second International Forum on Applications of Neural Networks to Power Systems ANNPS '93, 19-22 April 1993, pp. 124 – 129.
- [88] Y. Yu, Y. Zeng, C. Huang, S. T. Lee, and P. Zhang, "A Practical Direct Method for Determining Dynamic Security Regions of Electrical Power Systems by Power Perturbation Analysis", International Conference on Electrical Engineering ICEE2004, July 4-8, 2004, Sapporo, Japan.
- [89] S. A. Sovalov and V. A. Semenov, Emergency Control in Power Systems, Energoatomizdat, Moscow, 1988 – in Russian.
- [90] M. A. El-Sharkawi, R. J. Marks, M. E. Aggoune, D. C. Park, M. J. Damborg, and L. E. Atlas, "Dynamic Security Assessment of Power Systems Using Back Error Propagation Artificial Neuron Networks," Proceedings of the 2nd Symposium on Expert System Applications to Power Systems, Seattle, WA, July 1989.
- [91] R. Kumar, A. Ipahchi, V. Brandwajan, M. A. El-Sharkawi, and G. Cauley, "Neuron Networks for Dynamic Security Assessment of Large Scale Power Systems: Requirements Overview," Proceedings of 1st International Forum on Applications of Neuron Networks to Power Systems, Seattle, WA, July 1991, pp. 65-71.
- [92] A.A. EI-Keib and X. Ma, "Application of Artificial Neural Networks in Voltage Stability Assessment," IEEE Transactions on Power System, Vol. 10, No.4, Nov. 1995, pp. 1890-1896.
- [93] S. Chauhan and M.P. Dava, "Kohonen Neural Network Classifier for Voltage Collapse Margin Estimation," Electric Machines and Power Systems, Vol. 25, No. 6, July 1997, pp. 607-619.

- [94] Y. Mansour, A. Y. Chang, J. Tamby, E. Vaahedi, B. R. Corns, and M. A. El-Sharkawi, "Large Scale Dynamic Security Screening and Ranking Using Neuron Networks," IEEE Transactions on Power Systems, Vol. 12, No. 2, May 1997, pp. 954-960.
- [95] H B Wan and Y H Song, "Hybrid Supervised and Unsupervised Neural Network Approach to Voltage Stability Analysis", Electric Power System Research, Vol. 47, No. 2, 1998, pp.115-122.
- [96] V. R. Dinavahi and S. C. Srivastava, "ANN Based Voltage Stability Margin Prediction", IEEE Power Engineering Society Summer Meeting 2001, Vol. 2, 15-19 July 2001, pp. 1275-1280.
- [97] A. Sittithumwat and K. Tomsovic, "Dynamic Security Margin Estimation Using Artificial Neural Networks", IEEE Power Engineering Society Summer Meeting 2002, Vol. 3, 2002, pp. 1322- 1327.
- [98] M. M. Salamaa, E. M. Saieda, M. M. Abou-Elsaada, and E. F. Gharianyb, "Estimating the Voltage Collapse Proximity Indicator Using Artificial Neural Network", Energy Conversion and Management, Vol. 42, No. 1, January 2001, pp. 69-79.
- [99] H. Hakim, "Application of Pattern Recognition in Transient Security Assessment," Journal of Electrical Machines and Power Systems, Vol. 20, 1992, pp. 1-15.
- [100] L. Wehenkel, Automatic Learning Techniques in Power Systems, Kluwer Academic Publishers, MA, 1998.
- [101] C. Aldea and S. C. Savulescu, "Evaluation of the Stability Reserve of Transelectrica's Transmission System by Using Quickstab Professional", WEC Regional Energy Forum – FOREN 2004, Neptun, 13-17 June 2004.
- [102] P. Dimo, "L'Analyse Nodale des Réseaux D'Énergie", Eyrolles, 1971.
- [103] T. Van Cutsem, C. Vournas, "Voltage Stability of Electric Power Systems", Kluwer Academic Publishers (Power Electronics and Power Systems Series), Boston, 1998.
- [104] T. Van Cutsem and R. Mailhot, "Validation of a Fast Voltage Stability Analysis Method on the Hydro-Quebec System", IEEE Transactions on Power Systems, Vol. 12, No. 1, February 1997.
- [105] F. Paganini, B.C. Lesieutre, "Generic Properties, One-Parameter Deformations, and The BCU Method", IEEE Transactions On Circuits And Systems I: Fundamental Theory And Applications", Vol. 46, No. 6, pp. 760-763, June 1999.
- [106] H.-D. Chiang, C.-C. Chu, and G. Cauley, "Direct Stability Analysis of Electric Power Systems Using Energy Functions: Theory, Applications, and Perspective", Proceedings of the IEEE, 13, 1995, pp. 1497-1529.
- [107] H.-D, Chiang, C.-S. Wang, and H. Li, "Development of BCU classifiers for on-line dynamic contingency screening of electric power systems", IEEE Transactions on Power Systems, 14, 1999, pp. 660-666.
- [108] Y. V. Makarov, Z.-Y. Dong, and D. J. Hill, "A General Method for Small Signal Stability Analysis", IEEE Transactions on Power Systems, Vol. 13, Issue 3, August 1998, pp. 979 – 985.
- [109] Z.-Y. Dong, Y.V. Makarov, and D.J. Hill, "Genetic Algorithms in Power System Small Signal Stability Analysis", Fourth International Conference on Advances in Power System Control, Operation and Management APSCOM-97, Vol. 1, November 11-14, 1997, pp. 342 - 347 (Conference Publication No. 450).

- [110] A.A. Fouad and V. Vittal, *Power System Transient Stability Analysis Using the Transient Energy Function Method*, Prentice Hall, 1991.
- [111] I. Dobson, "Computing a Closest Bifurcation Instability in Multidimensional Parameter Space", *Journal of Nonlinear Science*, Vol. 3, 1993, pp. 307-327.
- [112] Y.V. Makarov, V. A. Maslennikov, and D. J. Hill, "Calculation of Oscillatory Stability Margins in the Space of Power System Controlled Parameters", *Proc. International Symposium on Electric Power Engineering Stockholm Power Tech: Power Systems*, Stockholm, Sweden, 18-22 June, 1995, pp. 416-422.
- [113] Y. V. Makarov, D. J. Hill, and Z.-Y. Dong, "Computation of Bifurcation Boundaries for Power Systems: A New Δ -Plane Method", *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications*, Vol. 47, Issue 4, April 2000, pp. 536 – 544.
- [114] Y.V. Makarov, D. J. Hill, and I. A. Hiskens, "Properties of Quadratic Equations and Their Application to Power System Analysis", *Electrical Power and Energy Systems*, 22 (2000), pp. 313-323.
- [115] M. Fulczyk and M. Sobierajski, "Probabilistic assessment of power system voltage stability margin using P-Q curve", *Proc. 8th International Conference on Probabilistic Methods Applied to Power Systems PSCE'2004*, Iowa State University, Ames, Iowa, September 2004.
- [116] "Voltage Stability/Security Assessment and On-Line Control", EPRI technical report TR-101931-V1-4, Vol. 1-4, 1993.
- [117] "Voltage Stability Analysis Program (VSTAB)", Version 2.1, User's Manual, EPRI Research ProjectRP30400-01, August 1992.
- [118] Xiaokang Xu, M. W. Gustafson, B.P Lam, J. D. Mountford., and S. L. Johnson, "Assessment of Voltage Stability and Real and Reactive Margins Using Advanced Analytical Tools", *Proceedings of International Conference on Power System Technology PowerCon 2002*, Vol. 4, 2002, pp. 2047 – 2051.
- [119] "VSAT – Voltage Security Assessment Tool", Available online:
http://www.dsapowertools.com/downloads/VSAT_Brochure.pdf.
- [120] "PowerWorld Simulator – PVQV", Available online:
<http://www.powerworld.com/products/pvqv.asp>.
- [121] S. Lockwood, R. Navarro, E. Bajrektarevic, P. Burke, S. Kang, P. Ferron, V. Kotecha, S. Kolluri, M. Nagle, S. Lee, P. Zhang, S. K. Agarwal, M. Papic, J. Useldinger, P. C. Patro, L. Arnold, D. Osborn, L. Fan, L. Hopkins, Member, M. Y. Vaiman, and M. M. Vaiman, "Utility Experience Computing Physical and Operational Margins: Part I – Basic Concept and Evaluation", 2004 IEEE PES Power Systems Conference & Exposition, New York, NY, October 10 - 13, 2004.
- [122] S. Lockwood, R. Navarro, E. Bajrektarevic, P. Burke, S. Kang, P. Ferron, V. Kotecha, S. Kolluri, M. Nagle, S. Lee, P. Zhang, S. K. Agarwal, M. Papic, J. Useldinger, P. C. Patro, L. Arnold, D. Osborn, L. Fan, L. Hopkins, Member, M. Y. Vaiman, and M. M. Vaiman, "Utility Experience Computing Physical and Operational Margins: Part II – Application to Power System Studies", 2004 IEEE PES Power Systems Conference & Exposition, New York, NY, October 10 - 13, 2004.
- [123] "BOR-Transient Stability: Dynamic Security Region", Available online:
<http://www.vrenergy.com/docs/bor-ts.pdf>

- [124] M. Papic, M. Y. Vaiman, and M. M. Vaiman, "Determining a Secure Region of Operation for Idaho Power Company", IEEE Power Engineering Society General Meeting, June 12-16, 2005, pp. 2720 – 2725.
- [125] "NEPLAN Electricity - Voltage Stability", Available online: http://www.neplan.ch/sites/en/neplan_elec_calcmod_voltage_stability.asp.
- [126] "CYMVSTAB, Voltage Stability", Available online: <http://www.cyme.com/software/cymvstab/>.
- [127] C.D. Vournas, "Interruptible Load as a Competitor to Local Generation for Preserving Voltage Security", Available online: http://www.transmission.bpa.gov/orgs/opi/power_stability/DirLdContVournas.pdf.
- [128] "On-Line Application of DSATools", Available online: http://www.dsapowertools.com/html/prod_application.php
- [129] "POM - Real Time (POM-RT)", Available online: <http://www.vrenergy.com/pom-rt.htm>.
- [130] E. Hnyilicza, S. T. Y. Lee, F. C. Schweppe, "Steady-State Security Regions: Set-Theoretic Approach," Proceedings of the IEEE PICA Conference, pp. 347-355, 1975.
- [131] S. T. Lee, "Community activity room as a new tool for transmission operation and planning under a competitive power market", IEEE Bologna Power Tech Conference Proceedings, Vol. 4, 23-26 June, 2003.
- [132] "QuickStab at a Glance", Available online: http://www.eciqs.com/QuickStab_at_a_Glance.htm.
- [133] T. Van Cutsem, F. Capitanescu, C. Moors, D. Lefebvre, V. Sermanson, "An Advanced Tool for Preventive Voltage Security Assessment", Proc. 7th Symposium of Specialists in Electric Operational and Expansion Planning (SEPOPE), Curitiba (Brazil), May 2000.
- [134] D. Ernst, D. Ruiz-Vega, M. Pavella, P. Hirsch, D. Sobajic, "A Unified Approach to Transient Stability Contingency Filtering, Ranking and Assessment", IEEE Transactions of Power Systems, Vol. 16, No. 3, August 2001.
- [135] A. Bihain, G. Burt, F. Casamatta, T. Koronides, R. Lopez, S. Massucco, D. Ruiz-Vega, and C. Vournas, "Advanced Perspectives and Implementation of Dynamic Security Assessment in the Open Market Environment", CIGRE 2002, France, August 2002.
- [136] T. Van Cutsem, F. Capitanescu, C. Moors, D. Lefebvre, V. Sermanson, "An Advanced Tool for Preventive Voltage Security Assessment", Proc. 7th Symposium of Specialists in Electric Operational and Expansion Planning (SEPOPE), Curitiba (Brazil), May 2000.
- [137] "Local Capacity Technical Analysis", Overview of Study Report and Preliminary Results, California ISO, June 23, 2005. Available online: <http://www.caiso.com/docs/2005/06/24/2005062408465116859.pdf>
- [138] L. Tobias, "Local Capacity Technical Analysis for Year 2006", Overview of Preliminary Results, California ISO Stakeholder Meeting, June 29, 2005. Available online: <http://www.caiso.com/docs/2005/06/28/2005062816522619093.pdf>
- [139] "Common Information Model (CIM): CIM 10 Version", EPRI, Palo Alto, CA: 2001, 1001976. Available online: <http://www.epriweb.com/public/00000000001001976.pdf>

- [140] S. Greene, I. Dobson, and F. L. Alvarado, "Sensitivity of the Loading Margin to Voltage Collapse with Respect to Arbitrary Parameters", IEEE Transactions on Power Systems, Vol. 12, Issue 1, February 1997, pp. 262 - 272
- [141] S. Greene, I. Dobson, and F. L. Alvarado, "Sensitivity of Transfer Capability Margins with a Fast Formula", IEEE Transactions on Power Systems, Vol. 17, Issue 1, February 2002, pp. 34 – 40
- [142] H. Wan; J. D. McCalley, V. Vittal, "Risk Based Voltage Security Assessment", IEEE Transactions on Power Systems, Vol. 15, Issue 4, Nov 2000, pp. 1247 – 1254.
- [143] S. Iwamoto and Y. Tamura, "A Load Flow Calculation Method for Ill-conditioned Power Systems", Proceedings of the IEEE PES Summer Meeting, Vancouver, British Columbia, Canada, July 1979.
- [144] S. Iwamoto and Y. Tamura, "A Load Flow Calculation Method for Ill-conditioned Power Systems", IEEE Trans on Power Apparatus and Systems, 1981, Vol. PAS-100(4), pp. 1736–1743.
- [145] Y. V. Makarov and Z. Y. Dong, "Eigenvalues and Eigenfunctions", Vol. 6: Computational Science and Engineering, Encyclopedia of Electrical and Electronics Engineering, edited by Professor John G. Webster, John Wiley & Sons, 1999, pp. 208-220, invited.
- [146] J. H. Wilkinson, The Algebraic Eigenvalue Problem, New York: Oxford University Press, 1965.
- [147] A. S. Deif, Advanced Matrix Theory for Scientists and Engineers, 2nd Edition, Abacus Press, Gordon and Breach Science Publishers, Switzerland, 1991.
- [148] P.-A. Löf, G. Andersson, and D. J. Hill, "Voltage Dependent Reactive Power Limits for Voltage Stability Studies," IEEE Trans. Power Systems, Vol. 10, pp. 220-228, February 1995.
- [149] P.-A. Löf, T. Smed, G. Andersson, and D. J. Hill, "Fast Calculation of a Voltage Stability Index," IEEE Trans. Power Systems, Vol. 7, pp. 54-64, February 1992.
- [150] Energy Consulting International website, Available: <http://www.scscce-us.com/>



Arnold Schwarzenegger
Governor

REAL TIME SYSTEM OPERATION 2006 – 2007

Real-Time Voltage Security Assessment
Algorithm's Simulation and Validation Results

Prepared For:
California Energy Commission
Public Interest Energy Research Program

Prepared By:
Lawrence Berkeley National Laboratory

CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

APPENDIX C

Month Year
CEC-500-2008-XXX-APC

Prepared By:

Lawrence Berkeley National Laboratory
Joseph H. Eto, Principal Investigator
Manu Parashar and Abhijeet Agarwal, Electric Power Group
Berkeley, CA 94720
Commission Contract No. 500-02-004
Commission Work Authorization No: MR-041

Prepared For:

Public Interest Energy Research (PIER)
California Energy Commission

Jamie Patterson
Contract Manager

Mike Gravely
Program Area Lead
ENERGY SYSTEMS INTEGRATION

Mike Gravely
Office Manager
ENERGY SYSTEMS RESEARCH




Martha Krebs, Ph.D.
PIER Director

Thom Kelly, Ph.D.
Deputy Director
ENERGY RESEARCH & DEVELOPMENT DIVISION

Melissa Jones
Executive Director

DISCLAIMER

This report was prepared as the result of work sponsored by the California Energy Commission. It does not necessarily represent the views of the Energy Commission, its employees or the State of California. The Energy Commission, the State of California, its employees, contractors and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the uses of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the California Energy Commission nor has the California Energy Commission passed upon the accuracy or adequacy of the information in this report.



ALGORITHM'S SIMULATION & VALIDATION RESULTS

Prepared For:
California Independent System Operator (CA ISO)

Prepared by:
Consortium for Electric Reliability Technology Solutions (CERTS)

Funded By:
California Public Interest Energy Research
Transmission Research Program

Date: January 15, 2008

The work described in this report was coordinated by the Consortium for Electric Reliability Technology Solutions with funding provided by the California Energy Commission, Public Interest Energy Research Program, through the University of California/California Institute of Energy Efficiency under Work for Others Contract No. 500-02-004, MR-041.

PREPARED FOR:

California Independent System Operator

PREPARED BY:

Manu Parashar, Ph.D. - Principal Investigator
Abhijeet Agarwal – Investigator
Electric Power Group, LLC

SPECIAL THANKS TO:

The Contributors of the Various Algorithms Mentioned in this Document:
Dr. Yuri Makarov, PNNL – Principal Consultant
Dr. Ian Dobson, University of Wisconsin - Consultant
Dr. Ning Zhou, PNNL - Consultant

DATE:

January 15, 2008

CONTENTS

1. INTRODUCTION.....	1
2. DESCRIPTION OF THE SYSTEM.....	3
2.1 GENERATORS IN STUDY REGION	3
2.2 LOADS IN THE STUDY REGION	4
2.3 SLACK BUS MODEL	5
3. ALGORITHM RESULTS.....	6
3.1 PARAMETER CONTINUATION METHOD	6
3.2 DIRECT METHOD	9
3.3 BOUNDARY ORBITING METHOD	10
3.4 MARGIN SENSITIVITIES	13
3.5 COLLAPSE PARTICIPATION FACTORS & VOLTAGE SENSITIVITIES.....	14
4. CONCLUSION.....	16

LIST OF FIGURES

Figure 1 - PV Curve for a Load Bus	7
Figure 2 - Load at Mission vs. Load at Santiago	7
Figure 3 - Comparison of Apparent Power Solutions (at PoC) between RTVSA and GE PSLF ..	8
Figure 4 - Comparison of Absolute Voltage Solutions (at PoC) between RTVSA and GE PSLF ..	8
Figure 5 - PoC Calculation by Predictor-Corrector Algorithm	9
Figure 6 - Direct Method's Accelerated PoC Calculation	10
Figure 7 - Security Region by Boundary Orbiting Method	11
Figure 8 - Security Region for Two Loads (For Eigenvalues with Same Signs).....	11
Figure 9 - Testing the Precision of Boundary Orbiting Method	12
Figure 10 - Switching of PV to PQ Buses and Vice-Versa	12
Figure 11 - Lagrangian Multipliers for SDGE cases	13
Figure 12 - RTVSA Output: Hyperplane slices at Carlton Hills and Mission.....	14
Figure 13 - RTVSA Output: PoC in MW for Carlton Hills and Mission	14
Figure 14 - Top Eight Voltage Sensitivities for Stressing Pattern I	15
Figure 15 - Top Eight Angle Sensitivities for Stressing Pattern I	15

LIST OF TABLES

Table 1: Generators in Study Area.....	3
Table 2: Loads in Study Area	5
Table 3: Percentage Difference between RTVSA and GE PSLF Calculations.....	9
Table 4: Patterns of SINK PF (Participation Factors)	13
Table 5: Generator PF at the 3 Units of South Bay (SB) for all Vectors	13

1. INTRODUCTION

The Real-Time Voltage Security Assessment (RTVSA) project is designed to be part of the suite of advanced computational tools for congestion management that is slated for practical applications in California within the next couple of years. Modern voltage assessment methods include the development of such advanced functions as identification of weak elements, automatic selection of remedial actions and automatic development of composite operating nomograms and security regions. With all the research advancements in the area of Voltage Security Assessment over the past few decades, the feasibility of deploying production-grade VSA tools that run in real time and integrate with existing EMS/SCADA systems utilizing results from the state estimator, are increasingly becoming a reality.

Some advanced contemporary real-time applications already promote the idea of using the security regions with the composite boundaries limited by stability, thermal, and voltage constraints. At the same time, the majority of these tools are still based on the static system power flow models and implement such traditional approaches as sink-source system stressing approach, P-V and V-Q analyses, V-Q sensitivity and modal analysis. Unfortunately, many of the most promising methods suggested in the literature have not been implemented yet in the industrial environment, including the state-of-the-art direct method to finding the exact Point of Collapse. Currently there exists no real-time monitoring tool for voltage security assessment. The problems of voltage security will be exacerbated by the effects of multi-transfers through the network. These sets of simultaneous transfers are manifest because of the buying and selling of electric power across the boundaries of control areas. Moreover the point of production and the point of delivery may be in geographically distant locations.

The RTVSA application is based on an extensive analysis of the existing VSA methodologies, by surveying the leading power system experts' opinion worldwide, and also with feedback from industrial advisors. Through this process, a state-of-the-art combination of approaches and computational engines was identified and selected for implementation in this project. The suggested approach is based on the following principles and algorithms:

- Use the concepts of local voltage problem areas and descriptive variables influencing the voltage stability problem in each area. Utilize information about the known voltage problem areas and develop formal screening procedures to periodically discover new potential problem areas and their description parameters.
- Use the descriptive variable space to determine the sequence of stress directions to approximate and visualize the boundary. The stress directions are based on pre-determined generation dispatches and load scaling patterns..
- Use hyperplanes to approximate the voltage stability boundary.
- To calculate the approximating hyperplanes, apply a combination of the parameter continuation techniques and direct methods as suggested in this report. Introduce a sufficient additional security margin to account for inaccuracies of approximation and uncertainties of the power flow parameters.
- Compute the control actions most effective in maintaining a sufficient security margin.

- Produce a list of abnormal reductions in nodal voltages and highlight the elements and regions most affected by potential voltage problems. The list of most congested corridors in the system will be ranked by the worst-case contingencies leading to voltage collapse.

The initial framework of this project was originally formulated by California ISO. The key elements of the suggested approach which are the use of parameter continuation, direct methods, and the hyperplane approximation of the voltage stability boundary were approved by a panel of leading experts in the area in the course of a survey conducted by Electric Power Group, LLC (EPG) in 2005. These concepts were also verified in the course of face-to-face personal meetings with well-known university professors, industry experts, software developers and included email discussions and telephone exchanges. CERTS industrial advisors approved these developments during various CEC Technical Advisory Committee (TAC) meetings conducted in the past years.

In 2005, the project development team successfully implemented the parameter continuation predictor-corrector methods. Necessary improvements were identified and developed. The PSERC parameter continuation program and MATLAB programming language were used in the project. During 2006-07, research work included the implementation of Direct Methods to quickly and accurately determine the exact Point of Collapse (PoC), Boundary Orbiting techniques to trace the security boundary, the investigation of descriptive variables, and the validation of techniques for analyzing margin sensitivities.

The above mentioned techniques have been tested using a ~6000 bus state estimator model covering the entire Western Interconnection and for the Southern California problem areas suggested by California ISO. These results are presented within this report.

2. DESCRIPTION OF THE SYSTEM

The selection of the critical parameters influencing the voltage stability margin and stress directions was conducted based on engineering judgment. The stress directions were defined using the sink-source and balanced loading principles. This means that the generators and the loads participating in each stress scenario are identified, as well as their individual participation factors; the participation factors are balanced so that the total of MW/MVAR increments and decrements is equal to zero. This allows avoiding re-dispatching of the remaining generation. Based on the California ISO recommendation, two study areas were selected for verifying the prototype VSA algorithms: the Humboldt and San Diego problem areas.

The San Diego region within Southern California suffers from voltage stability issues, and hence, forms a good test case. CA ISO provided the EPG team with the 5940 bus (1188 generators) State Estimator generated load flow solution on October 23, 2007 that spans the entire Western Interconnection and includes all buses/lines at or above the 115 kV level. Only elements below the 115kV level and external to the CAISO have been equivalenced. Within the CAISO jurisdiction, some of the lower voltage levels are also covered. Hence, this case precisely models the southern California region which is being studied.

2.1 Generators in Study Region

CA ISO identified the generators (Table 1) comprised in the region which have been used as the sources in the stressing scenarios:

Generating Units	Max Capacity (MW)
South Bay 1	152
South Bay 2	156
South Bay 3	183
South Bay 4	232
Encina 1	106.3
Encina 2	110.3
Encina 3	110.3
Encina 4	306
Encina 5	345.6
Palomar 1X1	180.6
Palomar 2X1	180.6
Huntington Beach 1	226
Huntington Beach 2	226
Huntington Beach 3	225
Huntington Beach 4	227
Alamitos 1	175
Alamitos 2	176
Alamitos 3	322
Alamitos 4	320
Alamitos 5	482
Alamitos 6	481

Table 1: Generators in Study Area

The generation stressing process adopted by the VSA tool involves all the generators, mentioned in table 1 above, with the participation factors calculated based on their maximum generation capacity:

$$\text{Participation Factor of } Gen_k = \frac{P_{gen_max}(Gen_k)}{P_{gen_max}(Total)}$$

This participation factor for generators are dynamic, as they change once a generator reaches its maximum generation limit and is left out of the equation.

2.2 Loads in the Study Region

CA ISO also identified the loads (Table 2) comprised in the San Diego region which have been used as the sinks in the stressing scenarios:

Load Bus	ID	Base Load, $Load_k$ (MW)
Moorpark	1	717
Riohondo	1	714
ValleySC 1	1	704
ValleySC 2	2	704
Santiago	1	699
Chino 1	12	440.93
Chino 2	3	220.07
Los Coches 1	31	25.266
Los Coches 2	32	25.266
Mission 1	30	23.391
Mission 2	31	23.391
Mission 3	32	23.391
Mission 4	33	23.391
Scripps 1	30	21.244
Scripps 2	31	21.244
Scripps 3	32	21.244
Old Town 1	30	21.109
Old Town 2	31	21.109
Old Town 3	32	21.109
Escondido 1	30	20.028
Escondido 2	31	20.028
Escondido 3	32	20.028
Telegraph Canyon 1	41	19.755
Telegraph Canyon 2	42	19.755
Capstrno 1	40	22.946
Capstrno 2	41	22.946
Miramar 1	30	21.231
Miramar 2	31	21.231
Miramar 3	32	21.231
Granite 1	30	21.001
Granite 2	31	21.001
Granite 3	32	21.001
Granite 4	33	21.001

Mesa Rim 1	31	19.838
Mesa Rim 2	32	19.838
Mesa Rim 3	33	19.838
Spring Valley 1	30	19.743
Spring Valley 2	31	19.743
Rose Canyon 1	30	18.739
Rose Canyon 2	32	18.739
Prctrvly 1	41	18.565
Prctrvly 2	42	18.565
Oceanside	31	17.992
Del Mar	32	16.04
La Jolla 1	30	12.962
La Jolla 2	31	12.962
Encinitas 1	20	12.234
Encinitas 2	31	12.234
Encinitas 3	32	12.234
Loveland	1	7.155
Cabrillo 1	30	6.433
Cabrillo 2	31	6.433

Table 2: Loads in Study Area

The participation factors for the loads are calculated using their base case $Load_k$ (in MWs), whereas the load power factor is maintained constant:

$$Participation\ Factor\ of\ Load_k = \frac{Base\ Load_k}{Total\ Load\ of\ the\ Stress\ Vector}$$

2.3 Slack Bus Model

The distributed slack bus model includes all buses in the system except the ones that participate in the stress vector. This model reacts to the active power mismatch that is caused by the stressing procedure and generation contingencies. The participation factors on the distributed slack buses are calculated proportionally to the $P_{gen_{max}}$ of generators. This will approximately simulate the post transient governor power flow. There are a total of 775 generators in the system; hence, the slack buses consist of all the generators other than those switched off and the ones listed under Table 1 above.

3. ALGORITHM RESULTS

The platform that was selected for implementing the RTVSA application includes the PSERC Continuation Power Flow program and MATLAB programming language. Major modifications have been made to the PSERC program to meet the objectives of the VSA project most efficiently. The developed RTVSA algorithms consist of the following steps:

1. Initial system stressing procedure for a given stress direction to reach a vicinity of the Point of Collapse (PoC) in this direction. This step is implemented using the Parameter Continuation Method. This method is one of the most reliable power flow computation methods; it allows approaching the PoC and obtaining the initial estimates of system state variables needed for the subsequent steps. The selected form of the continuation methods includes predictor and corrector steps.
2. The direct method is used then to refine the PoC location along the initial stress direction (the continuation method would require multiple iterations to find the PoC with the required accuracy). At least one of the power flow Jacobian matrix eigenvalues must be very close to zero at the PoC.
3. The inverse iteration method or Arnoldi algorithm is applied to find the left eigenvector corresponding to the zero eigenvalue at PoC.
4. The boundary orbiting procedure is then applied to trace the voltage stability boundary along a selected slice. This procedure is a combination of a predictor-corrector method and the transposed direct method. This code features a voltage/reactive power limit violation check that allows the generator buses to conveniently switch from a generator to a load bus and vice-versa, thus resulting in a significantly smooth and precise nomogram.
5. In case of divergence, the algorithm is repeated starting from Step 1 for a new stress direction predicted at the last iteration of the orbiting procedure. Divergence may be caused, for example, by singularities of the stability boundary shape along the slice.

3.1 Parameter Continuation Method

Parameter continuation predictor-corrector method was chosen as the preferred method capable of reaching the vicinity of point of collapse on the power flow feasibility boundary. The addition of new variables called continuation parameters determines the position of an operating point along some power system stress direction in the parameter space. The predictor step consists of an incremental movement of the power flow point along the state space trajectory, based on the linearization of the model. The corrector step, which follows each predictor step, consists in the elimination of the linearization error by balancing the power flow equations to some close point on the nonlinear trajectory.

The figure below shows the PV curve (real load vs. voltage magnitude plot) for a load bus that was part of the load stress vector in the RTVSA algorithm. The crosses are the predictor-corrector solution points as the algorithm traces the curve to reach the vicinity of the voltage instability point denoted by a star.




Figure 1 - PV Curve for a Load Bus

Similarly, the parameter continuation method can also be illustrated for a 2D stressing scenario for two loads in the San Diego region as shown below:




Figure 2 - Load at Mission vs. Load at Santiago

In order to verify the results of the parameter continuation algorithm, the GE PSLF simulation engine was modified to incorporate the RTVSA stress vectors as well as the participation factor calculations, among other minor changes. The source and the sink

vectors were stressed¹ to reach the point of voltage instability. The result of this comparative study revealed that the Point of Collapse solutions obtained from GE PSLF were indeed very close to that of the RTVSA algorithm as shown in Figures 3, 4 and the comparison chart in Table 3 below:




Figure 3 - Comparison of Apparent Power Solutions (at PoC) between RTVSA and GE PSLF




Figure 4 - Comparison of Absolute Voltage Solutions (at PoC) between RTVSA and GE PSLF

¹ GE PSLF uses Brute-Force method to determine the Point of Collapse solution

Loads	% Difference in Power	% Difference in Voltage
Miraloma	0.04%	0.09%
Vestal	-2.19%	0.22%
Mission	0.02%	0.19%
Telegraph Canyon	-0.01%	0.30%
PRCTRVLY	0.02%	0.33%

Table 3: Percentage Difference between RTVSA and GE PSLF Calculations

3.2 Direct Method

Direct methods for finding the Point of Collapse in a given direction combine a parametric description of the system stress, based on the specified loading vector in the parameter space and a scalar parameter describing a position of an operating point along the loading trajectory and the power flow singularity condition expressed with the help of the Jacobian matrix multiplied by a nonzero right or the left eigenvector that nullifies the Jacobian matrix at the collapse point. Unlike the power flow problem, this reformulated problem does not become singular at the point of collapse and can produce the bifurcation point very accurately.

In principle, the direct method allows finding the bifurcation points without implementing a loading procedure. There is, however, a problem of finding the initial guesses of the state variables and the eigenvector that may be resolved by initially loading the system along the stress direction. By doing so, the initial guess of state variables can be obtained. To evaluate the initial guess for the eigenvector, the inverse iteration method has been recommended to calculate the eigenvector corresponding to the minimum real eigenvalue. The RTVSA code, however, utilizes Arnoldi's algorithm in Matlab software, also known as 'eigs' function, for simulation purposes.

The accuracy and advantage of the Direct Method algorithm has been shown with the help of the two plots below, wherein the Direct Method algorithm (Figure 6) is capable of determining the solution point (Point of Collapse) in one step, compared to 18 iterations taken by the Predictor-Corrector algorithm (figure 5).




Figure 5 - PoC Calculation by Predictor-Corrector Algorithm




Figure 6 - Direct Method's Accelerated PoC Calculation

3.3 Boundary Orbiting Method

After reaching the Point of Collapse (PoC) solution point using a combination of the Continuation Parameter and Direct Method for a specified stress direction, the challenge is to orbit a static voltage stability boundary without repeating the time-consuming Continuation Parameter method along a selected slice. This problem is effectively solved by using the Boundary Orbiting Method algorithm instead, in order to change the stress direction and thus, trace the security region.

The Boundary Orbiting Method (BOM) may face divergence, for instance due to singularities at boundary edges, and hence, the continuation parameter method is repeated for a new stress direction predicted at the last iteration of the orbiting procedure. An example of a voltage security region for two loads in injection space has been shown below in Figure 7.

The slope of the boundary is determined by the sign of the eigenvalue corresponding to the load element in the left eigenvector. The positive slope illustrated in Figure 7 is due to the opposite signs of the eigenvalues of the two loads. Similarly, eigenvalues of the same sign results in a negative slope as shown in Figure 8.




Figure 7 - Security Region by Boundary Orbiting Method




Figure 8 - Security Region for Two Loads (For Eigenvalues with Same Signs)

To test the accuracy of the boundary points obtained by the orbiting procedure, the Continuation Parameter method, along with the Direct Method, was simulated for certain stress directions. A typical test result, as shown in Figure 9 below, reveals the precision of the Boundary Orbiting Method.




Figure 9 - Testing the Precision of Boundary Orbiting Method

The original PSERC Predictor Corrector algorithm was designed to switch generator to load buses (i.e., PV to PQ buses) due to the nature of the one-dimensional stressing process. However, the RTVSA proposed two-dimensional security region calls for a more complex two way switching of the buses from type PV to PQ and back to a PV bus as and when required. Hence, the RTVSA tool was modified to accommodate the required algorithm for conveniently switching the buses, thus generating a precise and smooth security region as shown below:




Figure 10 - Switching of PV to PQ Buses and Vice-Versa

3.4 Margin Sensitivities

The following input data is used as a simple example to examine the RTVSA tool. The stress parameters are sinks internal to Sand Diego region. The sources have been constrained to be the set of three generating units at South Bay. This corresponds to a scenario with no import from SONGS or Encina or from units West of the River or from Mexico. The sinks are loads at Carlton Hills (CHILLS) and Mission (MSSN). The sources are generator shifts at South Bay (SB).

Pattern	Color	CHILLS	MSSN	Code	
I	green	0.99	0.01	1	0
II	red	0.20	0.80	1	1
III	blue	0.01	0.99	0	1

Table 4: Patterns of SINK PF (Participation Factors)²

SB	SB	SB
4519	4520	4524
0.30	0.35	0.35

Table 5: Generator PF at the 3 Units of South Bay (SB) for all Vectors

The Lagrangian Multipliers³ at the PoC can also be interpreted as the left eigenvector at the PoC. Figure 11 shows the comparisons of Lagrangian Multipliers for the three stressing patterns. For example, Pattern II for CHILLS has a multiplier of 0.8, which means that reducing the load at CHILLS by 1 MW would increase the Margin to PoC by 0.8 MW. A bus with a very high Lagrangian Multiplier would signal congestion. Buses with very low Multipliers indicate locations at which power injections have almost no effect on the margin Margin to PoC that are a large electrical metric away from the point of collapse. Indicators, such as the statistics of multipliers that are above a certain threshold, can be used for distinguishing the “non-locality” of the collapse phenomenon.




Figure 11 - Lagrangian Multipliers for SDGE cases

Figure 12 can be considered a geometric validation of the result. The intercepts on the y axis (Mission or MSSN) are smaller for patterns II and III because of the larger Lagrangian multipliers for Mission. Likewise, the intercept on the x axis (Carton Hills or CHILLS) is large for patterns II and III because of the small Lagrange multipliers at Carlton Hills. Stressing

² The load at Carlton Hills is approximately four times smaller than the load at Mission.

³ The coefficients of the hyperplane consist of elements of the *left eigenvector* which can be interpreted as the Lagrangian multipliers corresponding to the parametric sensitivity of the hyperplane. The hyperplanes can be visualized as the constraints in a traditional optimization problem. The intercept on the descriptive variable axis is *inversely proportional* to the Lagrangian multiplier associated with the descriptive variable.

Pattern I has the opposite arrangement - a large Lagrangian multiplier for Carlton Hills and a small multiplier for Mission.




Figure 12 - RTVSA Output: Hyperplane slices at Carlton Hills and Mission

The high values of PoC in the CHILLS-MSSN case in Figure 12 are because the example was meant to illustrate the effects of electrical limits on the transmission of power from the source buses to a set of distributed sink buses. The effects of thermal limits have been temporarily neglected. The sources are also assumed to have an unlimited supply of reactive power. Both of these relaxations show the electrical capacity of the corridors of power flows from South Bay to CHILLS and MSSN. This capacity is far greater than when thermal and power injection limits are enforced.




Figure 13 - RTVSA Output: PoC in MW for Carlton Hills and Mission

3.5 Collapse Participation Factors & Voltage Sensitivities

The participation is computed from the right eigenvector of the Jacobian evaluated at voltage collapse corresponding to the zero eigenvalue. The right eigenvector provides information on the extent to which variables participate during a voltage collapse condition. This determines weak areas and whether the collapse is an angle collapse. (Specifying to the operator which buses participate most in the voltage collapse is useful, but it should also be noted that the buses with the biggest falls in voltage in the collapse may not be the

same as the most effective buses to inject reactive power. The most effective buses to inject reactive power are given by the left eigenvector or Lagrangian multipliers).

Additionally, a byproduct of the continuation method is the availability of the tangent vector at each operating point before reaching the PoC which provides information about the degradation in voltage or angle profiles due to an incremental increase in loading (i.e., Voltage or Angle Sensitivities), assuming that the continuation is parameterized by the margin. In other words, if the Margin to PoC increases (decreases) by 100 MW, then the Voltage Sensitivities will indicate the extent to which the voltages will deteriorate (recover) and are expressed in terms of kV/(100 MW of the Margin to PoC. However, at the PoC, this tangent vector can also be used to approximate the right eigen-vector and therefore provides information on the Collapse Participation Factors. Figure 14 shows these for Stressing Pattern I.




Figure 14 - Top Eight Voltage Sensitivities for Stressing Pattern I

Similar to Voltage Sensitivities one can examine the top ranked Angle Sensitivities. See below for Stress Pattern I.




Figure 15 - Top Eight Angle Sensitivities for Stressing Pattern I

4. CONCLUSION

The RTVSA application is based on an extensive analysis of the existing VSA approaches, by surveying the leading power system experts' opinion worldwide, and also with feedback from industrial advisors. The mismatch between the core power system reliability needs and the availability of the VSA tools was a motivation to design the RTVSA prototype.

The robustness of the Parameter Continuation technique combines with the accuracy of the Direct Method and Boundary Orbiting Method makes the RTVSA prototype a preferred choice for an advanced VSA application.

The underlying concepts are applicable to the simple one-dimensional approach or the more complex multi-directional stressing to explore the entire voltage security region in the parameter space or in full P-Q injection space. The RTVSA algorithms are complex enough to handle system stress/relief by allowing the generator buses to switch to load buses and vice-versa.

Possible follow-on research to the current work could include enhancing the proven and tested methodologies to achieve (1) better approximation; (2) select the number and position of hyperplanes based on desired accuracy; (3) "sliced bread procedure" to systematically trace the security boundary in multi-dimensional space; and (4) compute transmission reliability margins for voltage collapse from margin sensitivities. Other good additions to the conducted research would be to evaluate non-iterative voltage stability analysis techniques for tracing the voltage stability boundary as well as researching methodologies to screen the power system to detect places vulnerable to voltage collapse and help select descriptor parameters.



Arnold Schwarzenegger
Governor

REAL TIME SYSTEM OPERATION 2006 – 2007

Real-Time Voltage Security Assessment Summary Report

Prepared For:
California Energy Commission
Public Interest Energy Research Program

Prepared By:
Lawrence Berkeley National Laboratory

CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

APPENDIX D

Month Year
CEC-500-2008-XXX-APD

Prepared By:

Lawrence Berkeley National Laboratory
Joseph H. Eto, Principal Investigator
Berkeley, CA 94720
Manu Parashar and Wei Zhou, Electric Power Group
Dan Trudnowski, Montana Tech
Yuri Makarov, Pacific Northwest National Laboratory
Ian Dobson, University of Wisconsin, Madison
Commission Contract No. 500-02-004
Commission Work Authorization No: MR-041

Prepared For:

Public Interest Energy Research (PIER)
California Energy Commission

Jamie Patterson
Contract Manager

Mike Gravely
Program Area Lead
ENERGY SYSTEMS INTEGRATION

Mike Gravely
Office Manager
ENERGY SYSTEMS RESEARCH

Martha Krebs, Ph.D.
PIER Director


Thom Kelly, Ph.D.
Deputy Director
ENERGY RESEARCH & DEVELOPMENT DIVISION

Melissa Jones
Executive Director



DISCLAIMER

This report was prepared as the result of work sponsored by the California Energy Commission. It does not necessarily represent the views of the Energy Commission, its employees or the State of California. The Energy Commission, the State of California, its employees, contractors and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the uses of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the California Energy Commission nor has the California Energy Commission passed upon the accuracy or adequacy of the information in this report.



SUMMARY REPORT

Prepared For:

California Independent System Operator (CA ISO)

Prepared by:

Consortium for Electric Reliability Technology Solutions (CERTS)

Funded By:

**California Public Interest Energy Research
Transmission Research Program**

Revised June 26, 2008

Acknowledgement

This activity was lead by Manu Parashar, Electric Power Group (EPG), with assistance from research performers Abhijeet Agarwal, EPG and Yuri Makarov, Pacific Northwest National Laboratory and Ian Dobson, University of Wisconsin.

Citation

Parashar, Manu, etal. Consortium for Electric Reliability Technology Solutions (CERTS). 2008. Real-Time Voltage Security Assessment Summary Report. California Energy Commission, PIER Transmission Research Program. CEC-500-2008-XXX.

Preface

The Public Interest Energy Research (PIER) Program supports public interest energy research and development that will help improve the quality of life in California by bringing environmentally safe, affordable, and reliable energy services and products to the marketplace.

The PIER Program, managed by the California Energy Commission (Energy Commission), conducts public interest research, development, and demonstration (RD&D) projects to benefit California.

The PIER Program strives to conduct the most promising public interest energy research by partnering with RD&D entities, including individuals, businesses, utilities, and public or private research institutions.

PIER funding efforts are focused on the following RD&D program areas:

- Buildings End-Use Energy Efficiency
- Energy Innovations Small Grants
- Energy-Related Environmental Research
- Energy Systems Integration
- Environmentally Preferred Advanced Generation
- Industrial/Agricultural/Water End-Use Energy Efficiency
- Renewable Energy Technologies
- Transportation

Real Time System Operations (RTSO) 2006 - 2007 is the final report for the Real Time System Operations project (contract number 500-03-024 MR041 conducted by the Consortium for Electric Reliability Technology Solutions (CERTS). The information from this project contributes to PIER's Transmission Research Program.

For more information about the PIER Program, please visit the Energy Commission's website at www.energy.ca.gov/pier or contact the Energy Commission at 916-654-5164.

Table of Contents

Preface	ii
1.0 Introduction.....	1
2.0 Voltage Security Assessment (VSA) Surveys	3
2.1. Expert Recommendations	3
2.2. Industry Best Practices	6
3.0 CERTS RTVSA Framework and Algorithms.....	9
3.1. Real-Time Voltage Security Assessment Framework	9
3.2. CERTS RTVSA Algorithm Overview	11
3.3. Some Special Features of the RTVSA Application	15
3.4. Algorithm Simulation and Validation Results.....	17
3.5. Direct Method.....	20
3.6. Boundary Orbiting Method	21
4.0 CERTS RTVSA Functional Specification.....	25
4.1. On-Line RTVSA Functional Overview.....	25
4.2. System Architecture.....	28
4.3. Visualization and User Interaction	31
5.0 Conclusion.....	33
Appendices	
Appendix A, Survey 1 Results Table	
Appendix B, Survey 2 Results Table	
Appendix C, RTVSA Functional Specification Summary Table	

List of Figures

Figure 1: Multi Year Development Roadmap for California ISO Voltage Security Assessment (VSA) Project.....	5
Figure 2: Conceptual view of Voltage Security Region.....	10
Figure 3: RTVSA Algorithms Flowchart.....	14
Figure 4: PV Curve for a Load Bus.....	18
Figure 5: Load at Mission vs. Load at Santiago.....	19
Figure 6: Comparison of Power Solutions (at PoC) between RTVSA & GE PSLF.....	20
Figure 7: Comparison of Voltage Solutions (at PoC) between RTVSA & GE PSLF.....	20
Figure 8: PoC Calculation by Predictor-Corrector Algorithm.....	21
Figure 9: Direct Method's Accelerated PoC Calculation.....	21
Figure 10: Security Region by Boundary Orbiting Method.....	22
Figure 11: Security Region for Two Loads (For Eigenvalues with Same Signs).....	23
Figure 12: Testing the Precision of Boundary Orbiting Method.....	24
Figure 13: Switching of PV to PQ Buses and Vice-Versa.....	24
Figure 14: RTVSA System Architecture.....	29

List of Tables

Table 1: Survey 1 – University & Industry Recommendations on VSA Project.....	3
Table 2: Survey 2 – Evaluation of Existing RTVSA Tools & Industry’s Best Practices.....	8
Table 3: Percentage Difference between RTVSA and GE PSLF Calculations.....	20
Table 4: Summary of RTVSA Capabilities.....	27

1.0 Introduction

Over the past 40 years, more than 30 major blackouts worldwide were related to voltage instability and collapse. Among them, at least 13 voltage-related blackouts happened in the United States, including two major blackouts in the Western Interconnection in 1996 and a wide-scale blackout in the Eastern Interconnection in 2003. Several times, the blackout investigation teams indicated the need for on-line power flow and stability tools and indicators for voltage performance system-wide in a real-time. These recommendations are not yet completely met by the majority of U.S. power system control centers. The gap between the core power system voltage and reliability assessment needs and the actual availability and use of the voltage security analysis tools was a motivation to come forward with this project. The project's aim was to develop state-of-the-art methodologies, prototypes, and technical specifications for the Real-Time Voltage Security Assessment (RTVSA) tools. These specifications can be later used by selected vendors to develop industrial-grade applications for California ISO, other California Control Area Operators, and utilities in California.

An extensive analysis of existing VSA approaches was conducted. This included research by Consortium for Electric Reliability Technology Solutions (CERTS), surveys from the leading experts' opinion worldwide, feedback from industrial advisors, and brainstorm meetings with the projects' industry and academia consultants. A state-of-the-art combination of approaches and computational engines was identified and selected for implementation in this project. Subsequently, a multi-year project roadmap was developed which has guided the CERTS research on evaluating and demonstrating the recommended approaches on the California ISO test cases.

The initial framework of this project was originally formulated in close consultation with the California ISO. The key elements of the suggested approach which are the use of parameter continuation, direct methods, and the hyperplane approximation of the voltage stability boundary were approved by a panel of leading experts in the area in the course of a survey conducted by Electric Power Group, LLC (EPG) at the project's onset in 2005. These concepts were also verified in the course of face-to-face personal meetings with well-known university professors, industry experts, software developers, and included email discussions and telephone exchanges. CERTS industrial advisors approved these developments during various CEC Technical Advisory Committee (TAC) meetings conducted in the past years.

In 2005, the project development team successfully implemented the parameter continuation predictor-corrector methods. Necessary improvements were identified and developed. The Power Systems Engineering Research Center (PSERC) parameter continuation program and MATLAB programming language were used in the project. During 2006-07, research work included the implementation of Direct Methods to quickly and accurately determine the exact Point of Collapse (PoC), Boundary Orbiting techniques to trace the security boundary, the investigation of descriptive variables, and the validation of techniques for analyzing margin sensitivities. These techniques were tested using a ~6000 bus state estimator model covering the entire Western Interconnection and, for the Southern California problem, areas suggested by California ISO, and results were reported.

At the completion of the project, a functional specification document was developed which describes the design, functional and visualization requirements for a Real-Time Voltage Security Assessment (RTVSA) tool, as well as California ISO's preferences on certain implementation and visualization techniques.

2.0 Voltage Security Assessment (VSA) Surveys

2.1. Expert Recommendations

CERTS/EPG formulated a survey to reach out to the experts in the field of voltage security for comments, information, suggestions, and recommendations related to the VSA project. The surveys were sent to fifty-one experts in universities and in the power industry. Sixteen reviewers responded and their responses are summarized in Table 1. Eight of these respondents are from the power industry and eight are from academia. Four proposals for commercial software were also received from Bigwood, V&R, NETSSS, and ECI.

ISSUE	RESPONSES / COMMENTS	CONCLUSION
Voltage Security Assessment (VSA) (Hyperplanes for security regions)	<ul style="list-style-type: none"> - Online hyperplane possible - Not as unproven as interior point methods. - Ideally suited for phenomena that is local. 	Hyperplanes well suited for VSA
Methodology for computing hyperplanes	<ul style="list-style-type: none"> - Loading & Generation Direction needed. - Stress path until voltage collapses. - At collapse, determine local boundary. 	Use left eigenvector approach
Direct versus Time-domain methods	<ul style="list-style-type: none"> - Time domain iterative methods are proven and robust, capable of handling intermediate discrete actions/events. Example: Generator limits being reached Direct methods rely on simplistic models 	Direct Method could be used for fine-tuning the security boundaries after an iterative set of continuation power flows
Weak elements identification	<ul style="list-style-type: none"> - Voltage collapses are concentrated in certain regions in the sense that the voltage falls more in those regions. There is no single element that collapses. That is, voltage collapses occurs system wide with varying participation from all the system buses. 	The participation is computed from the right eigenvector of the Jacobian evaluated at voltage collapse corresponding to the zero eigenvalue.

Table 1: Survey 1 – University & Industry Recommendations on VSA Project

The consensus opinion was that the hyperplane approach to defining security regions was ideally suited for voltage instability assessment. Voltage instability is more of a local area/region phenomenon. Several participants in the survey felt that full blown time domain classifiers should augment the algorithms that utilize Direct Methods. An engineer from a utility in Northern California said that it was not clear how switching conditions could be revealed without “time domain” simulations. A utility from the South shared its experience that it was unable to develop suitable production metrics because of the integration of both continuous (load growth) and non-continuous (contingency) factors into a single metric. The computational methods to be used in VSA could be grouped into two broad classes – the Iterative Approach using Continuation Power Flows and the Direct Method. The Direct Method does not provide information on any discontinuous events when the stress parameter is increased. These discontinuous events occur when a thermal, voltage or reactive limit is reached.

The majority of responses favor the use of the hyperplane approach in determining Voltage Security Assessment. Also, the majority of respondents did not see hyperplanes suitable for determining Dynamic Voltage Assessment at this time. Small Signal Stability Analysis was considered to be a good first step for Wide Area Stability Monitoring and assessment using phasor measurements.

In summary, the primary recommendation for Real Time Voltage Security Assessment tool is to use the hyperplane approach in computing the corresponding security regions. Others are:

The computational engine for California ISO’s VSA is recommended to be the Continuation Power Flow. This tool has been tested and proven by several researchers in commercial and non-commercial software.

An alternate recommendation is a hybrid approach, where a Direct Method could be used for fine-tuning the security boundaries after an iterative set of continuation power flows.

These recommendations were incorporated into the overall proposed roadmap and project plan for the project (Figure 1), which was formulated through discussions with California ISO and through active participation of CERTS performers Dr. Yuri Makarov and Prof. Ian Dobson over conference calls and in meetings.




Figure 1: Multi Year Development Roadmap for California ISO Voltage Security Assessment (VSA) Project

2.2. Industry Best Practices

During the course of the project, a second survey was conducted among the vendors and utilities – the focus here was to evaluate existing power system voltage security tools and to identify the industry’s best practices with the following goals:

- Survey interfaces and protocols that are currently used to import/export/exchange data, such as OPC or CIM/XML, in a power system simulation software, and thus, choose the one most appropriate for Real Time Voltage Security Assessment (RTVSA).
- Review available visualization capabilities within existing applications; identify the best available solutions and gaps between what is available and RTVSA vision.
- Assess processing capabilities of available applications, and recommend improvements for the RTVSA tool.

Several vendors and utilities responded to the survey request, providing valuable information about their tool’s interoperability, processing and visualization capabilities. Subsequently, the CERTS team followed up telephonically with the participants in order to better understand their system. The following conclusions have been drawn based on the information provided by utilities and vendors through the RTVSA survey. The detailed survey responses are provided in Appendix B.

Interfacing Capabilities

→	Tool type	The tools are essentially standalone applications; however, they are 'transformed' into an EMS/SCADA (or on-line) application by automatically triggering the tool for each valid SE solution.
→	Data integration	<p>For real-time data, flat text files are predominantly in use that are either copied to shared folder or transferred via FTP. Service-Oriented Architecture (SOA) and Enterprise Message Bus technologies are being developed by users.</p> <p>Historical data are stored either in historians or in shared folders. Some tools (such as V&R's POM) back up input data for offline studies, such as trend analysis or post-mortem analysis.</p>
→	Data source	State Estimator
→	External data input & output formats	Flat text files (e.g., pss/e, pslf) are favored by most utilities and vendors. CIM/XML input is optional only for V&R's POM and Powertech's VSAT applications.
→	Input data model	<p>Both node/breaker and bus/branch is common</p> <p><i>Comment: Typically, a topology processor, which is internal to tools, converts a node/breaker model to bus/branch for power flow calculations. Hence, a node/breaker model is redundant unless it proves visually useful to operators and dispatchers.</i></p>

Processing Capabilities

→	Simulations	<ul style="list-style-type: none">- Bigwood's VSA&E and V&R's POM can perform all simulations (mentioned in the survey) in real time- ECI's QuickStab perform all the simulations, though most of them run manually- Bigwood's VSA&E, V&R's POM, and Powertech's VSAT are the only ones to display operating nomograms
---	-------------	--

→	Maximum number of buses supported	Sufficiently large
→	PF simulation speed	Less than a second for the majority (although this may vary depending on the number of buses, contingencies, processor speed, etc.)
→	<i>Recommendations (for a real-time tool)</i>	Monitoring thermal overloads, voltage deviation, voltage stability and dynamic security (including the one based on phasor measurement data)
Visualization Capabilities		
→	Common display formats	<ul style="list-style-type: none"> - Tabular (contingency list, corrective actions, voltage profiles, weak elements) - Graphical (bar charts for voltages, Mvar reserves, etc. , PV plots, bubble plots) - Geographical (voltage contours, interface flows, one-line diagrams)
→	Most useful visualization capabilities	<ul style="list-style-type: none"> - Operating nomograms for various system parameters (such as generators, loads & import/export limits) - Limiting contingencies - Security margins - Transfer limits bar charts - Graphical Interface flows - PV plots - SCADA trending charts - Alarming capability
→	Vendors have stated that their VSA application <i>is</i> being used by both real-time operators and dispatchers	

Table 2: Survey 2 – Evaluation of Existing RTVSA Tools & Industry’s Best Practices

3.0 CERTS RTVSA Framework and Algorithms

The RTVSA application is based on an extensive analysis of the existing VSA approaches, by surveying the leading power system experts' opinion worldwide, and also with feedback from industrial advisors, to address many of the limitations of existing tools such as:

Many existing tools use *the power flow existence criterion* to compute the boundary. This has the dangerous potential to overestimate the actual voltage security margin in situations where the saddle node bifurcation, Hopf bifurcation, or transient stability conditions are violated before the power flow equations become divergent.

The limitations of P-V/Q-V plots that represent the load versus the voltage of a selected bus become apparent when voltage collapses are not concentrated in a few buses. Some voltage collapses are regional or involve the entire system. P-V curves are calculated using the power flow solutions by step-by-step increasing the loads. The "nose point" of the curve corresponds to the maximum power which can be delivered to the load. The bus voltage at this point is the critical voltage. If the voltage of one particular bus approaches the nose point faster compared to the other buses, it is assumed that the system voltage stability margin is limited by this bus. This information does not capture the extent to which all the variables participate in the voltage collapse.

Many of the existing voltage security applications are run in an offline analysis mode. The additional constraint that the voltage security assessment be performed in real time imposes new speed/performance requirements that can only be met through a combination of the state-of-the-art algorithms embedded within an innovative framework.

The mismatch between the core power system reliability needs and the availability of the VSA tools was a motivation to design the following special features into the RTVSA application.

3.1. Real-Time Voltage Security Assessment Framework

The most promising method for determining the available voltage stability margin in real time is based on piece-wise linear approximation of the voltage collapse boundary in coordinates of independent power system parameters (i.e. Hyperplanes). The approximating conditions are calculated off-line as a set of inequalities specific for each analyzed contingency:

$$\begin{cases} a_{11}P_1 + \dots + a_{1n}P_n + b_{11}Q_1 + \dots + b_{1n}Q_n \leq c_1 \\ a_{21}P_1 + \dots + a_{2n}P_n + b_{21}Q_1 + \dots + b_{2n}Q_n \leq c_2 \\ \dots \\ a_{m1}P_1 + \dots + a_{mn}P_n + b_{m1}Q_1 + \dots + b_{mn}Q_n \leq c_m \end{cases} \quad (1)$$

The number of constraints m and the number of parameters P and Q included in each constraint are expected to be limited. Each face of the region approximates a part of the nonlinear region's boundary. The advantages to the proposed approach are:

- Fast and Convenient assessment: Having constraints (1) pre-calculated offline for each analyzed contingency, it is very easy to quickly determine in real time:
 - Whether the operating point is inside or outside the security region (by making sure that all approximating inequalities are satisfied)
 - Which constraints are violated (by identifying violated inequalities), and
 - What the most limiting constraints are (by calculating the distance from the current operating point to the approximating planes – see below).




Figure 2: Conceptual view of Voltage Security Region

- Easy-to-Calculate Security Margin: The distance d from the current operating point A to the nearest constraint face B determines the MVA security margin¹:

$$d_i = \frac{a_{i1}P_1^0 + \dots + a_{in}P_n^0 + b_{i1}Q_1^0 + \dots + b_{in}Q_n^0 - c_i}{\sqrt{a_{i1}^2 + \dots + a_{in}^2 + b_{i1}^2 + \dots + b_{in}^2}}$$

Where the current operating point $A = [P_1^0, \dots, P_n^0, Q_1^0, \dots, Q_n^0]$

The percent margin for each constraint i can be obtained based on a pre-established minimum admissible “MVA distance to instability” d^* :

¹ We assume that the region is convex.

$$d_i^{\%} = \min \left\{ \begin{array}{l} \frac{d_i}{d^*} \times 100\% \\ 100\% \end{array} \right\}$$

The resulting stability margin corresponds to the minimum distance, i.e. the distance to the closest constraint face:

$$D = \min_{(i)} d_i^{\%}$$

- Online computation of Parameter Sensitivities: The *normalized coefficients* of the set of hyperplane equations denoted by (1) are sensitivities that can be interpreted in several ways. These coefficients can be calculated trivially by the following mathematical expressions:

$$\frac{\partial D}{\partial P_j^0} = \frac{a_{ij}}{\sqrt{a_{i1}^2 + \dots + a_{in}^2 + b_{i1}^2 + \dots + b_{in}^2}}$$

$$\frac{\partial D}{\partial Q_j^0} = \frac{b_{ij}}{\sqrt{a_{i1}^2 + \dots + a_{in}^2 + b_{i1}^2 + \dots + b_{in}^2}}, j = 1, \dots, n$$

where D is critical vector $\vec{D} = \vec{AB}$ - see Figure 2.

The different representations of these coefficients include:

1. The locations in the network where the most sensitive controls are needed
2. The left eigenvector nullifying the power flow Jacobian matrix at the point of collapse
3. This eigenvector has an identical representation to *Lagrangian multipliers*² at PoC

3.2. CERTS RTVSA Algorithm Overview

The important concepts that are used in the CERTS RTVSA algorithm are stress direction (procedure), descriptor variables, state space, and parameter space.

The *stress direction (procedure)* specifies how the system parameters change from their base case values as a function of a scalar amount of stress. For example, generation and load participation factors can define a stress direction and the amount of generation can give a scalar amount of stress --- these together can specify the changes in the bus power injections that is, any system state along the stress direction can be associated with certain value of a stress parameter such as

² This representation is well suited to imply a 'Locational price' for an ancillary service such as the distance to voltage collapse specified in terms of dollars. Lagrangian multipliers specify the sensitivity of the constraints so that a constrained optimization problem becomes an unconstrained optimization problem – see Eric W. Weisstein. "Lagrange Multiplier" from MathWorld - A Wolfram Web Resource. <http://mathworld.wolfram.com/LagrangeMultiplier.html>

the percent of the total load increase in an area. Each specific direction and value of the stress parameter uniquely defines the system state. This implies certain fixed patterns for varying the system generation and loads (for example, load participation factors, sequence of generator dispatch, and others – detailed examples can be found in this report). Stress directions can include some local system stresses addressing a particular voltage stability problem area, and global stresses such as the total load growth and the corresponding generation redispatch in the system.

Descriptor variables reflect the most influential or understandable combinations of parameters (or derivative parameters) that influence the voltage stability margin. Examples are the total area load, power flows in certain system paths, total generation, and others (the system operating nomograms' coordinates are good examples of descriptor parameters). In the simplest case, descriptor parameters can include some primary system parameters such as nodal voltages and nodal power injections. Descriptor variables help to adequately address global and local voltage stability margins without involving thousands of primary parameters. Certain subsets of descriptor variables can correspond to some local voltage stability problem areas.

The *state space* includes all system nodal voltage magnitudes and voltage phase angles.

The (independent) *parameter space* includes all nodal power injections (for P-Q buses) and real power injections and voltage magnitudes (for P-V buses).

The voltage stability boundary can be comprehensively (and uniquely) described in the parameter space (and the state space), but in this case the description would involve thousands of variables. Descriptor parameters help to reduce the dimensionality of the problem by considering the most influential combinations of parameters (or derivative parameters).

The *descriptor parameter space* includes all descriptor parameters. Since the points in the descriptor parameter space can be mapped into the points of the parameter and state spaces in many different ways (because of the limited number of descriptor parameters space dimensions), certain fixed system stress procedures should be introduced to make this mapping adequate and unique.

The developed RTVSA algorithms consist of the following steps (which has been illustrated in a flowchart under Figure 3):

1. **Initial system stressing procedure** for a given stress direction **to reach a vicinity of the Point of Collapse (PoC)** in this direction. This step is implemented using the Parameter Continuation Method. The Continuation Method is one of the most reliable power flow computation methods; it allows approaching the PoC and obtaining the initial estimates of system state variables needed for the subsequent steps. The selected form of the continuation methods includes predictor and corrector steps.
2. **The direct method** is used then **to refine the PoC location** along the initial stress direction (the continuation method would require multiple iterations to find the PoC with the required accuracy). At least one of the power flow Jacobian matrix eigenvalues must be very close to zero at the PoC.

3. **The inverse iteration method or Arnoldi algorithm is applied to find the left eigenvector corresponding to the zero eigenvalue at PoC.** The left eigenvectors are used to build the set of approximating hyperplanes.
4. **The stability orbiting procedure is then applied to trace the voltage stability boundary along a selected slice.** This procedure is a combination of a predictor-corrector method and the transposed direct method.
5. In case of divergence, the algorithm is repeated starting from Step 1 for a new stress direction predicted at the last iteration of the orbiting procedure. Divergence may be caused, for example, by singularities of the stability boundary shape along the slice.
6. For a given voltage stability problem area and the corresponding descriptor parameters, **the “sliced bread procedure” is applied to explore the voltage stability boundary and build the set of approximating hyperplanes.**




Figure 3: RTVSA Algorithms Flowchart

The developed RTVSA algorithm performs voltage security assessment calculations under both offline and real-time modes.

The *offline calculations* produce an approximated voltage stability region (a 2-D, 3-D, or a higher dimensional nomogram) based on multi-directional stressing situation presenting the interaction and tradeoffs between different stressing directions. The pre-calculated voltage stability region is an inner intersection of stability regions for the set of user-specified contingencies. The offline calculations should be conducted periodically (ideally, several times a day) to update the approximated voltage security region and to reflect the most recent changes in the system.

The *real-time calculations* are conducted in real time (after each converged State Estimation cycle) to determine the current or future position of the system operating point against the walls of the approximated voltage stability region, and to calculate such essential security information as the available stability margin (distance to instability), the most limiting contingency, the most dangerous system stress directions, weak elements causing potential instability, and the recommended preventive and enhancement controls that help to increase the margin in an efficient way.

Note: The *offline* calculations can also be conducted in real time if a few stressing directions representative of the actual system loading, given by the real time dispatch schedule, planned outages, and load forecast, and/or predetermined stresses are to be considered separately. In such a scenario, the available security margins, distance to instability, the most limiting contingency, weak elements causing potential instability, and the recommended preventive and enhancement controls that help to increase the margin in an efficient way can be obtained in real-time using the algorithms proposed in this document.

3.3. Some Special Features of the RTVSA Application

The underlying concepts are applicable to the simple one-dimensional approach or the more complex multi-directional stressing to explore the entire voltage security region in the parameter space or in full P-Q injection space.

The RTVSA tool has the ability of analyzing the effects of multiple transfers. There are no restrictions in distributing the source and sink over a large number of buses in geographically distant locations in the system. A non-local treatment of congestion³ is crucial because conservatism causes costly curtailment of profitable power transfers and a suboptimal use of the transmission system.

³ Congestion can be quantified more precisely as the combined effect of multiple power transfers exceeding the transfer capability of the transmission system.

The RTVSA algorithm⁴ in the initial stages uses the parameter continuation method, which is one of the most reliable power flow methods capable of reaching the point of collapse on the power flow feasibility boundary. New variables called the continuation parameters are added and represents a position of a power flow operating point along some power system stress direction in the parameter space. The *predictor step* consists in an incremental moving of the power flow operating point along the state space trajectory, based on the linearization of the problem. The *corrector step*, that follows each predictor step, consists in elimination of the linearization error by balancing the power flow equations to some close point on the nonlinear trajectory.

The RTVSA algorithm also uses Direct methods for finding the PoC quickly and accurately, which combines the parametric description of the system stress and the power flow singularity condition expressed with the help of the Jacobian matrix multiplied by a nonzero right or the left eigenvector that nullifies the Jacobian matrix at the collapse point. In principle, the Direct Method avoids implementing a loading procedure. There may be problems of finding the initial guesses of the state variables and the eigenvector that may be resolved by initial loading the system along the stress direction. By doing so, the initial guess of variables can be obtained. Many inaccuracies of the step-by-step loading methods that do not exactly converge to the PoC will be avoided by implementing the Direct Method. There are savings in computational expenses because of the absence of iterations even though the Direct Method solves a problem almost double in dimension to the step-by-step loading methods.

The RTVSA algorithm determines the “right eigenvector” and the “left eigenvector” at the PoC. The weak elements are based on the right eigenvector and provide the extent to which variables participate in voltage collapse. This determines weak areas and also whether the collapse is an angle collapse. Large sensitivities of the margin to PoC indicate controllable parameters. These are represented by the left eigenvector and can be quantified for suitable corrective action by ranking the increase in margin with respect to a unit MW or MVAR in generator response.

Sensitivity computations relate changes in data to changes in transfer capability. The uncertainty in the transfer capability due to uncertainty in the data can be quantified to reveal which data is significant in the transfer calculations.

4 The RTVSA algorithm falls into the class of non-divergent power flow methods that manipulate the step size of the Newton-

Raphson method. If the power flow mismatches indicate divergence, the step size is reduced until convergence occurs or the step

becomes very small. A very small step size is considered to be an indicator of the point of collapse.

3.4. Algorithm Simulation and Validation Results

The selection of the critical parameters influencing the voltage stability margin and stress directions was conducted based on engineering judgment. The stress directions were defined using the sink-source and balanced loading principles. This means that the generators and the loads participating in each stress scenario are identified, as well as their individual participation factors; the participation factors are balanced so that the total of MW/MVAR increments and decrements is equal to zero. This allows avoiding re-dispatching of the remaining generation. Based on the California ISO recommendation, two study areas were selected for verifying the prototype VSA algorithms: the Humboldt and San Diego problem areas.

The San Diego region within Southern California suffers from voltage stability issues, and hence, forms a good test case. California ISO provided the CERTS team with the 5940 bus (1188 generators) State Estimator generated load flow solution on October 23, 2006 that spans the entire Western Interconnection and includes all buses/lines at or above the 115 kV level. Only elements below the 115 kV level and external to the California ISO have been equivalenced. Within the California ISO jurisdiction, some of the lower voltage levels are also covered. Hence, this case precisely models the southern California region being studied.

The generation stressing process adopted by the VSA tool involves generators with the participation factors calculated based on their maximum generation capacity:

$$\textit{Participation Factor of } Gen_k = \frac{P_{gen_max}(Gen_k)}{P_{gen_max}(Total)}$$

This participation factor for generators are dynamic, as they change once a generator reaches its maximum generation limit and is left out of the equation.

The participation factors for the loads are calculated using their base case $Load_k$ (in MWs), whereas the load power factor is maintained constant:

$$\textit{Participation Factor of } Load_k = \frac{Base\ Load_k}{Total\ Load\ of\ the\ Stress\ Vector}$$

The distributed slack bus model includes all buses in the system except the ones that participate in the stress vector. This model reacts to the active power mismatch that is caused by the stressing procedure and generation contingencies. The participation factors on the distributed slack buses are calculated proportionally to the P_{gen_max} of generators.

Parameter continuation predictor-corrector method was chosen as the preferred method capable of reaching the vicinity of point of collapse on the power flow feasibility boundary. The addition of new variables called continuation parameters determines the position of an operating point along some power system stress direction in the parameter space. The predictor step consists of an incremental movement of the power flow point along the state space trajectory, based on the linearization of the model. The corrector step, which follows each predictor step, consists in the elimination of the linearization error by balancing the power flow equations to some close point on the nonlinear trajectory.

Figure 4 below shows the PV curve (real load vs. voltage magnitude plot) for a load bus that was part of the load stress vector in the RTVSA algorithm. The crosses are the predictor-corrector solution points as the algorithm traces the curve to reach the vicinity of the voltage instability point denoted by a star.




Figure 4: PV Curve for a Load Bus

Similarly, the parameter continuation method can also be illustrated for a 2D stressing scenario for two loads in the San Diego region as shown in Figure 5 below:





Figure 5: Load at Mission vs. Load at Santiago

In order to verify the results of the parameter continuation algorithm, the GE PSLF simulation engine was modified to incorporate the RTVSA stress vectors as well as the participation factor calculations, among other minor changes. The source and the sink vectors were stressed⁵ to reach the point of voltage instability. The result of this comparative study revealed that the Point of Collapse solutions obtained from GE PSLF were indeed very close to that of the RTVSA algorithm as shown in Figure 6, Figure 7 and the comparison chart in Table 3 below:



⁵ GE PSLF uses Brute-Force method to determine the Point of Collapse solution

Figure 6: Comparison of Power Solutions (at PoC) between RTVSA & GE PSLF




Figure 7: Comparison of Voltage Solutions (at PoC) between RTVSA & GE PSLF

Loads	% Difference in Power	% Difference in Voltage
Miraloma	0.04%	0.09%
Vestal	-2.19%	0.22%
Mission	0.02%	0.19%
Telegraph Canyon	-0.01%	0.30%
PRCTRVLY	0.02%	0.33%

Table 3: Percentage Difference between RTVSA and GE PSLF Calculations

3.5. Direct Method

Direct methods for finding the Point of Collapse in a given direction combine a parametric description of the system stress, based on the specified loading vector in the parameter space and a scalar parameter describing a position of an operating point along the loading trajectory and the power flow singularity condition expressed with the help of the Jacobian matrix multiplied by a nonzero right or the left eigenvector that nullifies the Jacobian matrix at the collapse point. Unlike the power flow problem, this reformulated problem does not become singular at the point of collapse and can produce the bifurcation point very accurately.

In principle, the direct method allows finding the bifurcation points without implementing a loading procedure. There is, however, a problem of finding the initial guesses of the state variables and the eigenvector that may be resolved by initially loading the system along the stress direction. By doing so, the initial guess of state variables can be obtained. To evaluate the initial guess for the eigenvector, the inverse iteration method has been recommended to

calculate the eigenvector corresponding to the minimum real eigenvalue. The RTVSA code, however, utilizes Arnoldi's algorithm in Matlab software, also known as 'eigs' function, for simulation purposes.

The accuracy and advantage of the Direct Method algorithm has been shown with the help of the two plots below, wherein the Direct Method algorithm (Figure 9) is capable of determining the solution point (Point of Collapse) in one step, compared to 18 iterations taken by the Predictor-Corrector algorithm (Figure 8).




Figure 8: PoC Calculation by Predictor-Corrector Algorithm



Figure 9: Direct Method's Accelerated PoC Calculation

3.6. Boundary Orbiting Method

After reaching the Point of Collapse (PoC) solution point using a combination of the Continuation Parameter and Direct Method for a specified stress direction, the challenge is to orbit a static voltage stability boundary without repeating the time-consuming Continuation

Parameter method along a selected slice. This problem is effectively solved by using the Boundary Orbiting Method algorithm instead, in order to change the stress direction and thus, trace the security region.

The Boundary Orbiting Method (BOM) may face divergence, for instance due to singularities at boundary edges, and hence, the continuation parameter method is repeated for a new stress direction predicted at the last iteration of the orbiting procedure. An example of a voltage security region for two loads in injection space has been shown below in Figure 10.

The slope of the boundary is determined by the sign of the eigenvalue corresponding to the load element in the left eigenvector. The positive slope illustrated in Figure 10 is due to the opposite signs of the eigenvalues of the two loads. Similarly, eigenvalues of the same sign results in a negative slope as shown in Figure 12.




Figure 10: Security Region by Boundary Orbiting Method




Figure 11: Security Region for Two Loads (For Eigenvalues with Same Signs)

To test the accuracy of the boundary points obtained by the orbiting procedure, the Continuation Parameter method, along with the Direct Method, was simulated for certain stress directions. A typical test result, as shown in Figure 13 below, reveals the precision of the Boundary Orbiting Method.




Figure 12: Testing the Precision of Boundary Orbiting Method

The original PSERC Predictor Corrector algorithm was designed to switch generator to load buses (i.e., PV to PQ buses) due to the nature of the one-dimensional stressing process. However, the RTVSA proposed two-dimensional security region calls for a more complex two way switching of the buses from type PV to PQ and back to a PV bus as and when required. Hence, the RTVSA tool was modified to accommodate the required algorithm for conveniently switching the buses, thus generating a precise and smooth security region as shown below:




Figure 13: Switching of PV to PQ Buses and Vice-Versa

4.0 CERTS RTVSA Functional Specification

A functional specification document was developed for the Real-Time Voltage Security Assessment (RTVSA) tool that shall monitor voltage stability margin in real time, and will help the real time operators to manage this margin by controlling VAR resources, generation dispatch, and other resources on the transmission system. The application is expected to seamlessly integrate with the California ISO's real-time network analysis sequence (EMS) and run automatically after each successful state estimation process at every 5 minute intervals or on demand. The tool will help to identify the following:

1. Available voltage security margin
2. The most dangerous stresses in the system leading to voltage collapse
3. Worst-case contingencies resulting in voltage collapse and/or contingencies with insufficient voltage stability margin
4. Contingency ranking according to a severity index for voltage stability related system problems
5. Weakest elements within the grid and the regions most affected by potential voltage problems
6. Controls to increase the available stability margin and avoid instability
7. Information about voltage problems at the look-ahead operating conditions and for the worst-case contingencies (contingencies with large severity ranks) that may appear in the future
8. A real-time dispatcher's situational awareness-type wide area graphic and geographic displays.

This section summarizes the key technical and functional requirements for the California ISO RTVSA tool.

4.1. On-Line RTVSA Functional Overview

The RTVSA application will be integrated with California ISO's real-time network analysis sequence and run automatically after each successful state estimation process at every 5 minute intervals or on demand. The application will use data from the California ISO state estimation fed in every 5 minutes. The State Estimator (SE) solution, present in a Dynamic CIM/XML format, and the Detailed Network Model, present in a Static CIM/XML format, are outputs of California ISO's ABB Ranger Energy Management System (EMS); whereas the *RTVSA Supplementary Files* are predefined set of flat files obtained from an external source. The above mentioned three files are required by the tool to perform a thorough voltage security assessment.

The RTVSA tool shall feature two dominant modes of operation:

- 1) *Real-Time Modes* - Real-time operations mode
Real-time look-ahead mode

Under the 'Real Time Operations Mode', the RTVSA tool would perform a real time assessment utilizing the most current state estimator snapshot. On the other hand, the 'Real Time Look-Ahead Mode' would be useful in performing a 2-hour "look-ahead" predictive assessment by applying planned outage information available within the EMS and load forecast over the next 2 hours to the current state estimator snapshot.

- 2) *Study Mode* - Study mode offers off-line analysis capabilities on either the real-time data or on modified version of real-time solved cases.

The two available modes described above serve different purposes for two separate user environments:

- Real-time modes for Operator Display Console users
- Study modes for Stand-Alone Console users

The associated functionality offered within these two modes of operation is summarized in Table 4.

	<i>Real Time Modes</i>		<i>Study Modes</i>
	<i>Real Time</i>	<i>Look-Ahead</i>	
<i>Unidirectional Stressing</i>			
– <i>contingency screening & ranking</i>	×	×	×
– <i>real time alarming</i>	×		
– <i>voltage profiles</i>	×	×	×
– <i>MW/MVAR reserves</i>	×	×	×
– <i>single line diagrams</i>	×	×	×
– <i>Loading margins</i>	×	×	×
– <i>margin sensitivities to reactive support</i>	×	×	×
– <i>ranking of corrective controls</i>	×	×	×
– <i>identification of weak elements</i>	×	×	×
<i>Multidirectional Stressing</i>			
– <i>2-D, 3-D or N-D Security Regions (Nomograms) developed Offline</i>			×
– <i>real time assessment of operating point including contingency ranking, margins</i>	×	×	×
– <i>real time ranking of controls to steer away from the boundary</i>	×	×	×

Table 4: Summary of RTVSA Capabilities

The RTVSA processor will simultaneously operate between the two given modes, i.e. the real-time performance of the RTVSA tool will not be compromised upon simulation of one or many study cases at any given instance. To meet the computing needs of RTVSA, this tool shall be deployed across a cluster of high performance distributed computing, supporting a scalable Server-Client architecture. The *RTVSA Central Server* will be responsible for the data management, algorithmic computation, automation, and handling of remote client requests.

4.2. System Architecture

The overall functionality of the RTVSA application can be subdivided into three interdependent modules, which are:

1. 1) Input Subsystems:
2. 2) Central Server:
3. 3) User Interfaces:

Figure 14 of the proposed system architecture illustrates the affiliations among the various modules, as well as the constitutive functionalities of each of the consoles.

There are three sources of data **input subsystems** (California ISO EMS, Data Input Module, and Flat Files Storage) to the Central Server vis-à-vis the RTVSA tool. Depending on the tool's mode of operation, data can be acquired from any of the sources.




Figure 14: RTVSA System Architecture

As is shown in Figure 14, the California ISO's ABB-Ranger EMS generates Dynamic CIM/XML files at 5-minute intervals. This file in combination with the Static CIM (which contains network topology information) provides all the necessary data required to run a power flow. The *Data Input Module* primarily accounts for combining and managing the various files required by the RTVSA tool to perform power flow calculations and voltage security analysis during a real-time sequence. The *RTVSA Supplementary Files* are user predefined set of data that are essential while performing a complete voltage security assessment with the previously mentioned functionalities. These include Contingency List, Stressing Directions & Descriptor Variables, and Special Protection Schemes/Remedial Action Schemes.

The following are the data requirements for the RTVSA tool based on the operating modes:

Real-Time Modes:

- Data Source: California ISO EMS
 1. Valid State Estimator Solution
 2. Detailed Network Model
 3. System Component Status Information
 4. Available Power System Controls and their Priorities
 5. Limits (Voltage, Thermal, MVAR)
 6. Generator Model
 7. Distributed Slack Bus Information
 8. Low Voltage Load Models
 9. HVDC Models & Control Schemes
- Data Source: Data Input Module
 10. Contingency List
 11. Stressing Directions & Descriptor Variables
 12. Special Protection Schemes/Remedial Action Schemes

Study Modes:

- Data Source: Flat Files Storage
 1. Real-time solved case
 2. Modified real-time solved case
 3. RTVSA Supplementary Files

The minimum requirement for the data that is required to correctly describe the system equipments are Bus data with breaker information and status, transmission line data, transformers and tap control data, Generator data, Load data, Fixed Shunt data, Controllable shunt and static VAR devices (SVD) data, and HVDC controls data.

The **Central Server** houses the RTVSA application that performs simulations pertaining to voltage security assessment, processes network topology models as required by the system, a

Central Manager that streamlines the various processes, and a storage system for RTVSA application's study cases. The sub-modules that collectively define the functionality of the *Central Server* include Server Manager, Topology Processor, Flat Files Storage, and Simulation Engine

The *Simulation Engine* sub-module is the backbone of the system architecture. This unit is responsible for receiving data from the *Server Manager*, performing the various simulations, and sending the solution sets to the relevant users. It may run both in the real-time and study modes, simultaneously, while operating on a distributed computing platform.

The **User Interface** of the RTVSA application can be categorized under two domains of operation: 1) Operator Display Console for Real-time mode, which receives solution snapshots from the Central Server every time the RTVSA application runs on a set of real-time data. 2) The Stand-Alone Console caters to users of the RTVSA application under the study mode described earlier.

4.3. Visualization and User Interaction

The goal of the RTVSA application is to provide the real-time and study mode users with visualization capabilities that will assist them in making decisions. These capabilities can be classified under two broad domains: (1) Situational Awareness, and (2) Voltage Security Assessment.

Situational awareness type of displays present to the viewers simplified wide-area real time metrics, detection, alarming, trace, and trend visualization solutions. Accompanying the real-time displays would be scenarios under the worst case contingency. These include Voltage profiles at various buses, real and reactive power reserves across the system, Interface/line flows across key transmission corridors/voltage levels, and one-line diagrams.

Voltage Security Assessment displays demonstrate results of the Voltage Security Assessment tool under the look-ahead scenario with respect to key stressing direction(s). Such scenarios may be based on current operating conditions or under the worst case contingency. These illustrate voltage security conditions and metrics that help users study voltage stability and take decisions to prevent adverse situations. These capabilities include Real and reactive loading margins, Contingency ranking based on severity index (voltage margin, loading margin, etc.), Operating nomograms, Distance to instability, Weak elements information, and Corrective actions (preventive control, enhancement control)

The RTVSA visuals are displayed to both user interfaces: real-time user interface located in California ISO's Operator Consoles, and study-mode interface located in Stand-Alone Consoles. Since the simulation results obtained under each of the modes are case dependant (study or real-time case), the visual displays and techniques are different for the two users.

The Operator Console users view real-time results of RTVSA simulations under Current system scenario (base case) and System conditions under the worst case contingency. Display capabilities and features required for the Operator Console users to include Wide area geographic view of the current system conditions with the capability to zoom-in on a desired

local area, effective displays of priority based corrective controls information with rankings based on their effectiveness for each simulated stressing direction(s), and the capability to modify and customize display settings.

Study mode users shall interact with the system through a GUI in order to select the desired study case, make necessary modification to the same, and run simulations with preferred execution parameters (Supplementary Files) and controls. They would be able to study the reliability of the system with the help of various displays as well as by comparing multiple study cases. Display capabilities required for the stand-alone console users to include the ability to conveniently modify network topology, displays that indicate the available RTVSA execution control parameters and their current values, Emphasis on 'Voltage Security Assessment' type of displays, Capability to compare cases against each other, and Capability to plot simulation parameters and variables as a function of time.

5.0 Conclusion

The Real Time Voltage Security Assessment project was designed to be part of the suite of advanced computational tools for congestion management that is slated for practical applications in California in the next few years. The prototype application that was developed under this project is based on an extensive analysis of the existing VSA approaches, by surveying the leading power system experts' opinion worldwide, and also with feedback from industrial advisors. The mismatch between the core power system reliability needs and the availability of the VSA tools was a motivation to design the RTVSA prototype.

The robustness of the Parameter Continuation technique combines with the accuracy of the Direct Method and Boundary Orbiting Method makes the RTVSA prototype a preferred choice for an advanced VSA application.

The underlying concepts are applicable to the simple one-dimensional approach or the more complex multi-directional stressing to explore the entire voltage security region in the parameter space or in full P-Q injection space. The RTVSA algorithms are complex enough to handle system stress/relief by allowing the generator buses to switch to load buses and vice-versa.

The functional specification document prepared for the California ISO lays out the technical and functional requirements for a state-of-art Voltage Security Assessment tool that is designed to run in real time and is targeted towards real time operators to help them manage their reactive margin by controlling VAR resources, generation dispatch, and other resources on the transmission system. In particular, it allows operators to monitor system voltage conditions and provides real time reliability information related to reactive margin, abnormal nodal voltages, weak elements, contingency rankings, and recommended corrective actions. These functional specifications were used by the California ISO to select a vendor and to implement a commercial grade application to be in fully operation at the California ISO by summer 2008.

APPENDIX A – SURVEY 1 RESULTS TABLE

<i>Reviewer</i>	<i>VSA using Hyperplane Methods</i>
[1]	<ul style="list-style-type: none"> ❑ Recommends hyperplane approach for VSA. Furthermore suggests online hyperplane computation if loading directions and generating unit dispatch vectors are known a priori. Needs only up to 10 load flow runs with to compute “weak” elements.
[2]	<ul style="list-style-type: none"> ❑ Adopted similar direct methods for contingency ranking and also in hybrid system aimed to give a measure of angle as well as voltage stability. These experiences demonstrate the applicability of the proposed methodologies. ❑ Practical security boundary must account for grid topology changes (implying online security assessment).
[3]	<ul style="list-style-type: none"> ❑ More information needed about the hyperplane approach to VSA.
[4]	<ul style="list-style-type: none"> ❑ Has real potential – and it is not as unproven as some other concepts like interior point optimization.
[5]	<ul style="list-style-type: none"> ❑ Seems to be ideally suited for voltage instability where the phenomena is more localized and ideally suited for decision based on measurements ❑ Not convinced that Practical Dynamic Security Region direct method has any particular computational advantage over other methods
[6]	<ul style="list-style-type: none"> ❑ Experience has shown that secure operating space calculations done off line rarely match exact real time conditions, which may well be away from design conditions, implying online security assessment or adequate safety margins.
[7]	<ul style="list-style-type: none"> ❑ Least squares approximation of hyper planes with load flow simulations is prone to error enhancement for bad state estimator measurements.
[8]	<ul style="list-style-type: none"> ❑ Proposes New Electricity Transmission Software Solutions (NETSS) for voltage optimization, and the economic assessment of voltage support measurements (known as pilot points). ❑ It is important to determine the right locations to measure. Results depend on voltage dispatch strategies, loading conditions and system-specific equipment status.

<i>Reviewer</i>	<i>General comments on Tools and Methodologies Discussed in the Survey</i>
[9]	<ul style="list-style-type: none"> ❑ Advises to use equations like $J'(X) F(X) = 0$ to search for the closest points of the steady-state stability boundary. He also warns that the thermal constraints are often more limiting than stability constraints.
[10]	<ul style="list-style-type: none"> ❑ Methods not yet been utilized by grid operators. ❑ Emphasizes mode meter and system stiffness. ❑ Refers to WACS paper by Carson Taylor.

[11]	<p>Suggested the advantages of the following V&R products:</p> <ul style="list-style-type: none"> ❑ For off-line computations the exact boundary of dynamic security region (security nomogram) is automatically constructed using V&R's Boundary of Operating Region (BOR) software. ❑ For on-line computations, sensitivity-based n-dimensional boundary of operating region can be computed using BOR. The approximated boundary may be computed using Direct methods.
[12]	<ul style="list-style-type: none"> ❑ Visualization of voltage stability region in cut-set space has been implemented and a visualization system of dynamic security region in injection space to guarantee transient stability is in development for Henan Power System of CHINA ❑ It might be used in monitoring, assessment and optimization of security. "Up to now almost all research results of mine are about the dynamic security region in power injection space and the voltage stability region in cut-set power space. I think it might be used not only in security monitoring and control, but also in probabilistic security assessment."
[13]	<ul style="list-style-type: none"> ❑ Submitted a Proceeding of IEEE paper on WACS accepted for publication in May 2005. This paper co-authored by Taylor describes an online demonstration of a new response based wide area control system with discontinuous actions for power system stabilization.
[14]	<ul style="list-style-type: none"> ❑ Submitted a product overview of Energy Concepts International software "QuickStab".
[15]	<ul style="list-style-type: none"> ❑ Submitted a company overview and product list of Bigwood systems. ❑ This included information that showed partnerships with ABB to install BCU-DSA at the EMS of three power companies. BCU method is the only method used in EPRI Direct 4.0 and BCU method has been implemented by Siemens, at the Northern Power Company.
[16]	<ul style="list-style-type: none"> ❑ Provided areas of concern in the implementation of wide area monitoring such as: ❑ Validity of the system model to capture the phenomena of interest. ❑ Accuracy of angle measurements by PMUs. ❑ Accuracy of angle differences from PMUs of different vendors. ❑ Determining acceptable vs. unacceptable levels of angular separations among various pairs of PMU

APPENDIX B – SURVEY 2 RESULTS TABLE

Survey Bullets	BCTC	NE - ISO	Idaho Power	Midwest ISO	American Electric Power	PJM												
• Tool Name	Currently: In-house RTVSA Future: VSAT & Areva product	Power World	POM Real Time	VSAT & Areva product	Currently: In-house Voltage Contingency Analysis (VCA) <i>Note: Its not an assessment tool</i>	Real Time Voltage Stability Analysis and Control												
• Solution Provider	PowerTech and Areva	Power World	V & R Energy Systems Research	PowerTech and Areva	AEP	Siemens, Bigwood Systems, PJM												
• Contacts	Greg Dwernychuk, Djordje Atanackovic Vankayala, Vidya Vidya.Vankayala@bctc.com 804-293-5851	Xiaochuan Luo (413) 540-4236	--	Dede Subakti dsubakti@midwestiso.org 651-632-8472	Scott Lookwood; Kalle Chan splockwood@aep.com; kchan@aep 614-716-6671; 614-716-6623	Jianzhong Tong tongj@pjm.com 610-666-4621												
• Interfacing Capabilities																		
- Tool type	EMS/SCADA Application	Stand Alone Tool	Stand Alone Tool	EMS/SCADA Application	EMS/SCADA Application	EMS/SCADA Application												
- Data source	State Estimator Data	Areva State Estimator Data	State Estimator Data	State Estimator Data	State Estimator Data	State Estimator Data												
- External data input formats	CIM	PowerWorld AUX file	.epc, .raw, CIM/XML	.raw	--	.raw												
- External data output formats	CIM	.raw	--	.raw	--	--												
- Internal data formats	--	PowerWorld AUX file	POM format	--	Proprietary ABB database	database												
- Input data model	Node Breaker	Node Breaker	Node Breaker, Bus Branch	Node Breaker, Bus Branch	Bus Branch	Node Breaker, Bus Branch												
- Data integration specifics	Flat text files	Habitat, PI, Flat text files (AUX files)	Relational DB, Flat text files	eDNA, Flat text files (.raw files)	ABB database	real-time DB, Flat text files (.raw files)												
- Comments/Recommendations	<ul style="list-style-type: none"> The current file-transfer interface between EMS & VSAT is being replaced by JMS (Java Messaging Service) under the SOA (Service Oriented Architecture) environment - both at input & output of the tool. JMS is very useful when using structured data Historical files are stored in a 'history folder' for purposes of post-disturbance or trend analysis - separate from EMS database. Clustered computing, centralized processing Separation of planning and real-time environment 	<ul style="list-style-type: none"> EMS is generating PowerWorld network model and contingency list after each State Estimation run. An in-house Java code converts the State Estimator output along with the network information (acquired from EMS) into AUX files for PowerWorld. State Estimator (real-time data) is stored in PI (which does not contain the network information). Power World has the capability to process historical data acquired from PI. A configuration file maps PI tags to objects in AUX files A topology processor exists within Power World application 	<ul style="list-style-type: none"> A real-time tool should be capable of monitoring system constraints such as: thermal overloads, voltage deviation, voltage stability & dynamic security 	<ul style="list-style-type: none"> Our tools utilize Areva EMS node breaker model and Areva convert the files to *.raw format to be used by Powertech VSAT analysis. The result is fed back to Areva EMS for our operator display 	<ul style="list-style-type: none"> VCA performs approx. 400 contingency analysis on the modified operator's load flow, and displays results to operators/dispatchers AEP is considering installing Powertech's VSAT and Areva's EMS system 	<ul style="list-style-type: none"> There are 8 files that are transferred from EMS to VSAC (i.e. Network model, SE solution, contingencies, transfer interface definition, source/sink definition, facility limits, capability curve, load model). The interface between EMS & VSAC is being replaced by Enterprise Messaging Bus technology. The real-time DB, which is present in the EMS, acts as the data source to VSAC The input data [to the tool] can be stored as "compressed files" for 60 days (which is open to customization) for trend analysis. 												
• Processing Capabilities																		
- Available simulations:	Y/N	RT?	Freq	Y/N	RT?	Freq	Y/N	RT?	Freq	Y/N	RT?	Freq	Y/N	RT?	Freq	Y/N	RT?	Freq
Power Flow (PF)	✓	✓	5 mins	✓	✓	na	✓	✓	5 mins	✓	✓	na	✓	✓	30 mins	✓	✓	na
PF uses full model?	✓			✓			✓			✓			✓			✓		
Contingency analysis	✓	✓	5 mins	✓	✓	na	✓	✓	5 mins	✓	✓	5 mins	✓	✓	30 mins	✓	✓	5 mins
Distance to instability	✓	✓	5 mins	✓	✓	na	✓	✓	5 mins	x	x	x	x	x	x	✓	✓	5 mins
Most dangerous stress direction	✓	✓	5 mins	x	x	x	✓	✓	5 mins	✓	✓	na	x	x	x	✓	✓	5 mins
Weak elements	✓	✓	Manual	✓	✓	na	✓	✓	5 mins	x	x	x	x	x	x	✓	✓	5 mins
Margin sensitivities	✓	✓	Manual	✓	✓	na	✓	✓	5 mins	x	x	x	x	x	x	✓	✓	5 mins
Corrective actions	✓	✓	Manual	x	x	x	✓	✓	5 mins	x	x	x	x	x	x	✓	✓	5 mins
Operating nomograms	✓	✓	5 mins	x	x	x	✓	✓	5 mins	✓	x	x	x	x	x	x	x	x
Multidimensional?		2-D			--		Can handle 3-D			2-D transfers				No		No		
- Max # of buses supported	5,000 (open for expansion)	100,000 seconds	No limit	80,000	No limit	13,500												
- PF simulation speed (6000 bus)	1,200 powerflows < 3 mins		48,000 buses = 0.5 seconds	powerflow takes 3-5 seconds	3 minutes	n/a												
- How does it work in an 'on-line' real-time environment?	The RT-VSA is part of the real-time sequence and is triggered by the state estimator for every valid SE solution. The SE solution is sent by file transfer and real-time VSA results are sent back to EMS by file transfer as well - an in-house script.	<ul style="list-style-type: none"> We are still working on the implementation. PowerWorld simulator shall take the AUX file generated from the EMS, then the PV tool shall calculate the voltage limits. The automation server is available as an add-on component 	It uses dynamic created cases by SE every 5 minutes	Our tools utilize Areva EMS node breaker model and Areva convert the files to *.raw format to be used by Powertech VSAT analysis. The result is fed back to Areva EMS for our operator display	<ul style="list-style-type: none"> It is embedded in AEP's EMS system The SE output is stored in ABB's internal database in binary format, and VCA automatically picks it up for every valid SE solution 	Application takes SE solution with network model and SA contingencies to perform calculation of the margins (distance to instability) for each transfer interfaces, margin sensitivities, identifying weak elements, preventive and corrective controls.												
- Recommended simulations (for a real-time tool)	--	--	Monitor dynamics of the system by using phasor measurement data	--	--	--												
- Comments	Powertech's VSAT only displays worst contingencies, operating nomograms, and remedial actions (since these were the only requirements of the utility).		--	--	--													<ul style="list-style-type: none"> It utilizes 10 dual-core clustered machines (Windows 2003 server) and performs power flow on 14000 buses, along with 3000 contingencies and 1 or 2 stressing directions, within 3 minutes

Survey Bullets	BCTC	NE - ISO	Idaho Power	Midwest ISO	American Electric Power	PJM
Visualization Capabilities						
- Results' display options:	Yes/No	Yes/No	Yes/No	Yes/No	Yes/No	Yes/No
One-line diagrams	x	√	√	x	√	x
Geographical	x	√	√	x	√	x
Tabular	x	√	√	√	√	√
Graphical	√	√	√	√	x	√
Security Regions	√	√	√	√	x	x
Summary Dashboard	√	x	x	x	x	√
- Most useful visualization method	A two dimensional graph with the x and y axis being two separate generation sources. Operating point is displayed as well as generation limits and import/export limits	Graphical - (1) GIS based contours (Nodal LMP and Voltage), and (2) Bubble diagram (internal interface & wide area monitor)	Something that is easy to understand	--	<ul style="list-style-type: none"> One-line diagrams - in node-breaker format Tabular - (1) Contingency results in delta-V, (2) voltage profile at buses Geographical - Voltage contour plots (color coded) Power flow on interfaces and transmission lines 	--
- Recommended visuals (for a real-time tool)	What we have is adequate to meet our objectives	Alarm capability	Graphical Secure Operating Regions	Bar charts	--	--
- Comments	<ul style="list-style-type: none"> In addition to providing voltage stability results it has proven very useful for state estimator maintenance and evaluation of quality of state estimator results. Visualization schemes is provided by EMS itself (Areva's eterra platform) 	<ul style="list-style-type: none"> The future displays include: (1) 3D MVAR reserve, (2) Island display, and (3) Advanced displays as per operators' request 	--	--	<ul style="list-style-type: none"> Areva and Power World are helping AEP with visualization techniques AEP utilizes 32 50" LCD screens as their display medium (by Aydin Displays, INC) Node-breaker form of display is liked by the operators/dispatchers 	--
General Comments	<ul style="list-style-type: none"> RT-VSA was place on line Mar 2006 and has been executing with an availability of 97%. When the AREVA EMS goes into service in fall 2008, the intention is to integrate Powertech's VSAT as the primary voltage stability analysis tool. This tool is to be used by the planning group 	This is a follow-up to our control room visualization project. We have used PowerWorld as a visualization tool in control room and have established a real time synchronization between PowerWorld and EMS model. Naturally we plan to use the PV tool of PowerWorld simulator to calculate voltage limits. We may also consider other tools integrated with EMS to assess voltage security such as VSAT.	--	--	--	PJM RT VSA&C has real time mode and study mode. The study mode provides a very comprehensive tool to operation engineers and dispatchers to perform any kinds of study.
Notes:						
PF = Power Flow						
Y/N = Yes/No						
RT = Real Time						
Freq. = Frequency of simulation						

Survey Bullets	Bigwood Systems	V&R Energy	Powertech Labs	ABB	Energy Consulting Intl.										
• Tool Name	SecureSuite On-Line Voltage Stability Analysis and Enhancement - Real-Time Mode & Study Mode	Physical and Operational Margins (POM) Suite of Applications	VSAT (Voltage Security Assessment Tool)	Voltage Security Assessment (VSA) - Real Time and Study	QuickStab Professional and WeakLinks Professional										
• Contacts	Pat Causgrove 607-257-0915 pat@bigwood-systems.com	Marianna Vaiman 310-979-5966 marvaiman@vrenenergy.com	Hamid Hamadani 604-590-7476 hamid.hamadani@powertechlabs.com	Mani Subramanian 281 274 5045 mani.subramanian@us.abb.com	Savu C. Savulescu (212)913-9154 scs@eciqs.com										
• Interfacing Capabilities															
- Tool type	Stand Alone Tool	Stand Alone Tool	Stand Alone Tool	EMS/SCADA Application	EMS/SCADA Application										
- Data source	State Estimator, EMS database	State Estimator	State Estimator	SCADA, SE, Contingency cases	SE, dispatcher's PF, off line PF										
- External data input formats	pss/e all recent up to v30	epc, raw, CIM/XML	epc, raw, CIM/XML	--	epc, raw, IEEE										
- External data output formats	pss/e	epc, raw, CIM/XML	epc, raw, CIM/XML	CIM/XML	CSV and ASCII flat files										
- Internal data formats	common information technology data structures	--	proprietary binary format	ABB Data Base Management System	ASCII flat files										
- Input data model	Node/Breaker, Bus/Branch	Bus/Branch	Bus/Branch	Node/Breaker	Bus/Branch										
- Data integration specifics	Flat Text Files	Access, ACII, Excel files	Flat Text Files	ABB Relational Database	Flat Text Files										
- Comments	The tool is an application in our customers' EMS, but stand-alone vis-a-vis the vendor EMS	--	For existing VSAT users, Powertech has worked with EMS vendor to establish an effective and efficient data exchange (flat files) between EMS and VSAT. The same can be done for CAISO.	--	QuickStab has been seamlessly integrated, and is currently being used, in real-time, but is also available, and has been used for a long time, as a stand-alone off-line application										
• Processing Capabilities															
- Available simulations:	Y/N	RT?	Freq	Y/N	RT?	Freq	Y/N	RT?	Freq	Y/N	RT?	Freq	Y/N	RT?	Freq
Power Flow (PF)	√	√	5 mins	√	√	5 mins	√	√	5 mins	√	√	15 mins	√	x	x
PF uses full mode?	√			√			√			√			√		
Contingency analysis	√	√	5 mins	√	√	5 mins	√	√	5 mins	√	√	15 mins	√	√	5 mins
Distance to instability	√	√	5 mins	√	√	5 mins	√	√	5 mins	√	√	15 mins	√	√	5 mins
Most dangerous stress direction	√	√	5 mins	√	√	5 mins	x	x	x	x	x	x	√	x	manual
Weak elements	√	√	5 mins	√	√	5 mins	x	x	x	√	√	15 mins	√	x	manual
Margin sensitivities	√	√	5 mins	√	√	5 mins	√	√	manual	x	x	x	√	x	manual
Corrective actions	√	√	5 mins	√	√	5 mins	√	√	manual	x	x	x	√	x	manual
Operating nomograms	√	√	5 mins	√	√	5 mins	√	√	5 mins	x	x	x	x	x	x
Multidimensional?		2-D				computes n-D; 2-D & 3-D displays			1-D, 2-D			na			na
- Max # of buses supported	50,000 buses			none					100,000				none		35000 = input load-flow
- PF simulation speed (6000 bus)	0.1 sec			0.5 sec for 45000 bus system					0.07 sec				30-45 sec = base case + 10 conting.		1 sec for 3800 bus system
- How does it work in an 'on-line' real-time environment?	See attachment			See attachment					See attachment				See attachment		See attachment
- Comments	See attachment			See attachment					See attachment				See attachment		See attachment

Survey Bullets	Bigwood Systems	V&R Energy	Powertech Labs	ABB	Energy Consulting Intl.
• Visualization Capabilities					
- Results' display options:	Yes/No	Yes/No	Yes/No	Yes/No	Yes/No
<i>One-line diagrams</i>	x	√	x	x	x
<i>Geographical</i>	x	√	x	x	x
<i>Tabular</i>	√	√	√	√	√
<i>Graphical</i>	√	√	√	√	√
<i>Security Regions</i>	x	√	√	x	x
<i>Summary Dashboard</i>	√	x	x	x	x
<i>Others</i>	na	na	Bar charts of transfer limits	na	SCADA trending charts; bar charts; speedometer charts; PV curves
- Most useful visualization method	Primary interest is on defined Interfaces (flow gates), the limiting contingency and margins.	--	Bar charts of transfer limits, 2-D plots of secure regions	PV plots	SCADA trending charts which allow the operator to follow minute-by-minute the evolution of the distance to instability
- Comments	VSA&E implements a Real-Time Mode application and On-line Study mode application	--	Customized displays can be developed based on user requirements	The results are available for each solution point for all buses. Can be displayed using visualization tools (eg.contours). Weak buses can be color coded.	QuickStab's speedometer charts are also quite unique in the industry and have received great acceptance from the users
• Customer Information					
- Participating utilities	PJM Inteconnection, Tennessee Valley Authority, Taiwan Power Company	25 utilities in US, Asia and South America	20 major utilities are currently using or implementing VSAT in the control center.	CFE (Mexico), ComEd, ITC	See attachment
- Is the tool used by operators and/or dispatchers?	Yes	Yes	Yes	Operators (to some extent) and Mostly Dispatchers	Yes
• General Comments					
	See attachment	--	See attachment	See attachment	See attachment

Notes:

PF = Power Flow

Y/N = Yes/No

RT = Real Time

Freq. = Frequency of simulation

APPENDIX C – RTVSA FUNCTIONAL SPECIFICATION SUMMARY TABLE

<i>I</i>	<i>Input Data Specifications</i>
A	Valid state estimation solution snapshots available every 5 minutes in dynamic CIM format.
B	Detailed network model with node-breaker details in the static CIM format.
C	Contingency list containing all N-1 and some user-specified N-2 contingencies with the associated RASs
D	Stressing directions including generator dispatch sequence and load patterns, and associated RASs.
<i>II</i>	<i>Modes of Operation</i>
A	‘Real time operations mode’ presenting real time voltage stability analysis using the current state estimator snapshot.
B	‘Real time look-ahead mode’ providing predictive voltage stability analysis using a priori knowledge of planned outages and load forecast.
C	‘Study mode’ offering offline ‘what-if’ capabilities on the real time study cases.
<i>III</i>	<i>Functional Capabilities</i>
A	Contingency analysis and ranking based on voltage violations or loading margins for each stressing directions.
B	Voltage profiles, powerflow patterns, real/reactive reserves and loading margins to PoC under base case and most binding contingency.
C	Margin sensitivities to reactive support for each stressing direction.
D	Suggest and rank Enhancement Controls to increase reactive load margins and Preventive Remedial Controls to retract to a secure region.
E	Identify weak elements and their voltage sensitivities to reactive load margins.
F	Construct 2-D, 3-D or N-D security regions (nomograms) offline for a set of pre-defined stressing directions and descriptor variables.
G	Evaluate current state estimator snapshot within N-dimensional security regions.

H	Real-time alarming on voltage violations and low real/reactive load margins.
IV	<i>System Architecture & User Environments</i>
A	Central-server/multi-client architecture
B	Simulation engine performing the various simulations and analysis.
C	Topology processor to convert the node/breaker to bus/branch for analysis and vise-versa for presenting simulation results.
D	Flat file storage housing the most current real time solved cases and modified study cases.
E	Real time information presented within Operator Display consoles.
F	Study mode capabilities within stand-alone user consoles.
G	User interface to enable/disable automated controls, and modify simulation parameters, supplementary files (e.g. Stressing directions, contingency list, RASs).
V	<i>Visualization Capabilities</i>
A	Voltage profiles, real & reactive reserves at key stations, and power flows at the higher voltage levels within wide within wide area geographic displays.
B	Real and reactive loading margins as bar graphs.
C	One-line diagrams within Operator Displays.



Arnold Schwarzenegger
Governor

REAL TIME SYSTEM OPERATION 2006 – 2007

Real-Time Voltage Security Assessment
Functional Specifications for
Commercial Grade Application

Prepared For:

California Energy Commission
Public Interest Energy Research Program

Prepared By:

Lawrence Berkeley National Laboratory

CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

APPENDIX E

Month Year
CEC-500-2008-XXX-APE

Prepared By:

Lawrence Berkeley National Laboratory
Joseph H. Eto, Principal Investigator
Berkeley, CA 94720
Manu Parashar and Abhijeet Agarwal, Electric Power Group
Yuri Makarov, Pacific Northwest National Laboratory
Ian Dobson, University of Wisconsin, Madison
Commission Contract No. 500-02-004
Commission Work Authorization No: MR-041

Prepared For:

Public Interest Energy Research (PIER)
California Energy Commission

Jamie Patterson
Contract Manager

Mike Gravely
Program Area Lead
ENERGY SYSTEMS INTEGRATION

Mike Gravely
Office Manager
ENERGY SYSTEMS RESEARCH

Martha Krebs, Ph.D.
PIER Director

Thom Kelly, Ph.D.
Deputy Director
ENERGY RESEARCH & DEVELOPMENT DIVISION

Melissa Jones
Executive Director



DISCLAIMER

This report was prepared as the result of work sponsored by the California Energy Commission. It does not necessarily represent the views of the Energy Commission, its employees or the State of California. The Energy Commission, the State of California, its employees, contractors and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the uses of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the California Energy Commission nor has the California Energy Commission passed upon the accuracy or adequacy of the information in this report.

*Consortium for
Electric
Reliability
Technology
Solutions*

FUNCTIONAL SPECIFICATIONS For Commercial Grade Application

Prepared For:
California Independent System Operator (CA ISO)

Prepared by:
Consortium for Electric Reliability Technology Solutions (CERTS)

Funded By:
California Public Interest Energy Research
Transmission Research Program

Date: April 09, 2007

CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

The work described in this report was coordinated by the Consortium for Electric Reliability Technology Solutions with funding provided by the California Energy Commission, Public Interest Energy Research Program, through the University of California/California Institute of Energy Efficiency under Work for Others Contract No. 500-02-004, MR-041.

PREPARED FOR:

California Independent System Operator

PREPARED BY:

Electric Power Group
Manu Parashar, Ph.D. - Principal Investigator
Abhijeet Agarwal - Investigator

Pacific Northwest National Laboratory
Yuri Makarov, Ph.D. - Principal Consultant

University of Wisconsin, Madison
Ian Dobson, Ph.D. - Consultant

DATE:

April 2007

EXECUTIVE SUMMARY

Voltage stability is the ability of a power system to maintain acceptable voltages at all buses in the system under normal operating conditions and after being subjected to a disturbance. A system enters a state of voltage instability when a disturbance, increase in load demand, or change in system condition cause a progressive and uncontrollable decline in voltage. The main factor causing voltage instability is the inability of the power system to meet the demand for reactive power. *Voltage collapse* is the process or sequence of events accompanying voltage instability which leads to a low unacceptable voltage profile in a significant part of the system.

Objectives

Develop functional specifications for a Real-Time Voltage Security Assessment (RTVSA) tool that monitors voltage stability margin in real time, and help the real time dispatchers to manage this margin by controlling VAR resources, generation dispatch, and other resources on the transmission system. This application is expected to seamlessly integrate with the CA ISO's real-time network analysis sequence (EMS) and run automatically after each successful state estimation process at every 5 minute intervals or on demand. The tool will help to identify the following:

1. Available voltage security margin
2. The most dangerous stresses in the system leading to voltage collapse
3. Worst-case contingencies resulting in voltage collapse and/or contingencies with insufficient voltage stability margin
4. Contingency ranking according to a severity index for voltage stability related system problems
5. Weakest elements within the grid and the regions most affected by potential voltage problems
6. Controls to increase the available stability margin and avoid instability
7. Information about voltage problems at the look-ahead operating conditions and for the worst-case contingencies (contingencies with large severity ranks) that may appear in the future
8. A real-time dispatcher's situational awareness-type wide area graphic and geographic displays.

Approach

An extensive analysis of existing VSA approaches was conducted. This included research by Consortium for Electric Reliability Technology Solutions (CERTS), surveys from the leading experts' opinion worldwide, feedback from industrial advisors and brainstorm meetings with the projects' industry and academia consultants. A state-of-the-art combination of approaches and computational engines was identified and selected for implementation in this project. Subsequently, a multi-year project roadmap was developed which has guided the CERTS research on evaluating and demonstrating the recommended approaches on the CA ISO test cases.

This document describes the design, functional and visualization requirements for a Real-Time Voltage Security Assessment (RTVSA) tool, as well as CA ISO's preferences on certain implementation and visualization techniques.

CONTENTS

- 1. INTRODUCTION..... 1**
 - 1.1 BACKGROUND 1
- 2. ON-LINE RTVSA FUNCTIONAL OVERVIEW 3**
 - 2.1 MODES OF OPERATION 3
 - 2.2 RTVSA CAPABILITIES 4
 - 2.3 SYSTEM HARDWARE PERFORMANCE REQUIREMENTS 6
- 3. SYSTEM ARCHITECTURE 7**
 - 3.1 INPUT SUBSYSTEMS 9
 - 3.1.1 *CA ISO EMS* 9
 - 3.1.2 *Data Input Module* 9
 - 3.1.3 *Flat Files Storage* 9
 - 3.2 DATA REQUIREMENTS 10
 - 3.2.1 *Data Description* 10
 - 3.2.2 *Modeling Details* 12
 - 3.3 INPUT SUBSYSTEMS INTERFACE REQUIREMENTS 13
 - 3.4 CENTRAL SERVER 14
 - 3.4.1 *Server Manager* 14
 - 3.4.2 *Topology Processor* 15
 - 3.4.3 *Flat Files Storage* 15
 - 3.4.4 *Simulation Engine* 15
 - 3.5 USER INTERFACES 17
 - 3.5.1 *Operator Display Console* 17
 - 3.5.2 *Stand-Alone Console* 18
- 4. VISUALIZATION & USER INTERACTION 19**
 - 4.1 RECOMMENDED VISUALIZATION TECHNIQUES 19
 - 4.2 USER INTERACTION 20
- 5. SUMMARY TABLE 22**

LIST OF FIGURES

Figure 1 - RTVSA System Architecture	8
Figure 2 - Input Subsystems Interface	13

LIST OF TABLES

Table 1 - Summary of RTVSA capabilities 6
Table 2 - RTVSA Summary Table..... 22

ACKNOWLEDGEMENTS

Special thanks to California ISO staff Dr. Soumen Ghosh, Dr. Matthew Varghese, Mr. Dinesh Salem Natarajan, Mr. Patrick Truong, Mr. Steve Gillespie, Mr. Bill Ellard, Mr. Catalin Micsa, and Mr. David Le for their consultations to the project. The project team also appreciates contributions from Mr. Paul Bleuss, Mr. Robert Sparks, Mr. Ruhua You, Mr. Ray Camacho, Mr. J Sprouse, Mr. Y Zhang, Mr. Sirajul Chowdhury, Mr. Eric Whitley, and Dr. Enamul Haq.

Mr. Dave Hawkins (California ISO) for his expertise, comprehensive support, and advice.

Dr. Yuri V. Makarov and Dr. Ning Zhou (PNNL), for their role in suggesting the framework of the project, developing and selecting the methodology, participation in the brainstorm meetings, organizing face-to-face interviews and other contacts with the leading experts, advice, troubleshooting, literature review, and report writing.

Prof. Ian Dobson, (University of Wisconsin-Madison), for his role in suggesting and developing the methodology, participation in the brainstorm meetings and interviews, expertise and essential advice.

Dr. S. L. Greene (Price Waterhouse Coopers) for his help with the PSERC software.

Mr. Jim Cole (California Institute for Energy Efficiency) for sponsorship and support of this project, and participants of the TAC meeting for their thoughtful suggestions.

Mr. Joseph Eto (Lawrence Berkeley National Lab) for his support.

Participants of the CERTS surveys for their expertise and advice:

- Prof. M. Anantha Pai (University of California – Berkeley)
- Mr. Raymond L. Vice (Southern Company Services, Inc.)
- Dr. Savu Savulescu (Energy Concepts International Corp.)
- Dr. Michael Y. Vaiman and Mrs. Marianna Vaiman (V&R Energy Systems Research)
- Dr. Alex M. Kontorovich (Israel)
- Dr. Anatoliy Meklin (Pacific Gas and Electric)
- Prof. Marija D. Ilic (Carnegie Mellon University)
- Prof. Enrico De Tuglie (Politecnico di Bari, Italy)
- Prof. Gerald T. Heydt (Arizona State University)
- Mr. William Mittelstadt (Bonneville Power Administration)
- Prof. Yixin Yu (Tianjin University, China)
- Mr. Carson W. Taylor (Bonneville Power Administration)
- Prof. H.-D. Chiang (Cornell University)
- Dr. Navin Bhatt (American Electric Power)
- Kalle Chan (American Electric Power)
- Mani Subramanian (ABB)
- Vidya Vankayala (British Columbia Transmission Company)
- Xiaochuan Luo (New England ISO)
- Dede Subakti (Midwest ISO)
- Jianzhong Tong (PJM)
- Hamid Hamadani (Powertech Labs Inc.)
- Marianna Vaiman (V&R Energy)

Participants of the face-to-face interviews for their evaluation of the project and advice:

Prof. Ian Dobson (University of Wisconsin – Madison)

Prof. Vijay Vittal (Arizona State University)

Prof. Venkataramana Ajarapu (Iowa State University)

Dr. Zhao Yang Dong (University of Queensland, Australia)

Dr. Anatoliy Meklin (Pacific Gas and Electric)

Dr. Vitaliy Faybisovich (South California Edison)

Dr. Michael Vaiman and Dr. Marianna Vaiman (V&R Energy Systems Research)

1. INTRODUCTION

California Independent System Operator's (CA ISO) intends to implement a Real-Time Voltage Security Assessment (RTVSA) tool as a part of the suite of advanced computational tools for monitoring and preventing system problems and congestion management in the California ISO Control Area. Modern voltage assessment methods include such advanced functions as identification of real/reactive loading margins under different stressing conditions and associated weak elements, advice on selection of remedial actions and automatic development of operating nomograms and security regions. Real-time production-grade Voltage Security Assessment tools are becoming increasingly available nowadays. These tools are integrated with EMS/SCADA systems and use results from the state estimator.

1.1 Background

A system enters a state of voltage instability when a disturbance, increase in load demand, or change in system condition causes a progressive and uncontrollable decline in voltage. The main factor causing voltage instability is the inability of the power system to meet the demand for reactive power. *Voltage stability* is the ability of a power system to maintain acceptable voltages at all buses in the system under normal operating conditions and after being subjected to a disturbance. *Voltage stability margin* is the distance to instability determined for a selected *loading* or *stress direction* in parameter space.

It is known that voltage magnitudes alone are poor indicators of voltage stability or security. Voltages can be near normal with generators, synchronous condensers, and Static VAR compensators (SVCs) near current limiting levels, thus resulting in a possible voltage collapse. However, as a security problem distinct from voltage collapse, it is also desirable that the system voltage magnitudes remain within limits, and some of the control actions to maintain voltage magnitudes may also be of benefit in avoiding voltage instability. Sufficient reactive power reserves at generators and SVCs contribute strongly to maintaining voltage stability, but do not measure the ability of the transmission system to transmit reactive power. Both voltage magnitudes and reactive load margins are useful indicators; however, the voltage stability margin is the more accurate and complete metric for the proximity to voltage collapse.

CA ISO system operators need to know how to more effectively manage the grid and its reactive resources, including coordination with other organizations (interconnected system operators, load-serving entities, and generators), within today's changed operational environment, particularly during periods of system stress. Today, generation operated by independent power producers as well as generation operated by utilities are not responding to system-operator-directed voltage-VAR requirements as reliably as they did prior to restructuring. This condition, which is compounded by the continued, large volumes of long distance energy transactions in the Western Electricity Coordination Council (WECC), is creating very unusual and dangerous voltage patterns that could jeopardize the reliability of both the CA ISO's grid and the Western Interconnection. Inadequate, region-wide coordination of VAR reserves was a contributor the 1996 west coast blackouts, leading WECC to adopt stricter voltage-VAR requirements.

The California Energy Commission has been sponsoring the ongoing research to review, and assess the state-of-art in voltage security assessment that is geared towards a real time environment. This work has been conducted by the Electric Power Group and Pacific Northwest National Laboratory (CERTS members) with an active participation of the leading

University professors (through PSERC). At the onset of the project, a questionnaire had been distributed among 60 leading specialists worldwide in order to collect a collective and incorporate their feedback and ideas on the state-of-the art approaches and technologies in the area. Based on the responses and feedback from this expert community, a multi-year project roadmap was developed which has guided the CERTS research on evaluating and demonstrating the recommended approaches on the CA ISO test cases. Leading utilities have also been interviewed in parallel on their implementation of a similar voltage security assessment tool within their operations or planning environment.

2. ON-LINE RTVSA FUNCTIONAL OVERVIEW

The RTVSA application will be integrated with CA ISO's real-time network analysis sequence and run automatically after each successful state estimation process at every 5 minute intervals or on demand. The application will use data from the CA ISO state estimation fed in every 5 minutes. The State Estimator (SE) solution, present in a Dynamic CIM/XML format, and the Detailed Network Model, present in a Static CIM/XML format, are outputs of California ISO's ABB Ranger Energy Management System (EMS); whereas the *RTVSA Supplementary Files* are predefined set of flat files obtained from an external source. The above mentioned three files are required by the tool to perform a thorough voltage security assessment.

2.1 Modes of Operation

The RTVSA tool shall feature two dominant modes of operation:

- 1) *Real-Time Modes* - Real-time operations mode
- Real-time look-ahead mode

Under the 'Real Time Operations Mode', the RTVSA tool would perform a real time assessment utilizing the most current state estimator snapshot. On the other hand, the 'Real Time Look-Ahead Mode' would be useful in performing a 2-hour "look-ahead" predictive assessment by applying planned outage information available within the EMS and load forecast over the next 2 hours to the current state estimator snapshot.

In general context, the real-time mode will provide the system operators up-to-date information on the security status of the system with respect to voltage stability, including real time contingency analysis to ensure security of the system in the event of occurrence of any of critical contingencies, and compute key indices such as real or reactive loading margins under different stressing scenarios that quantify the degree of stability or instability for each case. The application will also suggest appropriate controls to the operator for increasing these margins.

The real-time case results are automatically stored into a centrally located rolling *Flat File* archive for future retrieval. The size of this rolling buffer of RTVSA solved cases must be configurable and shall be determined by CA ISO depending on the storage space requirements.

- 2) *Study Mode* - Study mode offers off-line analysis capabilities on either the real-time data or on modified version of real-time solved cases.

Under the study mode, the users of the stand-alone console would have the option and convenience to run the RTVSA simulation engine on a "study case". Such study cases are: (1) real time RTVSA solved cases archived overtime within the *Flat Files Storage* (under Central Server), (2) modified versions of the above mentioned real-time solved cases to study hypothetical scenarios. For instance, a study mode user may extract a previously archived RTVSA solved case from the *Flat Files Storage*, remove one or more transmission lines, manually specify stressing directions, resolve using the RTVSA simulation capabilities and perform a complete voltage security assessment, and export this as a new "study case" to the central server if so desired.

The RTVSA tool should restrict users from overwriting a real-time solved case. Any modifications made to these cases must be stored as a new study case. Although multiple

users would be allowed to simultaneously access the same file, the RTVSA tool should prevent everyone, except the first user of the case, from imposing changes to the same. This 'locking' feature of the tool would help in preventing certain possibly conflicts. However, all the users should have the option to perform simulations as well as to save the case (under a different name) in order to make the desired changes.

The two available modes described above serve different purposes for two separate user environments:

- Real-time modes for Operator Display Console users
- Study modes for Stand-Alone Console users

The associated functionality offered within these two modes of operation are described in details in the next section and summarized in Table 1.

2.2 RTVSA Capabilities

The RTVSA application shall offer the following categories of functional capabilities:

Real Time Voltage Stability Analysis under Unidirectional Stressing

- 1) *Contingency screening and ranking with respect to voltage limit violations or loading margins associated with known stressing direction* – The application should perform such contingency analysis under all N-1 conditions and some user defined N-2 conditions within each 5 minute real time cycle. A directional stressing, representative of the actual system loading conditions based on the real time dispatch schedule and load forecast, will be used for this analysis and the most binding contingency shall be identified.
- 2) *Wide area monitoring capabilities offering real time situational awareness to the operators on key indicators that are closely associated with voltage security* – These include voltage profiles at select buses, real or reactive reserves at key generators both under base case and the most binding contingency within geographic visualization. It also includes animated power flow visuals at the higher voltage levels (e.g. 500 kV, 230 kV, and 138 kV). The application will also have the capability of sending real time alarms to the end-users on voltage violations and insufficient real or reactive loading margins.
- 3) *Real time voltage stability analysis with known stressing direction* – The application shall present the loading margins (real or reactive) to the point of collapse under the base case and the most binding contingency, allowing for an additional 2.5% and 5% (user configurable) safety margins for N-1 and N-2 contingencies, respectively. ([Note to CA ISO: Voltage margins between base case and Point of Collapse \(POC\) solution may be an optional voltage stability metric](#)).
- 4) *Quantify the efficacy of reactive power support at the most effective buses in terms of their sensitivities* ([Note to CA ISO: These sensitivities translate to a linear constraint and is representative of the voltage stability limit associated with the unidirectional stressing which can be incorporated into Security Constrained Unit Commitment \(SCUC\) and Security Constrained Economic Dispatch \(SCED\) applications in the future](#)).
- 5) *Rank available corrective controls based on their effectiveness* – These actions may include enhancement controls that optimally increase the loading margin with respect to

the stressing direction, or remedial controls in the situation that a contingency may lead the system state into an insecure region.

- 6) *Identify the weak elements within the system associated with the one-dimensional stressing* – These are buses/regions with the grid that experience severe degradation in their voltage profile at the voltage collapse caused by the additional stressing. The proportions by which the voltage magnitudes will fall at these buses shall be presented.

Comprehensive Voltage Security Assessment under Multi-Directional Stressing

This is generalization of the above mentioned capabilities to a multi-directional stressing situation presenting the interaction and tradeoffs between different stressing directions, and the associated interpretation of the safe-operating region as a 2-D or 3-D (or higher dimensional) nomogram. The application shall:

- 1) *Develop and update voltage security regions offline on demand based on a set of pre-defined stressing directions* – The boundaries of these regions shall be expressed as piece-wise linear approximations (i.e., hyperplanes) in coordinates of key descriptive parameters (such as MW transfers, total MW generation, total MW loading, etc) associated with the stressing directions. As with the unidirectional stressing case, these security region boundaries too shall be representative of the most binding contingency in the various stressing directions
[\(Note to CA ISO: These hyperplanes are representative of the voltage stability limits associated with various stressing scenarios which can ultimately be embedded into SCUC and SCED applications\).](#)
- 2) *Real time voltage security assessment with respect to the multidirectional stressing* – The voltage stability margins between the most current base case operating condition and the security region boundaries shall be evaluated within each 5 minute real time cycle.
- 3) *Suggest appropriate controls to enhance margin to the boundary* – While the current operating point is within the security region, the application should also suggest appropriate control actions to optimally steer away from the closest boundary.

	Real Time Modes		Study Modes
	Real Time	Look-Ahead	
<i>Unidirectional Stressing</i>			
– <i>contingency screening & ranking</i>	x	x	x
– <i>real time alarming</i>	x		
– <i>voltage profiles</i>	x	x	x
– <i>MW/MVAR reserves</i>	x	x	x
– <i>single line diagrams</i>	x	x	x
– <i>Loading margins</i>	x	x	x
– <i>margin sensitivities to reactive support</i>	x	x	x
– <i>ranking of corrective controls</i>	x	x	x
– <i>identification of weak elements</i>	x	x	x
<i>Multidirectional Stressing</i>			
– <i>2-D, 3-D or N-D Security Regions (Nomograms) developed Offline</i>			x
– <i>real time assessment of operating point including contingency ranking, margins</i>	x	x	x
– <i>real time ranking of controls to steer away from the boundary</i>	x	x	x

Table 1 - Summary of RTVSA capabilities

(Note to CA ISO: The above mentioned unidirectional and multidirectional stressing analysis could be implemented through a 'staged approach' whereby the more straightforward unidirectional capabilities could be requested from the vendor over the short-term and successfully demonstrated at the CA ISO, and this capability could be enhanced at a follow-on stage and transformed to handle the broader multidirectional stressing for a more comprehensive security assessment.

2.3 System Hardware Performance Requirements

The RTVSA processor will simultaneously operate between the two given modes, i.e. the real-time performance of the RTVSA tool will not be compromised upon simulation of one or many study cases at any given instance.

To meet the computing needs of RTVSA, this tool shall be deployed across a cluster of high performance distributed computing, supporting a scalable Server-Client architecture. The *RTVSA Central Server* will be responsible for the data management, algorithmic computation, automation, and handling of remote client requests.

At any given time, the CA ISO anticipates that there will be XX real-time and YY off study mode users of the application. Under these conditions, the vendor will be asked to recommend appropriate hardware requirements to ensure that the CPU usage at the *RTVSA Central Server* not exceed 50% over any extended periods of time.

3. SYSTEM ARCHITECTURE

The overall functionality of the RTVSA application can be subdivided into three interdependent modules, which are:

1) Input Subsystems

- CA ISO EMS
- Data Input Module
- Flat Files Storage

2) Central Server

- Server Manager
- Topology Processor
- Flat Files Storage
- Simulation Engine

3) User Interfaces

- Operator Display Console (Real-Time Mode Interface)
- Stand-Alone Console (Study Mode Interface)

The following figure of the proposed system architecture illustrates the affiliations among the various modules, as well as the constitutive functionalities of each of the consoles.




Figure 1 - RTVSA System Architecture

3.1 Input Subsystems

There are three sources of data input to the *Central Server* vis-à-vis the RTVSA tool:

- 1) CA ISO EMS
- 2) Data Input Module
- 3) Flat Files Storage

Depending on the tool's mode of operation, data can be acquired from any of the above mentioned sources.

3.1.1 CA ISO EMS

California ISO's ABB-Ranger EMS generates Dynamic CIM/XML files at 5-minute intervals. This file in combination with the Static CIM (which contains network topology information) provides all the necessary data required to run a power flow. These files are available to the *Data Input Module* for purposes of combining them with the *RTVSA Supplementary Files*. The SE solution is passed on at a frequency set by the *RTVSA Central Server*. The Detailed Network Model file is not required frequently unless the network topology undergoes modifications.

(Note to CA ISO: The CA ISO EMS also houses a historian which stores the dispatcher's load flow saved cases for 7 days (subject to expansion). This database may be used for fetching files under the study mode, for purposes such as trending and post-disturbance assessment. Since both the Static and Dynamic CIM files are stored, the RTVSA tool should be equipped to match the timestamp on both the files during the retrieval process).

3.1.2 Data Input Module

The *Data Input Module* primarily accounts for combining and managing the various files required by the RTVSA tool to perform power flow calculations and voltage security analysis during a real-time sequence. With the help of a *Data Manager*, the Static and Dynamic CIM files, as well as the RTVSA Supplementary Files are combined into a single file to be transferred to the *Server Manager* within the *Central Server* module. This manager shall check for any missing or poorly transmitted data and take necessary actions.

The *RTVSA Supplementary Files* are user predefined set of data that are essential while performing a complete voltage security assessment with the previously mentioned functionalities. These include:

- Contingency List
- Stressing Directions & Descriptor Variables
- Special Protection Schemes/Remedial Action Schemes

These files are fetched for each real-time simulation sequence, and a copy of these files is stored in *Flat Files Storage* since they are needed during offline studies. The tool shall offer a convenient way (e.g. GUI) to edit the above mentioned supplementary files.

3.1.3 Flat Files Storage

Please refer to page 15 for details.

3.2 Data Requirements

The following are the data requirements for the RTVSA tool based on the operating modes:

Real-Time Modes:

- Data Source: CA ISO EMS
 1. Valid State Estimator Solution
 2. Detailed Network Model
 3. System Component Status Information
 4. Available Power System Controls and their Priorities
 5. Limits (Voltage, Thermal, MVAR)
 6. Generator Model
 7. Distributed Slack Bus Information
 8. Low Voltage Load Models
 9. HVDC Models & Control Schemes

- Data Source: Data Input Module
 10. Contingency List
 11. Stressing Directions & Descriptor Variables
 12. Special Protection Schemes/Remedial Action Schemes

The RTVSA tool running in real-time modes would require all the above mentioned data to be present in the *Central Server*.

Study Modes:

- Data Source: Flat Files Storage
 - 1) Real-time solved case
 - 2) Modified real-time solved case
 - 3) RTVSA Supplementary Files

While running the RTVSA tool under a study mode, the user has the option to choose between the two study cases – real-time solved case or the modified solved case. RTVSA Supplementary Files would also be required here for a complete voltage security assessment with the previously mentioned functionalities.

3.2.1 Data Description

The following are details on the required list of data:

1. Valid SE solution

Contains Nodal voltage magnitudes and phase angles, and is the solved load flow solution obtained from the EMS that guarantees convergence.

2. Detailed Network Model

Contains information in a volume sufficient for detailed power flow simulations, under the CA ISO standards, i.e., branch information (connectivity data, line impedance), breaker status, etc

3. System Component Status Information

Includes the current status of generators, transmission circuits, transformers, switching devices, and other system components

4. Available Power System Controls and their priorities¹

The available controls and their priorities must be provided to support the control advisory function of the RTVSA application. Examples are:

- Tap Changers
- Static VAR Compensator (SVC)
- Fixed and Controllable Shunt
- Generator Redispatch, etc.

5. Limits (Voltage, Thermal, MVar, Others)²

Consists of operational limits of system facilities/components that are to be specified in appropriate units, e.g. transformer limits in MVA, line limits in Amps, etc

6. Generator Model

Required information for generator modeling, such as:

- MVA ratings
- Q_{max} , Q_{min} values
- Leading and lagging power factor

7. Distributed Slack Bus Information

Required for governor power flow simulations

8. Low Voltage Load Models

These models (static characteristics) should cover the low voltage load behavior and voltage collapse situations. Any load model switching for low voltage cases should be clearly described by the vendor.

9. HVDC Models & Control Schemes¹

Note: Vendors are requested to provide details on HVDC modeling and control schemes their RTVSA tool would feature.

10. Contingency List

Consists of:

- All (N-1) and some (N-2) contingencies, *or*
- User specified contingency list
- Any Remedial Action Schemes (RASs) associated with these contingencies

11. Stressing Directions & Descriptor Variables

Contains:

- Generator dispatch sequence & pattern
(*Should be capable of factoring in CA ISO's Unit Commitment Operating Procedures*)
- Load stress pattern
(*Should feature the capability to assign participation factors to loads on an individual, area or zonal basis*)

Descriptor variables are parameters that influence the voltage stability margin in certain parts of the system (voltage stability problem areas). Examples of descriptor variables are: total area load, power flows in certain transmission paths, total area generation, and so on. The operating engineers' should be able to define/modify these variables for the known voltage problem areas in the course of offline studies.

¹ The study mode users should have the capability to turn off the power system controls for simulation purposes.

² The study mode users should be able to turn off the operational limits for study purposes.

12. Special Protection Schemes/Remedial Action Schemes

During the system stressing process (mentioned in 'Data Description #11' above) and contingency analysis, it is required for the RTVSA tool to automatically trigger Remedial Action Schemes (RAS) or Special Protection Schemes (SPS) to provide realistic voltage stability margins.

3.2.2 Modeling Details

Accurate modeling of voltage stability conditions and parameters that influence them is a must for the RTVSA application. This includes the following requirements:

- (1) Voltage stability conditions simulated using full power flow Jacobian singularity conditions.
- (2) The algorithms used must converge accurately to the power system equilibrium in all cases in which that equilibrium exists, including cases at and nearly at voltage collapse.
- (3) Low voltage/voltage stability load models including the models reflecting the OLTC action (e.g., constant active and reactive power for the OLTC regulation range), static characteristics representing load behavior outside the regulation range of the OLTC, and static characteristics approximately reflecting load behavior at the low voltage conditions
- (4) Special Protection Schemes (SPS), Under-Voltage Protection schemes, and Remedial actions schemes (including remote RAS)
- (5) Consistent treatment of the discrete event sequences, for example, the switching sequence of capacitors (non-uniqueness of these sequences for a given stressing path is not acceptable)
- (6) Distributed slack bus/post-transient power flow (governor) model
- (7) Generation dispatch options reflecting California ISO models and practices (e.g. generators maximum and minimum active power output, reliability must-run units, emission-induced constraints, etc)
- (8) Multi-area power flow
- (9) Adequate modeling of the reduced (equivalent) parts of the system, especially, voltage and governor responses of the reduced part of the system.

The RTVSA tool should be capable of handling CIM/XML file format at both the input and output ends. The minimum requirement for the data that is required to correctly describe the system equipments have been briefly mentioned here.

1. Bus data
 - Consisting of all bus types: swing/slack, PQ, PV, HVDC
 - Representation with breaker information and status
2. Transmission line data
 - Consisting of: out-of-service, in-service, bypassed, and HVDC lines
 - Representation with lossy model
3. Transformers and tap control data
 - Model types: 2 & 3 winding transformers
 - Control types: Fixed impedance with no control, voltage, MW, and MVAR control

4. Generator data
 - Generator remote regulation
 - Reactive power limits as Q_{\min}/Q_{\max}
5. Load data
 - Static model as described under Modeling Details (3) above
6. Fixed Shunt data
7. Controllable shunt and static VAR devices (SVD) data
 - SVD control types: locked, stepwise control, continuous control, stepwise control with deadband, on/off control with deadband
 - Models any controllable capacitive/inductive devices, such as:
 - o Static VAR compensators (SVC)
 - o Mechanically Switched Capacitors (MSC)
 - o Synchronous Condensers
8. HVDC controls
 - The vendor is requested to provide details on the control modes featured by their tool.

Note: The vendor is asked to provide model parameterization details for their tool, as well as any additional modeling details beyond the above mentioned set of minimum requirements.

3.3 Input Subsystems Interface Requirements

As described above, the RTVSA processor may operate, though simultaneously, under the two mentioned modes. The files required under each of the modes have also been described in details. The question that yet remains to be answered is how should data be transferred from one module to another? Specifically:

- Data flow along *Interface 1* (refer to Figure 2 below)




Figure 2 - Input Subsystems Interface

The approach that will be used to transfer data along Interface 1 should result in the seamless integration of the RTVSA tool with CA ISO's EMS, thus minimizing time lag and enabling the tool to run in "real-time". Industry standard technologies such as, messaging queue, web services, COM/DCOM, etc shall be used for this data transfer. Vendors are requested to suggest feasible options for this data exchange between RTVSA and CA ISO's ABB-Ranger EMS. Implementation details will be worked out in close consultation between CA ISO IT/Network Applications experts and the chosen vendor.

Note: The vendor is requested to recommend supported interface options in their responses.

3.4 Central Server

The *Central Server* houses the RTVSA application that performs simulations pertaining to voltage security assessment, processes network topology models as required by the system, a Central Manager that streamlines the various processes, and a storage system for RTVSA application's study cases.

This module is capable of simultaneously handling both real-time and study mode data processing based on the State Estimator solutions and study cases, respectively. The real-time data set solution outputs are displayed to the real-time mode interface users, whereas the study case results are demonstrated to the study mode interface users. Both these results are also stored in *Flat Files Storage* for trending purposes, post-disturbance analysis and future retrieval. The *Central Server* allows customization to server settings such as alarms, threshold levels, and simulation frequency.

The sub-modules that collectively define the functionality of the *Central Server* include:

- 1) Server Manager
- 2) Topology Processor
- 3) Flat Files Storage
- 4) Simulation Engine

The tasks of each of the sub-modules will now be discussed in details.

3.4.1 Server Manager

This sub-module is responsible for the following four tasks:

1) *Automation Scheduler* – automates the process of retrieving the real-time data at regular intervals (every 5 minutes for instance); these files are the SE snapshot, RTVSA Supplementary Files and the Detailed Network Model (when needed).

2) *Processes Manager* – manages the various sub-modules contained within the Central Server (i.e. topology processor, simulation engine, and flat files storage) under both the real-time and study mode environments. It procures either real-time data or study cases, performs the relevant topology processing with the help of the *Topology Processor*, executes the voltage security assessment application via the *Simulation Engine*, and stores the solutions (depending on server settings) in *Flat Files Storage*. These solution files are also sent to the relevant users upon certain processing of its network topology.

3) *Status and Logging Manager* – is responsible for displaying the current server status relevant to users, such as the details of the data set the Simulation Engine is currently working upon, time at which the process started, and the number of contingencies it has already simulated to name a few. It also maintains solution logs, and time & name stamps for every solved/modified case. This helps in identifying appropriate solved cases while retrieving them from the storage module.

4) *Client Request Manager* – identifies and pursues requests that originate from the Stand-Alone Console. These requests can be in the form of:

- Retrieval of study cases from Flat Files Storage
- Modification request to RTVSA Supplementary Files present in the storage
- Submission of study cases for simulations

The Client Request Manager should restrict users from overwriting a real-time solved case. Although the Manager may allow multiple users to simultaneously access the same file, it should prevent everyone, except the first user of the case, from imposing changes to the same. This 'locking' feature prevents from overwriting of study cases or causing system deadlocks and bottlenecks. However, all the users should have the option to perform simulations as well as to save the case (under a different name) in order to make the desired changes.

3.4.2 Topology Processor

The topology processor sub-module, as the name suggests, deals in either converting node/breaker model to bus/branch format and vice-versa or validating network modifications submitted by Stand-Alone Console users. For instance, it checks for and eliminates any islands (or hanging buses) that have been created due to the removal of transmission line(s) in study cases submitted by users.

The Detailed Network model, which the Server Manager receives as a real-time data in node/breaker model format, is converted to bus/branch format as required by power flow algorithms. Additionally, the Simulation Engine solutions are mapped back to the node/breaker model for one-line diagram displays to users.

3.4.3 Flat Files Storage

The storage space provided in the Central Server stores the following information:

- Real-time solved cases - solution outputs from Simulation Engine for each real-time data set
- Modified real-time solved cases - modifications to real-time solved cases submitted by users and/or the simulation solutions thereto
- Original or modified versions of RTVSA Supplementary Files

Every modified case has a name tag that identifies the user responsible for making the change(s). While a user is working upon a study case, the system (specifically the Client Request Manager) prevents another user from using the same case for modification purposes.

3.4.4 Simulation Engine

The *Simulation Engine* sub-module is the backbone of the system architecture. This unit is responsible for receiving data from the *Server Manager*, performing the various simulations, and sending the solution sets to the relevant users. It may run both in the real-time and study modes, simultaneously, while operating on a distributed computing platform.

All the data that is delivered to the *Central Server* is rendered to the Engine for simulation purposes. Moreover, the *Detailed Network Model* file (received from the EMS in a Node/Breaker format) is converted into a Bus/Branch model (by the *Topology Processor*) as required by power flow algorithms.

Perhaps one of the most important aspects of this document is the simulation capabilities offered by the RTVSA application. Apart from calculating the power flows and determining the nodal voltages and angles, the tool should feature the following mentioned simulation capabilities for given stressing direction(s):

- 1) Contingency Analysis & Ranking
- 2) Distance to Instability
- 3) Corrective Actions
 - a. Enhancement Control
 - b. Preventive Remedial Control
- 4) Weak Elements Information

In the case that multiple stressing directions have been defined, the application shall create 2-D, 3-D or N-D operating nomograms in coordinates of key descriptive parameters (such as MW transfers, total MW generation, total MW loading, etc).

1) Contingency Analysis

Contingency analysis is to be performed for all (N-1) and some (N-2) contingencies that may occur in the system. This process shall be repeated for every 5 minute real-time sequence. The contingency analysis simulations should:

- Perform full AC power flow computations for each stressing direction(s). Generation re-dispatch may be involved if the corresponding contingency includes forced generator unit outages.
- Trigger any Remedial Actions Schemes (RASs) associated with such contingencies.
- Rank contingencies based on voltage violations and/or loading margins.

Note: If the RTVSA tool utilizes a screening process for contingency simulation, the vendor is requested to provide detailed description of this process.

2) Distance to Instability

This simulation capability is particularly useful in providing users with useful margin indices, such as voltage margin, real & reactive load margin, etc. Distance to instability, or to voltage collapse, is to be calculated for both the base case scenario and under the worst case contingency for each stressing direction(s).

During the process of system stress, it is required for the RTVSA tool to automatically trigger Remedial Action Schemes (RASs) to provide realistic distance to instability.

Note: Vendors are requested to provide details on the computation technique used to calculate distance to instability.

3) Corrective Actions

Corrective controls provide users with the ability to increase the stability margin, or steer away from the region of instability should certain critical contingency(s) occur. These controls shall be ranked based on their effectiveness for each simulated stressing direction(s).

Enhancement control capabilities shall allow users to increase the stability margin by specifying an amount (in %) of improvement desired under both the base case and worst-

case contingency. This capability includes controlling of the phase shifters, ULTCs, static VAR devices, controllable shunts, etc for improving the current system state.

Preventive remedial controls provide the ability for users to secure the system from critical (or insecure) contingencies by suggesting priority-based control actions to improve margin indices. For instance, if the current base case scenario indicates sufficient load margin, whereas the occurrence of a certain contingency(s) places the system in the insecure operating region, the tool would determine 'preventive' controls to retract into a safe operating region.

4) Weak Elements Information

This simulation capability shall provide voltage sensitivity information with respect to stressing direction(s). This may be at various buses/regions that experience severe degradation in their voltage profile under additional stressing representative of voltage collapse patterns.

5) Operating Nomograms

The boundaries of the 2-D, 3-D or N-D operating nomograms shall be expressed as piece-wise linear approximations (i.e., hyperplanes) in coordinates of key descriptive parameters (such as MW transfers, total MW generation, total MW loading, etc.) associated with the stressing directions.

3.5 User Interfaces

The users of the RTVSA application can be categorized under two domains of operation:

- 1) Real-time mode users *or* users of the Operator Display Console
- 2) Study mode users *or* users of the Stand-Alone Console

3.5.1 Operator Display Console

Operator Display Console receives solution snapshots from the Central Server every time the RTVSA application runs on a set of real-time data. The users of this console, called real-time mode users, view results to RTVSA tool's simulations (consisting of the ones mentioned in Section 3.4.4) in the two mentioned modes, namely: real-time operations mode and real-time look-ahead mode.

The *Real-Time Mode Interface* facilitates exchange of unidirectional data from the *Server Manager* located within the *Central Server*. It receives only the real-time solutions data for display purposes, and restricts users from interacting with the Central Server. The interaction capabilities of these users are limited to the post processing of solution data. These include customization of display settings, such as, assigning a value (say 5%) to the reactive load margin on top of the most binding contingency – a criteria mandated by Western Electric Coordinating Council (WECC).

A Configuration Graphical User Interface (GUI) allows users to switch between the various display options, as well as update and modify the current display methodology. The users have the capability to look at the system from a bird's eye view (wide-area visualization), and subsequently zoom into the area of interest (local area view and/or one-line diagrams).

3.5.2 Stand-Alone Console

The Stand-Alone Console caters to users of the RTVSA application under the study mode described earlier. The users have the option to choose from any of the following two study cases:

- 1) RTVSA tool's real-time solved case
- 2) User modified real-time solved case

After selecting the appropriate case, the user may modify solution parameters and network topology, and with the help of certain required Supplementary Files, perform simulations to study hypothetical scenarios.

The *Study Mode Interface* sub-module is responsible for exchanging data to and from the Central Server. The *Client Request Manager*, which is a part of the Server Manager, manages various requests originating from the Stand-Alone Console users. The users shall have the capability to request files from the Flat Files Storage (i.e., study cases) to conduct studies. The Simulation Engine performs the desired calculations and returns the results to the Server Manager. Subsequently, the Server Manager [optionally] saves results in Flat Files Storage (along with the appropriate time and name stamps), as well as passes on the solutions to the Study Mode Interface for display purposes.

The study-mode console is to be equipped with an effective and user-friendly graphic user interface with point and click features, and pull-down menus. Modern graphics shall be used for the quick assessment of complex situations.

The study-mode RTVSA environment must be easy to understand and manipulate. The following is the summary of the features that shall be available to users:

1. Ability to request study cases and save modification and simulation results thereto.
2. Ability to adjust certain system parameters and to compute the sensitivity of the results to changes in parameters: this may apply to selection of fewer or more contingencies, together with the ability to construct system scenarios for study purposes.
3. Capability to perform 'what-if' and post-disturbance analysis on desired case(s)
4. Ability to visualize simulation results through appropriate graphical means. The capability to plot simulation parameters and variables as a function of time (trend analysis) is also desirable.
5. Ability to compare simulation results obtained from multiple cases.

4. VISUALIZATION & USER INTERACTION

The goal of the RTVSA application is to provide the real-time and study mode users with visualization capabilities that will assist them in making decisions. These capabilities can be classified under two broad domains: (1) Situational Awareness, and (2) Voltage Security Assessment.

Situational Awareness

Situational awareness type of displays present to the viewers simplified wide-area real time metrics, detection, alarming, trace, and trend visualization solutions. Accompanying the real-time displays would be scenarios under the worst case contingency. These include, but are not limited to:

- ✓ Voltage profiles at various buses
- ✓ Real and reactive power reserves across the system
- ✓ Interface/line flows across key transmission corridors/voltage levels
- ✓ One-line diagrams

Voltage Security Assessment

The display capabilities under this category demonstrate results of the Voltage Security Assessment tool under the look-ahead scenario with respect to key stressing direction(s). Such scenarios may be based on current operating conditions or under the worst case contingency. These illustrate voltage security conditions and metrics that help users study voltage stability and take decisions to prevent adverse situations. These capabilities include, but are not limited to:

- ✓ Real and reactive loading margins
 - Margin at base case to point of collapse (POC)
 - Margin under worst case contingency base case to POC
- ✓ Contingency ranking based on severity index (voltage margin, loading margin, etc.)
- ✓ Operating nomograms
- ✓ Distance to instability
- ✓ Weak elements information
- ✓ Corrective actions (preventive control, enhancement control)

4.1 Recommended Visualization Techniques

Based on discussions held with CA ISO operators and operating engineers/planners, the following are some of the preferred visualization techniques mentioned:

- "Situational Awareness" type wide area geographic color-coded contour plots displaying information for both the base case and under the worst-case contingency about:
 - Nodal voltages
 - Real & Reactive reserves

- Interface/line flows with respect to flow limits
- The color coding legend on contour plots shall accommodate different 'normal' operating ranges for the different substations. For example, a particular 500 kV bus at a substation may normally operate at 525 kV and this should be appropriately indicated by the 'normal' color used within the legend.
- For each of the operating modes, the users would like to be able to view the loading margins as bar graphs under the base case and the most binding contingency.
- Additionally, for the real time modes, and under the most binding contingency, the line flows should also be shown within a geographic display at least at the higher voltage levels. The more detailed flows under these situations should be visible on one-line diagrams within CA ISO's Operator Display Consoles.
- The ability to filter and view information by regional buses and by voltage levels
- The tools should support alarming capabilities when voltage profiles and/or margins drop below pre-defined operating limits. These limits should be configurable.

4.2 User Interaction

The RTVSA visuals are displayed to both user interfaces: real-time user interface located in CA ISO's Operator Consoles, and study-mode interface located in Stand-Alone Consoles. Since the simulation results obtained under each of the modes are case dependant (study or real-time case), the visual displays and techniques are different for the two users.

The Operator Console users view real-time results of RTVSA simulations under four system scenarios:

- (1) Current system scenario (base case)
- (2) System conditions under the worst case contingency
- (3) 2 hour look-ahead condition under base case
- (4) 2 hour look-ahead conditions under the worst case contingency

Although presenting multiple plots may sound intimidating to users, a clever layout of the visuals may reduce the involved complexities. For instance, the "current mode" tab would display plots (1) & (2), and by simply clicking on the "look-ahead" tab, the displays would switch to plots (3) & (4) – thereby replacing the old values with new one while keeping the display pattern (or technique) unchanged.

Here are some of the display capabilities and features required for the Operator Console users:

- Wide area geographic view of the current system conditions with the capability to zoom-in on a desired local area
- 'Situational Awareness' and 'Voltage Security Assessment' type displays for the above mentioned four system scenarios
- Effective displays of priority based corrective controls information with rankings based on their effectiveness for each simulated stressing direction(s).
- The capability to modify and customize display settings

Study mode users shall interact with the system through a GUI in order to select the desired study case, make necessary modification to the same, and run simulations with preferred execution parameters (Supplementary Files) and controls. They would be able to study the reliability of the system with the help of various displays as well as by comparing multiple study cases. The following are some of the display capabilities required for the stand-alone console users:

- The ability to conveniently modify network topology through means such as one-line diagrams, tabular displays, etc. The same applies for the various user-defined RTVSA supplementary files.
- Displays that indicate the available RTVSA execution control parameters and their current values.
- Emphasis on 'Voltage Security Assessment' type of displays.
- Capability to compare cases against each other through appropriate graphical means which focus on the key parameters associated with various comparisons (e.g. indices, margins, sensitivities and trends). For example, it would be desirable to be able to assess the sensitivity of results to any parameter of a component via clicking on that component in the GUI.
- Capability to plot simulation parameters and variables as a function of time.

5. SUMMARY TABLE

The RTVSA feature set and functional capabilities are summarized in the table below:

I	<i>Input Data Specifications</i>
A	Valid state estimation solution snapshots available every 5 minutes in dynamic CIM format.
B	Detailed network model with node-breaker details in the static CIM format.
C	Contingency list containing all N-1 and some user-specified N-2 contingencies with the associated RASs
D	Stressing directions including generator dispatch sequence and load patterns, and associated RASs.
II	<i>Modes of Operation</i>
A	'Real time operations mode' presenting real time voltage stability analysis using the current state estimator snapshot.
B	'Real time look-ahead mode' providing predictive voltage stability analysis using a priori knowledge of planned outages and load forecast.
C	'Study mode' offering offline 'what-if' capabilities on the real time study cases.
III	<i>Functional Capabilities</i>
A	Contingency analysis and ranking based on voltage violations or loading margins for each stressing directions.
B	Voltage profiles, powerflow patterns, real/reactive reserves and loading margins to PoC under base case and most binding contingency.
C	Margin sensitivities to reactive support for each stressing direction.
D	Suggest and rank Enhancement Controls to increase reactive load margins and Preventive Remedial Controls to retract to a secure region.
E	Identify weak elements and their voltage sensitivities to reactive load margins.
F	Construct 2-D, 3-D or N-D security regions (nomograms) offline for a set of pre-defined stressing directions and descriptor variables.
G	Evaluate current state estimator snapshot within N-dimensional security regions.
H	Real-time alarming on voltage violations and low real/reactive load margins.
IV	<i>System Architecture & User Environments</i>
A	Central-server/multi-client architecture
B	Simulation engine performing the various simulations and analysis.
C	Topology processor to convert the node/breaker to bus/branch for analysis and vice-versa for presenting simulation results.
D	Flat file storage housing the most current real time solved cases and modified study cases.
E	Real time information presented within Operator Display consoles.
F	Study mode capabilities within stand-alone user consoles.
G	User interface to enable/disable automated controls, and modify simulation parameters, supplementary files (e.g. Stressing directions, contingency list, RASs).
V	<i>Visualization Capabilities</i>
A	Voltage profiles, real & reactive reserves at key stations, and power flows at the higher voltage levels within wide within wide area geographic displays.
B	Real and reactive loading margins as bar graphs.
C	One-line diagrams within Operator Displays.

Table 2 - RTVSA Summary Table